

SOP-001 - Pump Isolation & Mechanical Seal Replacement (CP200)

Standard Operating Procedure | Tier 1

1. Purpose

To safely isolate an MSC-CP200 pump and replace the cartridge mechanical seal, restoring the OEM-specified seal flush plan.

2. Procedure

1. Obtain a work permit and confirm the pump is scheduled out of service.
2. Stop the pump locally and verify no rotation.
3. Close suction and discharge isolation valves; tag them shut.
4. Isolate the motor electrically and apply LOTO per SOP-003; confirm zero energy.
5. De-pressurise and drain the pump to the closed drain; allow to cool below 45 C.
6. Disconnect and cap the seal flush piping.
7. Follow the OEM cartridge seal replacement procedure (MSC-CP200 manual Section 5.3).
8. On reassembly, verify the seal flush plan is OEM Plan 11 with the correct orifice - do not leave a substitute flush plan in service.
9. Re-check coupling alignment before removing LOTO.
10. Restore flush, remove LOTO and isolations, prime and restart; confirm no leakage and positive flush flow.

This page is a scanned sign-off sheet.

Work carried out by: _____

Checked by (supervisor): _____

Permit number: _____

Seal flush plan verified as OEM Plan 11: Y / N

Date: _____ Time: _____

Signature: _____