

SOP-009 - Motor Insulation Resistance Test Routine

Standard Operating Procedure | Tier 3

1. Purpose

Routine IR testing of electric motors.

2. Procedure

1. Isolate and lock out the motor per SOP-003.
2. Measure insulation resistance with a megger.
3. Log the reading and flag any value below 1 Mohm.