

SOP-010 - Compressor Routine Check

Standard Operating Procedure | Tier 3

1. Purpose

Routine checks on rotary screw compressors.

2. Procedure

1. Check oil level, discharge temperature and pressure.
2. Drain condensate and check for abnormal noise or vibration.
3. Log the readings.