

Infrastructure & Engineering

Your ref:

Our ref: **20141107/32/11305/FC**

Date: **11 June 2026**

Who deals with this: **Mr. C. Tetyana**

Tel: **+27 (0) 41 506 2439**

e-Mail: **ctetyane@mandelametro.gov.za**

PO Box 7, Port Elizabeth, 6000
Republic of South Africa

TO : HUMAN SETTLEMENTS DIRECTORATE: DEVELOPMENT AND SUPPORT

FROM : INFRASTRUCTURE AND ENGINEERING DIRECTORATE: PLANNING AND RESEARCH DIVISION

DATE : 11 JUNE 2026

SUBJECT : FINAL APPROVAL OF CAPACITIES WITHIN THE SEWER LINES AND AT WASTEWATER TREATMENT WORKS (WWTW): PROPOSED WALMER HOUSING DEVELOPMENT ON ERF 11305, WALMER

The purpose of this memorandum is to confirm the capacities within the bulk sanitation system that serve the Proposed Walmer Housing Development on Erf 11305, Walmer.

Based on the technical information provided by Human Settlements Directorate on behalf of NMBM under the proposed site development plan (Wal/14022/Option B) dated 22 August 2024, as submitted within Final Scoping Report dated 13 April 2026, the proposed development consists of the following development types and densities:

- General Res Zone 4 : 300
- Single Res Zone (LCH) : 509
- Single Res Zone 1 (Gap) : 143
- Business Zone 1 : 1
- Community Zone 2 : 1
- Authority Zone : 2
- Open Space Zone 1 : 11
- Open Space Zone 3 : 13

Accordingly, the following comment(s) are provided in relation to the capacities of the bulk sanitation system:

1. BULK SANITATION CONFIRMATION

- 1.1. The Proposed Walmer Housing Development on Erf 11305, Walmer has been estimated to generate an additional sewerage of 3.03MI/day at peak wet weather flows.
- 1.2. Based on these flows, Infrastructure and Engineering Directorate ("the Directorate") shall provisionally support the implementation that shall contribute additional sewerage flows to the limit of 3.03MI/day (PWWF), only; and
- 1.3. Driftsands Wastewater Treatment Works shall have sufficient capacity to facilitate the treatment of the limited additional sewage flows equating to 3.03MI/day (PWWF).
- 1.4. The proposed sewer tie-in the Ø500mm sewer line, located along the south-west boundary of Erf 11305, along Victoria Drive shall be approved by the NMBM.

2. CONCLUSION

- 2.1. To ensure uninterrupted development within the NMBM, and in accordance with the Municipal Systems Act, Act No. 32 of 2000, Section 73, this final approval letter shall remain valid for a period of two (2) years from the date of issue and may be renewed upon expiry, on resubmission by the Developer and subject to the Directorates' approval.
- 2.2. Notwithstanding **Clause 2.1**, this approval shall lapse upon the commencement of construction works in terms of the approved construction drawings submitted to the Directorate.

Yours faithfully,



MR. L. PIETERSE

PLANNING & RESEARCH DIVISION

WATER & SANITATION SUB-DIRECTORATE

INFRASTRUCTURE & ENGINEERING DIRECTORATE