

AAMA/FGIA
Design Pressure Field Test Pressure

	Laboratory			Field (2/3 of Lab)			Residential
Window Rating (On Label)	Lab Pressure (PSF)	Lab Inches of Water (PSF x 0.1923)	Lab Equivalent Wind Speed (MPH)	Field Pressure (PSF)	Field Inches of Water (PSF x 0.1923)	Field Equivalent Wind Speed (MPH)	
15	2.25	0.43	33	1.50	0.29	24	
20	3.00	0.58	38	2.00	0.38	28	
25	3.75	0.72	42	2.50	0.48	31	
30	4.50	0.87	45	3.00	0.58	34	
35	5.25	1.01	48	3.50	0.67	37	
40	6.00	1.15	51	4.00	0.77	40	
45	6.75	1.30	54	4.50	0.87	42	
50	7.50	1.44	57	5.00	0.96	44	
55	8.25	1.59	59	5.50	1.06	46	
60	9.00	1.73	62	6.00	1.15	48	
65	9.75	1.87	64	6.50	1.25	50	
70	10.50	2.02	66	7.00	1.35	52	
80	12.00	2.31	68	8.00	1.54	56	

For AW class products, take the rating x 0.2 for the lab pressure with the maximum being 12 psf.

Examples: an AW 60 rated window is lab tested at 60 x 0.2 = 12.0 psf.

An AW40 window is tested at 40 x 0.2 = 8.0 psf. The 2/3 rule for the field applies for AW rated windows also.

Therefore an AW40 rated windows is field tested at

$2/3 \times 8.0 \text{ psf} = 5.3 \text{ psf}$

	Laboratory			Field (2/3 of Lab)			Commercial
Window Rating (On Label)	Lab Pressure (PSF)	Lab Inches of Water (PSF x 0.1923)	Lab Equivalent Wind Speed (MPH)	Field Pressure (PSF)	Field Inches of Water (PSF x 0.1923)	Field Equivalent Wind Speed (MPH)	
15	3.00	0.58	33	2.00	0.38	28	
20	4.00	0.77	38	2.67	0.51	32	
25	5.00	0.96	42	3.33	0.64	36	
30	6.00	1.15	45	4.00	0.77	40	
35	7.00	1.35	48	4.67	0.90	43	
40	8.00	1.54	51	5.33	1.03	46	
45	9.00	1.73	54	6.00	1.15	48	
50	10.00	1.92	57	6.67	1.28	51	
55	11.00	2.12	59	7.33	1.41	54	
60	12.00	2.31	62	8.00	1.54	56	