A. General Information

1	Project Name	010012-SchSml-CECStd22			
2	Run Title				
3	Project Location	- specify -			
4	City	- specify -	**5**	Standards Version	Compliance 2022
6	Zip code	95814	**7**	Compliance Software (version)	CBECC 2022.3.2-SP1 (1369)
8	Climate Zone	12	**9**	Building Orientation (deg)	0
10	Building Type(s)	• Nonresidential	**11**	Weather File	SACRAMENTO-EXECUTIVE_STYP20.epw
12	Project Scope	• New complete scope	**13**	Number of Dwelling Units	0
14	Total Conditioned Floor Area in Scope (ft^2)	24412.7	**15**	Total # of hotel/motel rooms	0
16	Total Unconditioned Floor Area (ft^2)	0	**17**	Fuel Type	Natural gas
18	Nonresidential Conditioned Floor Area	24412.7	**19**	Total # of Stories (Habitable Above Grade)	1
20	Residential Conditioned Floor Area	0			

B. PROJECT SUMMARY

Table B shows which building components are included in the performance calculation. If indicated as not included, the project must show compliance prescriptively if within the permit application.

Building Components Complying via Performance

Envelope (See Table G)	Nonres	Performance	Solar Thermal Water Heating (See Table I3)	☐	Performance
	MultiFam	Not Included		☒	Not Included
Mechanical (See Table H)	Nonres	Performance	Covered Process: Commercial Kitchens (see Table J)	☐	Performance
	MultiFam	Not Included		☒	Not Included
Domestic Hot Water (See Table I)	Nonres	Performance	Covered Process: Laboratory Exhaust (see Table J)	☐	Performance
	MultiFam	Not Included		☒	Not Included
Lighting (Indoor Conditioned, see Table K)	Nonres	Performance	Photovoltaics (see Table F)	☒	Performance
	MultiFam	Not Included		☐	Not Included
			Battery (see Table F)	☒	Performance
				☐	Not Included

Building Components Complying Prescriptively

The following building components are ONLY eligible for prescriptive compliance and should be documented on the NRCC form listed if within the scope of the permit application (i.e. compliance will not be shown on the NRCC-PRF-E).	
Indoor Lighting (Unconditioned) 140.6 & 170.2(e)	NRCC-LTI-E is required
Outdoor Lighting 140.7 & 170.2(e)	NRCC-LTO-E is required
Sign Lighting 140.8 & 170.2(e)	NRCC-LTS-E is required
Building Components Complying with Mandatory Measures	
Electrical power systems, commissioning, solar ready, elevator and escalator requirements are mandatory and should be documented on the NRCC form listed if applicable (i.e. compliance will not be shown on the NRCC-PRF-E.)	
Electrical Power Distribution 110.11	NRCC-ELC-E is required
Commissioning 120.8	NRCC-CXR-E is required
Solar and Battery 110.10	NRCC-SAB-E is required

C1. COMPLIANCE SUMMARY			
COMPLIES[3]			
	Time Dependent Valuaton (TDV)		**Source Energy Use**
	Efficiency[1] (kBtu/ft^2 - yr)	**Total[2] (kBtu/ft^2 - yr)**	**Total[2] (kBtu/ft^2 - yr)**
Standard Design	196.52	136.87	12.39
Proposed Design	196.52	136.87	12.38
Compliance Margins	**0**	**0**	**0.01**
	Pass	**Pass**	**Pass**

[1] *Efficiency measures include improvements like a better building envelope and more efficient equipment*

[2] *Compliance Totals include efficiency, photovoltaics and batteries*

[3] *New Construction, Complete Addition Scope: Building complies when all efficiency and total compliance margins are greater than or equal to zero and unmet load hour limits are not exceeded*

Existing, Addition and Alteration Scope: Building complies when efficiency compliance margin is greater than or equal to zero and unmet load hour limits are not exceeded

C2. TDV ENERGY COMPLIANCE RESULTS FOR PERFORMANCE COMPONENTS (Annual TDV Energy Use, kBtu/ft^2 - yr)			
COMPLIES[2]			
Energy Component	**Standard Design (TDV)**	**Proposed Design (TDV)**	**Compliance Margin (TDV)[1]**
Space Heating	22.8	22.8	0
Space Cooling	52.62	52.62	0
Indoor Fans	78.21	78.27	-0.06
Heat Rejection	0	0	0
Pumps & Misc.	0	0	0
Domestic Hot Water	23.43	23.37	0.06
Indoor Lighting	19.46	19.46	0
Flexibility	---	---	---
EFFICIENCY COMPLIANCE TOTAL	**196.52**	**196.52**	**0 (0%)**
Photovoltaics	-53.87	-53.87	---
Batteries	-5.78	-5.78	---
TOTAL COMPLIANCE	**136.87**	**136.87**	**0 (0%)**

[1] *Notes: This number in parenthesis following the Compliance Margin in column 4, represents the Percent Better than Standard.*

C3. TDV ENERGY RESULTS FOR NON-REGULATED COMPONENTS[1]			
Non-Regulated Energy Component	**Standard Design (TDV)**	**Proposed Design (TDV)**	**Compliance Margin (TDV)[1]**
Receptacle	48.7	48.7	---
Process	6.49	6.49	---
Other Ltg	---	---	---
Process Motors	0.5	0.5	---
TOTAL (TOTAL COMPLIANCE + NON-REGULATED COMPONENTS)	**192.56**	**192.56**	**0 (0%)**
[1] *Notes: This table is not used for Energy Code Compliance.*			

C4. SOURCE ENERGY COMPLIANCE RESULTS FOR PERFORMANCE COMPONENTS (Annual SOURCE Energy Use, kBtu/ft^2 /yr)			
COMPLIES[2]			
Energy Component	**Standard Design (SOURCE)**	**Proposed Design (SOURCE)**	**Compliance Margin (SOURCE)[1]**
Space Heating	3.06	3.06	0
Space Cooling	1.83	1.83	0
Indoor Fans	6.59	6.59	0
Heat Rejection	0	0	0
Pumps & Misc.	0	0	0
Domestic Hot Water	1.93	1.92	0.01
Indoor Lighting	1.87	1.87	0
Flexibility	---	---	---
EFFICIENCY COMPLIANCE TOTAL	**15.28**	**15.27**	**0.01 (0.1%)**
Photovoltaics	-1.92	-1.92	---
Batteries	-0.97	-0.97	---
TOTAL COMPLIANCE	**12.39**	**12.38**	**0.01 (0.1%)**
[1] *Notes: This number in parenthesis following the Compliance Margin in column 4, represents the Percent Better than Standard.*			

C5. SOURCE ENERGY RESULTS FOR NON-REGULATED COMPONENTS[1]

Non-Regulated Energy Component	Standard Design (SOURCE)	Proposed Design (SOURCE)	Compliance Margin (SOURCE)[1]
Receptacle	3.66	3.66	---
Process	0.71	0.71	---
Other Ltg	---	---	---
Process Motors	0.04	0.04	---
TOTAL (TOTAL COMPLIANCE + NON-REGULATED COMPONENTS)	**16.8**	**16.79**	**0.01 (0.1%)**

[1] Notes: This table is not used for Energy Code Compliance.

C6. 'ABOVE CODE' QUALIFICATIONS

☐ This project is pursuing CalGreen Tier 1 ☐ This project is pursuing CalGreen Tier 2

C7. ENERGY USE SUMMARY

Energy Component	Standard Design Site (MWh)	Proposed Design Site (MWh)	Margin (MWh)	Standard Design Site (MBtu)	Proposed Design Site (MBtu)	Margin (MBtu)
Space Heating	17.4	17.4	0	---	---	---
Space Cooling	29.9	29.9	0	---	---	---
Indoor Fans	67	67	0	---	---	---
Heat Rejection	---	---	---	---	---	---
Pumps & Misc.	---	---	---	---	---	---
Domestic Hot Water	24.1	24	0.1	---	---	---
Indoor Lighting	16.9	16.9	0	---	---	---
Flexibility	---	---	---	---	---	---
EFFICIENCY TOTAL	**155.3**	**155.2**	**0.1**	**0**	**0**	**0**
Photovoltaics	-67.4	-67.4	0	---	---	---
Batteries	0.7	0.7	0	---	---	---
ENERGY USE SUBTOTAL	**88.6**	**88.5**	**0.1**	**0**	**0**	**0**
Receptacle	48	48	0	---	---	---
Process	5.6	5.6	0	---	---	---
Other Ltg	---	---	---	---	---	---
Process Motors	0.4	0.4	0	---	---	---
ENERGY USE TOTAL	**142.6**	**142.5**	**0.1**	**0**	**0**	**0**

C8. ENERGY USE INTENSITY (EUI)				
	Standard Design (kBtu/ft^2 / yr)	Proposed Design (kBtu/ft^2 / yr)	Margin (kBtu/ft^2 / yr)	Margin Percentage
GROSS EUI[1]	29.35	29.34	0.01	0.03
NET EUI[1]	19.93	19.92	0.01	0.05

[1] Notes: Gross EUI is Energy Use Total (not including PV)/Total Building Area. Net EUI is Energy Use Total (including PV)/Total Building Area.

D1. EXCEPTIONAL CONDITIONS
• The aged solar reflectance and aged thermal emittance must be listed in the Cool Roof Rating Council database of certified products. For projects where initial reflectance is used, the initial reflectance must be listed, and the aged reflectance is calculated by the software program and used in the compliance model.

F1. REQUIRED PV SYSTEMS											
01	02	03	04	05	06	07	08	09	10	11	12
DC System Size (kWdc)	Exception[1]	Module Type	Array Type	Power Electronics	CFI	Azimuth (deg)	Tilt Input	Array Angle (deg)	Tilt: (x in 12)	Inverter Eff. (%)	Annual Solar Access (%)
43.09		Standard (14-17%)	Fixed	none	true	150-270	n/a	n/a	<=7:12	96	98

[1]See Table D1 for any PV exceptions used.

F1B. PV BATTERY BUILDING TYPE(S)

01	02	03
Building Occupancy Type* (From Table 140.10-A/B and 170.2-U/V)	Conditioned Floor Area (ft^2)	Unconditioned Floor Area (ft^2)
Grocery	0	0
High-Rise Multifamily	0	0
Office, Financial Institutions, Unleased Tenant Space	2201.36	0
Retail	0	0
School	22211.3	0
Warehouse	0	0
Auditorium, Convention Center, Hotel/Motel, Library, Medical Office Building/Clinic, Restaurant, Theater	0	0
None	0	0

**Building Occupancy Types are defined in Section 100.1 of the Energy Code*

F2. BATTERY SYSTEMS[1]

01	02	03	04	05	06	07
Control	Capacity (kWh)	Charging Efficiency	Charging Rate (kW)	Discharging Efficiency	Discharging Rate (kW)	Round Trip Efficiency
TOU	83.45	N/A	19.55	N/A	19.55	0.9

[1]*See Table D1 for any Battery exceptions used.*

G1. ENVELOPE GENERAL INFORMATION (conditioned spaces only)

01	02	03	04
Opaque Surfaces & Orientation	**Total Gross Surface Area (ft^2)**	**Total Fenestration Area (ft^2)**	**Window to Wall Ratio (%)**
North-Facing[1]	4746.9	2003.67	42.21
East-Facing[2]	2228.14	819.3	36.77
South-Facing[3]	4746.9	1959.75	41.28
West-Facing[4]	2228.14	180.67	8.11
Total	**13950.1**	**4963.39**	**35.58**
Roof	24412.7	0	0

Notes

[1]*North-Facing is oriented to within 45 degrees of true north, including 4500'00" east of north (NE), but excluding 4500'00" west of north (NW),*

[2]*East-Facing is oriented to within 45 degrees of true east, including 4500'00" south of east (SE), but excluding 4500'00" north of east (NE),*

[3]*South-Facing is oriented to within 45 degrees of true south, including 4500'00" west of south (SW), but excluding 4500'00" east of south (SE),*

[4]*West-Facing is oriented to within 45 degrees of true west, including 4500'00" north of west (NW), but excluding 4500'00" south of west (SW),*

G2A. ROOFING PRODUCT SUMMARY (NONRESIDENTIAL)

01	02	03	04	05	06
Assembly Name	**Roof Pitch**	**Roof Rise (x in 12)**	**Aged Solar Reflectance**	**Thermal Emittance**	**SRI**
Base_CZ12-FlatNonresWoodFramingAndOtherRoofU034	LowSlope	N/A	0.63	0.75	N/A

G4. NONRESIDENTIAL AIR BARRIER

01	02
Building Story Name	**Air Barrier**
Level 1	Air barrier - not verified

G5. OPAQUE SURFACE ASSEMBLY SUMMARY										
01	02	03	04	05	06		07	08	09	10
Surface Name	Construction Type	Area (ft^2)	Framing Type	Cavity R-Value	Continuous R-Value		Units	Value	Description of Assembly Layers	Status[1]
					Interior	Exterior				
Base_CZ12-SlabOnOrBelowGradeF073	Underground Floor	24,412.7	N/A	0	N/A	N/A	F-factor	0.73	Slab Type =Unheated slab on grade Insulation Orientation =None Insulation R-Value =none	N
Base_CZ12-NonresMetalFrameWallU055	Exterior Wall	13,950.1	Metal	0	N/A	16.05	U-factor	0.055	Stucco - 7/8 in. Compliance Insulation R14.60 Compliance Insulation R1.41 Compliance Insulation R0.02 Compliance Insulation R0.02 Air - Metal Wall Framing - 16 or 24 in. OC Gypsum Board - 1/2 in.	N
NACM_MetalFrameWallInterior	Interior Wall	17,891.4	Metal	0	N/A	N/A	U-factor	0.3195	Gypsum Board - 5/8 in. Air - Metal Wall Framing - 16 or 24 in. OC Gypsum Board - 5/8 in.	N
Base_CZ12-FlatNonresWoodFramingAndOtherRoofU034	Roof	24,412.7	N/A	0	N/A	28.63	U-factor	0.034	Metal Standing Seam - 1/16 in. Compliance Insulation R28.63	N

[1] Status: N - New, A - Altered, E - Existing

G7A. FENESTRATION ASSEMBLY SUMMARY (NONRESIDENTIAL)

01	02	03	04	05	06	07	08	09
Fenestration Assembly Name	Fenestration Type/ Product Type / Frame Type	Certification Method[1]	Assembly Method	Area (ft^2)	Overall U-factor	Overall SHGC	Overall VT	Status[2]
Base_AllCZ_FixedWindowU34	Vertical fenestration Fixed window N/A	NFRC	Manufactured	4,963.39	0.34	0.22	0.42	N

[1] Notes: Newly installed fenestration shall have a certified NFRC Label Certificate or use the CEC default tables found in Table 110.6-A and Table 110.6-B. Center of Glass (COG) values are for the glass-only, determined by the manufacturer, and are shown for ease of verification. Site-built fenestration values are calculated per Nonresidential Appendix NA6 and are used in the analysis.

[2] Status: N - New, A - Altered, E - Existing

H1. DRY SYSTEM EQUIPMENT (FURNACES, AIR HANDLING UNITS, HEAT PUMPS, VRF, ECONOMIZERS ETC.)

01	02	03	04	05	06	07	08	09	10	11	12
			Heating				Cooling				
Equipment Name	Equipment Type	Qty	Total Heating Output (kBtu/h)	Supp Heat Output (kBtu/h)	Efficiency Unit	Efficiency	Total Cooling Output (kBtu/h)	Efficiency Unit	Efficiency	Economizer Type (if present)	Status[1]
Common_Mech/Elec-SZAC-Sys	Single Zone Heat Pump (SZHP) Air System	1	17.2	11.91	HSPF	8	15.83	SEER	14	No Economizer	N
Wing1_Side1-SZAC-Sys (x4)	Single Zone Heat Pump (SZHP) Air System	4	29.86	28.34	HSPF	8	27.48	SEER	14	No Economizer	N
Wing1_Corridor-SZAC-Sys	Single Zone Heat Pump (SZHP) Air System	1	29.6	27.76	HSPF	8	27.24	SEER	14	No Economizer	N

[1] Status: N - New, A - Altered, E - Existing

H1. DRY SYSTEM EQUIPMENT (FURNACES, AIR HANDLING UNITS, HEAT PUMPS, VRF, ECONOMIZERS ETC.)											
01	02	03	04	05	06	07	08	09	10	11	12
			Heating				Cooling				
Equipment Name	Equipment Type	Qty	Total Heating Output (kBtu/h)	Supp Heat Output (kBtu/h)	Efficiency Unit	Efficiency	Total Cooling Output (kBtu/h)	Efficiency Unit	Efficiency	Economizer Type (if present)	Status[1]
Wing1_Side2-SZAC-Sys (x4)	Single Zone Heat Pump (SZHP) Air System	4	21.9	25.4	HSPF	8	20.16	SEER	14	No Economizer	N
Common_Lobby-SZAC-Sys	Single Zone Heat Pump (SZHP) Air System	1	18.36	14.25	HSPF	8	16.89	SEER	14	No Economizer	N
Common_Corridor-SZAC-Sys	Single Zone Heat Pump (SZHP) Air System	1	37.92	28.26	HSPF	8	34.9	SEER	14	Fixed DB	N
Wing2_Side1-SZAC-Sys (x4)	Single Zone Heat Pump (SZHP) Air System	4	29.46	28.12	HSPF	8	27.11	SEER	14	No Economizer	N
Wing2_Corridor-SZAC-Sys	Single Zone Heat Pump (SZHP) Air System	1	29.8	27.86	HSPF	8	27.42	SEER	14	No Economizer	N
Wing2_Side2-SZAC-Sys (x4)	Single Zone Heat Pump (SZHP) Air System	4	23.09	25.98	HSPF	8	21.25	SEER	14	No Economizer	N
Common_Office-SZAC-Sys	Single Zone Heat Pump (SZHP) Air System	1	65.6	48.08	HSPF	8	60.37	SEER	14	Fixed DB	N
Common_Cafeteria-SZVAVAC-Sys	Package SZ VAV Heat Pump Air System	1	102.75	123.56	COP	3.4	94.55	EER	11	Fixed DB	N

[1] *Status: N - New, A - Altered, E - Existing*

H3. NONRESIDENTIAL / COMMON USE AREA FAN SYSTEMS SUMMARY												
01	02	03	04	05	06	07	08	09	10	11	12	13
Name or Item Tag	Qty	Design OA CFM	Supply Fan				Return / Relief Fan					Status[1]
			CFM	Power	Power Units	Control	Fan Type	CFM	Power	Power Units	Control	
Common_Mech/Elec-SZAC-Sys	1	66.97	558.33	0.74	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
Wing1_Side1-SZAC-Sys (x4)	4	286.32	904.23	0.74	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
Wing1_Corridor-SZAC-Sys	1	258.33	960.93	0.74	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
Wing1_Side2-SZAC-Sys (x4)	4	286.32	710.97	0.74	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
Common_Lobby-SZAC-Sys	1	101.72	595.88	0.74	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
Common_Corridor-SZAC-Sys	1	258.33	990.01	0.74	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
Wing2_Side1-SZAC-Sys (x4)	4	286.32	889.52	0.74	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
Wing2_Corridor-SZAC-Sys	1	258.35	967.31	0.74	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
Wing2_Side2-SZAC-Sys (x4)	4	286.32	749.51	0.74	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
Common_Office-SZAC-Sys	1	330.2	2,052.39	0.74	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
Common_Cafeteria-SZVAVAC-Sys	1	1429.87	3,335.22	0.74	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
Common_Restroom-Exhaust	1	0	500	0.2	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N

[1] Status: N - New, A - Altered, E - Existing

H5. GENERAL EXHAUST FAN SUMMARY

01	02	03	04	05	06	07	08
System ID	Zone Name	Qty	CFM	Power	Power Units	Continuous Operation?	Status[1]
Common_Restroom-Exhaust	Common_Restroom_Zn	1	500	0.2	WattsPerCFM	No	N

[1] *Status: N - New, A - Altered, E - Existing*

H8. SYSTEM SPECIAL FEATURES

01	02	03	04
System Name	Equipment Type	Interlocks per 140.4(n)[1]	Other Special Features and Controls
Common_Corridor-SZAC-Sys	Single Zone Heat Pump (SZHP) Air System	N/A	Fixed DB
Common_Office-SZAC-Sys	Single Zone Heat Pump (SZHP) Air System	N/A	Fixed DB
Common_Cafeteria-SZVAVAC-Sys	Package SZ VAV Heat Pump Air System	N/A	Zone(s) With CO2 Sensor Vent. Control Fixed DB
SHWFluidSysHtPump	Service Hot Water	N/A	Fixed Temperature Control

Notes: This table includes controls related to the performance path only. For projects using the prescriptive path, mandatory and prescriptive controls requirements are documented on the NRCC-MCH-E.

[1] *Yes = interlocks are provided, No = interlocks are not provided, NA means no operable openings.*

H9. NONRESIDENTIAL / COMMON USE AREA & HOTEL/MOTEL VENTILATION

01	02	03	04	05	06	07
Zone Name	Mechanical Ventilation				Conditioned Area (sf)	DCV or Occupant Sensor Controls, or Both
	Ventilation Function	# of People	Supply OA CFM	Exhaust CFM		
Common_Restroom_Zn	Exhaust - Toilets, public	5.02	0	500	1004.6	N/A
Common_Mech/Elec_Zn	Misc - Telephone closets	0.67	66.97	0	446.49	N/A
Wing1_Side1_Zn	Education - Classrooms (ages 9-18)	75.35	1145.28	0	3013.91	N/A

H9. NONRESIDENTIAL / COMMON USE AREA & HOTEL/MOTEL VENTILATION						
01	02	03	04	05	06	07
Zone Name	Mechanical Ventilation				Conditioned Area (sf)	DCV or Occupant Sensor Controls, or Both
	Ventilation Function	# of People	Supply OA CFM	Exhaust CFM		
Wing1_Corridor_Zn	General - Corridors	8.61	258.33	0	1722.22	N/A
Wing1_Side2_Zn	Education - Classrooms (ages 9-18)	75.35	1145.28	0	3013.91	N/A
Common_Lobby_Zn	General - Corridors	3.39	101.72	0	678.13	N/A
Common_Corridor_Zn	General - Corridors	8.61	258.33	0	1722.23	N/A
Wing2_Side1_Zn	Education - Classrooms (ages 9-18)	75.35	1145.26	0	3013.85	N/A
Wing2_Corridor_Zn	General - Corridors	8.61	258.35	0	1722.32	N/A
Wing2_Side2_Zn	Education - Classrooms (ages 9-18)	75.35	1145.29	0	3013.92	N/A
Common_Office_Zn	Office - Office space	11.01	330.2	0	2201.36	N/A
Common_Cafeteria_Zn	Food Service - Cafeteria/fast-food dining	95.33	1429.87	0	2859.73	DCV

H11. ZONAL SYSTEM AND TERMINAL UNIT SUMMARY											
01	02	03	04	05	06	07	08	09	10	11	12
System ID	System Type	Qty	Rated Capacity (kBtuh)		Airflow (cfm)			Fan			VSD
			Heating	Cooling	Design	MIn.	Min. Ratio	Power	Power Units	Cycles	
Common_Mech/Elec_TU	Uncontrolled	1	N/A	N/A	558.33	N/A	0	N/A	N/A	N/A	☐
Wing1_Side1_TU	Uncontrolled	4	N/A	N/A	904.23	N/A	0	N/A	N/A	N/A	☐
Wing1_Corridor_TU	Uncontrolled	1	N/A	N/A	960.93	N/A	0	N/A	N/A	N/A	☐
Wing1_Side2_TU	Uncontrolled	4	N/A	N/A	710.97	N/A	0	N/A	N/A	N/A	☐
Common_Lobby_TU	Uncontrolled	1	N/A	N/A	595.88	N/A	0	N/A	N/A	N/A	☐
Common_Corridor_TU	Uncontrolled	1	N/A	N/A	990.01	N/A	0	N/A	N/A	N/A	☐

H11. ZONAL SYSTEM AND TERMINAL UNIT SUMMARY

01	02	03	04	05	06	07	08	09	10	11	12
System ID	System Type	Qty	Rated Capacity (kBtuh)		Airflow (cfm)			Fan			VSD
			Heating	Cooling	Design	MIn.	Min. Ratio	Power	Power Units	Cycles	
Wing2_Side1_TU	Uncontrolled	4	N/A	N/A	889.52	N/A	0	N/A	N/A	N/A	☐
Wing2_Corridor_TU	Uncontrolled	1	N/A	N/A	967.31	N/A	0	N/A	N/A	N/A	☐
Wing2_Side2_TU	Uncontrolled	4	N/A	N/A	749.51	N/A	0	N/A	N/A	N/A	☐
Common_Office_TU	Uncontrolled	1	N/A	N/A	2,052.39	N/A	0	N/A	N/A	N/A	☐
Common_Cafeteria_TU	Variable Air Volume No Reheat Box	1	N/A	N/A	3,335.22	1,667.61	0.5	N/A	N/A	N/A	☐

I1. WATER HEATER EQUIPMENT SUMMARY

01	02	03	04	05	06	07	08	09	10	11	12	13	14
Name	Heater Element Type	Tank Type	Qty	Tank Vol (gal)	Rated Input	Rated Input Unit	Efficiency	Efficiency Unit	Tank Insulation R-value Int/Ext	Standby Loss Fraction	1st Hr. Rating or Flow Rate (gal)	Heat Pump Type	Tank Location or Ambient Condition
WaterHeaterElec	Electricity	Storage	1	44.58	6.9	kW	2.15	UEF	N/A	N/A	75	Heat Pump Split Water Heater	N/A

K1. INDOOR CONDITIONED LIGHTING GENERAL INFO					
01	02	03	04	05	06
Occupancy Type[1]	Conditioned Floor Area[2] (ft^2)	Installed Lighting Power (Watts)	Lighting Control Credits (Watts)	Additional (Custom) Allowance	
				Area Category Footnotes (Watts)	Area Category Footnotes (Watts)
Classroom, Lecture, or Training Vocational	12055.6	7233.35	0	0	0
Corridor	5844.9	2337.96	0	0	0
Dining - Fastfood	2859.73	1286.88	0	0	0
Electrical Mechanical Telephone Room	446.49	178.59	0	0	0
Office (250 square feet)	2201.36	1320.82	0	0	0
Restroom	1004.6	652.99	0	0	0
Building Totals:	**24412.7**	**13010.6**	**0**	**0**	**0**

[1]*See Table 140.6-C*
[2]*See NRCC-LTI--E for unconditioned spaces*
[3]*Lighting information for existing spaces modeled is not included in this table*

K4. INDOOR CONDITIONED LIGHTING MANDATORY LIGHTING CONTROL

See NRCC-LTI-E for mandatory controls

L. DECLARATION OF REQUIRED CERTIFICATES OF INSTALLATION

Selections made by Documentation Author indicate which Certificates of Installation must be submitted for the features to be recognized for compliance. These documents must be retained and provided to the building inspector during construction and can be found online

Building Component	Form/Title
Envelope	NRCI-ENV-E - Envelope (for all buildings)
Mechanical	NRCI-MCH-E - For all buildings with Mechanical Systems
Plumbing	NRCI-PLB-E - For all buildings with Plumbing Systems
	NRCI-SAB-E - Solar Water Heating, PV and Battery Storage Systems

L. DECLARATION OF REQUIRED CERTIFICATES OF INSTALLATION

Selections made by Documentation Author indicate which Certificates of Installation must be submitted for the features to be recognized for compliance. These documents must be retained and provided to the building inspector during construction and can be found online

Building Component	Form/Title
Indoor Lighting	NRCI-LTI-E - Indoor Lighting (for all buildings)

M. DECLARATION OF REQUIRED CERTIFICATES OF ACCEPTANCE

Selections made by Documentation Author indicate which Certificates of Acceptance must be submitted for the features to be recognized for compliance. These documents must be provided to the building inspector during construction and must be completed through an Acceptance Test Technician Certification Provider (ATTCP).

Building Component	Form/Title & System Name(s)
Envelope	NRCA-ENV-02-F - NRFC label verification for fenestration
Indoor Lighting	NRCA-LTI-02-A - Occupancy Sensors and Automatic Time Switch Controls.
Indoor Lighting	NRCA-LTI-03-A - Automatic Daylight Controls.
Indoor Lighting	NRCA-LTI-04-A - Demand Responsive Lighting Controls.
Mechanical	NRCA-MCH-02-A - Outdoor Air must be submitted for all newly installed HVAC units. Note: MCH-02-A can be performed in conjunction with MCH-07-A Supply Fan VFD Acceptance (if applicable) since testing activities overlap
	Common_Mech/Elec-SZAC-Sys, Wing1_Side1-SZAC-Sys (x4), Wing1_Corridor-SZAC-Sys, Wing1_Side2-SZAC-Sys (x4), Common_Lobby-SZAC-Sys, Common_Corridor-SZAC-Sys, Wing2_Side1-SZAC-Sys (x4), Wing2_Corridor-SZAC-Sys, Wing2_Side2-SZAC-Sys (x4), Common_Office-SZAC-Sys and Common_Cafeteria-SZVAVAC-Sys.
Mechanical	NRCA-MCH-03-A - Constant Volume Single Zone HVAC
	Common_Mech/Elec-SZAC-Sys, Wing1_Side1-SZAC-Sys (x4), Wing1_Corridor-SZAC-Sys, Wing1_Side2-SZAC-Sys (x4), Common_Lobby-SZAC-Sys, Common_Corridor-SZAC-Sys, Wing2_Side1-SZAC-Sys (x4), Wing2_Corridor-SZAC-Sys, Wing2_Side2-SZAC-Sys (x4) and Common_Office-SZAC-Sys.
Mechanical	NRCA-MCH-05-A - Air Economizer Controls
	Common_Corridor-SZAC-Sys, Common_Office-SZAC-Sys and Common_Cafeteria-SZVAVAC-Sys.
Mechanical	NRCA-MCH-06-A Demand Control Ventilation Systems must be submitted for all systems required to employ demand controlled ventilation (refer to) can vary outside ventilation flow rates based on maintaining interior carbon dioxide (CO2) concentration setpoints.
	Common_Cafeteria-SZVAVAC-Sys
Mechanical	NRCA-MCH-07-A Supply Fan Variable Flow Controls
	Common_Cafeteria-SZVAVAC-Sys
Mechanical	NRCA-MCH-12-A FDD for Packaged Direct Expansion Units
	Common_Corridor-SZAC-Sys, Common_Office-SZAC-Sys and Common_Cafeteria-SZVAVAC-Sys.

M. DECLARATION OF REQUIRED CERTIFICATES OF ACCEPTANCE

Selections made by Documentation Author indicate which Certificates of Acceptance must be submitted for the features to be recognized for compliance. These documents must be provided to the building inspector during construction and must be completed through an Acceptance Test Technician Certification Provider (ATTCP).

Building Component	Form/Title & System Name(s)
Mechanical	NRCA-MCH-19-A Occupancy Sensor Controls
	Wing1_Corridor-SZAC-Sys, Common_Lobby-SZAC-Sys, Common_Corridor-SZAC-Sys and Wing2_Corridor-SZAC-Sys.

N. DECLARATION OF REQUIRED CERTIFICATES OF VERIFICATION

Selections made by Documentation Author indicate which Certificates of Verification must be submitted for the features to be recognized for compliance. These documents must be retained and provided to the building inspector during construction and can be found online

Building Component	Form/Title
Mechanical	NRCV-MCH-27 Indoor Air Quality & Mechanical Ventilation
Mechanical	NRCV-MCH-32 Local Mechanical Exhaust

Documentation Author's Declaration Statement

1. I certify that this Certificate of Compliance documentation is accurate and complete.	
Documentation Author Name:	Documentation Author Signature:
Company:	Signature Date:
Address:	CEA/HERS Certification Identification (if applicable):
City/State/Zip: ,	Phone:

Responsible Person's Declaration statement

I certify the following under penalty of perjury, under the laws of the State of California:

1. The information provided on this Certificate of Compliance is true and correct.
2. I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer)
3. The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations.
4. The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application.
5. I understand that a registered copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections, and I will take the necessary steps to accomplish this requirement.
6. I understand that a registered copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy, and I will take the necessary steps to accomplish these requirements.

Responsible Designer Name:	Responsible Designer Signature:	
Company:		
Address:	Date Signed:	
City/State/Zip: ,	License #:	
Phone:	Title:	Scope: