



Solar Cost Offset Calculation

Project: Terraces at Lafayette

Date: 10/24/2025

Solar Cost Offset Calculation - provides an estimate of the common area energy loads by applying the overall energy consumption percentage of T24 to the total building footprint.

Design Phase Estimate - actual energy consumption will vary based on real-world usage patterns and operational conditions.

Energy Use and Cost by Category

Category	kWh/yr	\$/yr
EV Chargers (L2 32Amp)	409,968	\$90,193
EV Chargers (L2 16Amp)	965,790	\$212,474
Site Lighting	46,424	\$10,213
Site Uses	1,422,182	\$312,880
Fitness	9,100	\$2,002
Clubhouse	103,800	\$22,836
Studio	8,800	\$21,277
Non-Res Buildings	121,700	\$46,115
Corridor Ventilation	96,716	\$21,277
Elevators (15 total spread across buildings)	120,000	\$26,400
Elevators & Corridors— subtotal	216,716	\$47,677
Pool	20,300	\$6,162
Water Feature	32,193	\$7,082
Pools — subtotal	52,493	\$13,244
Grand Total	1,813,090	419,917

Reference / Source	Notes
CA Title 24, Part 6 (2022) — Table 140.6-C	Used for interior common-area lighting power densities.
Title 24 §130.2 (Outdoor Lighting Controls)	Default assumptions for hours/control; user can override.
Nonresidential Certificate of Compliance (Outdoor Lighting)	Installed Watts pasted into Site Lighting.
RE 623 Budget Worksheet (California DRE)	Roll-up to 201 Electricity and 202 Gas for HOA budgets.
PG&E / SCE / SDG&E official rate sheets 2025	Enter blended annual \$/kWh, demand \$/kW, fixed \$/mo.

Assumptions

Electricity Rate (\$/kWh)	0.22
Gas Rate (\$/therm)	1.5
Rated kW per EV Port	7.2
Avg Use per EV Port (hours/day)	6

Basis of Calculations

Pool Size (ft ² surface area)	1749
Parking Garage Area (ft ²)	0
Hardscape / Parking Areas	5898
# of Elevators	15
Total Parking Spaces	504
% EV Charger Spaces of Total	30
Total Conditioned Area (ft ²)	0
Unconditioned Ventilated Area	36802.01