

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD		NRCC-PRF-E
Nonresidential Performance Compliance Method		(Page 1 of 39)
Project Name:	070012-HotSml-CECStd22	Date Prepared: 2025-12-23

A. General Information				
1	Project Name	070012-HotSml-CECStd22		
2	Run Title			
3	Project Location	- specify -		
4	City	- specify -	5	Standards Version
6	Zip code	95814	7	Compliance Software (version)
8	Climate Zone	12	9	Building Orientation (deg)
10	Building Type(s)	• Hotel/Motel	11	Weather File
12	Project Scope	• New complete scope	13	Number of Dwelling Units
14	Total Conditioned Floor Area in Scope (ft²)	42554	15	Total # of hotel/motel rooms
16	Total Unconditioned Floor Area (ft²)	0	17	Fuel Type
18	Nonresidential Conditioned Floor Area	15282.8	19	Total # of Stories (Habitable Above Grade)
20	Residential Conditioned Floor Area	27271.1		

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 2 of 39)

B. PROJECT SUMMARY							
Table B shows which building components are included in the performance calculation. If indicated as not included, the project must show compliance prescriptively if within the permit application.							
Building Components Complying via Performance					Building Components Complying Prescriptively		
Envelope (See Table G)	Nonres	Performance	Solar Thermal Water Heating (See Table I3)	☒	Performance	The following building components are ONLY eligible for prescriptive compliance and should be documented on the NRCC form listed if within the scope of the permit application (i.e. compliance will not be shown on the NRCC-PRF-E).	
	MultiFam	Not Included		☐	Not Included		
Mechanical (See Table H)	Nonres	Performance	Covered Process: Commercial Kitchens (see Table J)	☐	Performance	Indoor Lighting (Unconditioned) 140.6 & 170.2(e)	NRCC-LTI-E is required
	MultiFam	Not Included		☒	Not Included	Outdoor Lighting 140.7 & 170.2(e)	NRCC-LTO-E is required
Domestic Hot Water (See Table I)	Nonres	Performance	Covered Process: Laboratory Exhaust (see Table J)	☐	Performance	Sign Lighting 140.8 & 170.2(e)	NRCC-LTS-E is required
	MultiFam	Not Included		☒	Not Included	Building Components Complying with Mandatory Measures	
Lighting (Indoor Conditioned, see Table K)	Nonres	Performance	Photovoltaics (see Table F)	☒	Performance	Electrical power systems, commissioning, solar ready, elevator and escalator requirements are mandatory and should be documented on the NRCC form listed if applicable (i.e. compliance will not be shown on the NRCC-PRF-E.)	
	MultiFam	Not Included		☐	Not Included	Electrical Power Distribution 110.11	NRCC-ELC-E is required
			Battery (see Table F)	☒	Performance	Commissioning 120.8	NRCC-CXR-E is required
				☐	Not Included	Solar and Battery 110.10	NRCC-SAB-E is required

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 3 of 39)

C1. COMPLIANCE SUMMARY			
COMPLIES ³			
	Time Dependent Valuaton (TDV)		Source Energy Use
	Efficiency ¹ (kBtu/ft ² - yr)	Total ² (kBtu/ft ² - yr)	Total ² (kBtu/ft ² - yr)
Standard Design	164.51	148.39	23.38
Proposed Design	161.61	145.49	22.96
Compliance Margins	2.9	2.9	0.42
	Pass	Pass	Pass
¹ Efficiency measures include improvements like a better building envelope and more efficient equipment ² Compliance Totals include efficiency, photovoltaics and batteries ³ New Construction, Complete Addition Scope: Building complies when all efficiency and total compliance margins are greater than or equal to zero and unmet load hour limits are not exceeded Existing, Addition and Alteration Scope: Building complies when efficiency compliance margin is greater than or equal to zero and unmet load hour limits are not exceeded			

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 4 of 39)

C2. TDV ENERGY COMPLIANCE RESULTS FOR PERFORMANCE COMPONENTS (Annual TDV Energy Use, kBtu/ft² - yr)			
COMPLIES²			
Energy Component	Standard Design (TDV)	Proposed Design (TDV)	Compliance Margin (TDV)¹
Space Heating	28.77	28.75	0.02
Space Cooling	38.44	38.44	0
Indoor Fans	25.43	25.43	0
Heat Rejection	0	0	0
Pumps & Misc.	0.02	0.02	0
Domestic Hot Water	48.37	45.49	2.88
Indoor Lighting	23.48	23.48	0
Flexibility	---	---	---
EFFICIENCY COMPLIANCE TOTAL	164.51	161.61	2.9 (1.8%)
Photovoltaics	-16.12	-16.12	---
Batteries	---	---	---
TOTAL COMPLIANCE	148.39	145.49	2.9 (2%)
¹ Notes: This number in parenthesis following the Compliance Margin in column 4, represents the Percent Better than Standard.			

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 5 of 39)

C3. TDV ENERGY RESULTS FOR NON-REGULATED COMPONENTS¹			
Non-Regulated Energy Component	Standard Design (TDV)	Proposed Design (TDV)	Compliance Margin (TDV)¹
Receptacle	87.09	87.09	---
Process	22.58	22.58	---
Other Ltg	9.1	9.1	---
Process Motors	---	---	---
TOTAL (TOTAL COMPLIANCE + NON-REGULATED COMPONENTS)	267.16	264.26	2.9 (1.1%)
¹ Notes: This table is not used for Energy Code Compliance.			

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 6 of 39)

C4. SOURCE ENERGY COMPLIANCE RESULTS FOR PERFORMANCE COMPONENTS (Annual SOURCE Energy Use, kBtu/ft² /yr)			
COMPLIES²			
Energy Component	Standard Design (SOURCE)	Proposed Design (SOURCE)	Compliance Margin (SOURCE)¹
Space Heating	6.76	6.75	0.01
Space Cooling	1.48	1.48	0
Indoor Fans	1.97	1.97	0
Heat Rejection	0	0	0
Pumps & Misc.	0	0	0
Domestic Hot Water	11.53	11.12	0.41
Indoor Lighting	2.07	2.07	0
Flexibility	---	---	---
EFFICIENCY COMPLIANCE TOTAL	23.81	23.39	0.42 (1.8%)
Photovoltaics	-0.43	-0.43	---
Batteries	---	---	---
TOTAL COMPLIANCE	23.38	22.96	0.42 (1.8%)
¹ Notes: This number in parenthesis following the Compliance Margin in column 4, represents the Percent Better than Standard.			

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 7 of 39)

C5. SOURCE ENERGY RESULTS FOR NON-REGULATED COMPONENTS¹			
Non-Regulated Energy Component	Standard Design (SOURCE)	Proposed Design (SOURCE)	Compliance Margin (SOURCE)¹
Receptacle	8.04	8.04	---
Process	2.07	2.07	---
Other Ltg	0.91	0.91	---
Process Motors	---	---	---
TOTAL (TOTAL COMPLIANCE + NON-REGULATED COMPONENTS)	34.4	33.98	0.42 (1.2%)
¹ Notes: This table is not used for Energy Code Compliance.			

C6. 'ABOVE CODE' QUALIFICATIONS	
☐ This project is pursuing CalGreen Tier 1	☐ This project is pursuing CalGreen Tier 2

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 8 of 39)

C7. ENERGY USE SUMMARY						
Energy Component	Standard Design Site (MWh)	Proposed Design Site (MWh)	Margin (MWh)	Standard Design Site (MBtu)	Proposed Design Site (MBtu)	Margin (MBtu)
Space Heating	0	0	0	328.3	328.1	0.2
Space Cooling	40.2	40.2	0	---	---	---
Indoor Fans	36	36	0	---	---	---
Heat Rejection	---	---	---	---	---	---
Pumps & Misc.	0	0	0	---	---	---
Domestic Hot Water	3.7	0.6	3.1	550.2	539.5	10.7
Indoor Lighting	36.6	36.6	0	---	---	---
Flexibility	---	---	---	---	---	---
EFFICIENCY TOTAL	116.5	113.4	3.1	878.5	867.6	10.9
Photovoltaics	-35.2	-35.2	0	---	---	---
Batteries	---	---	---	---	---	---
ENERGY USE SUBTOTAL	81.3	78.2	3.1	878.5	867.6	10.9
Receptacle	132.1	132.1	0	6.9	6.9	0
Process	34.9	34.9	0	---	---	---
Other Ltg	12.5	12.5	0	---	---	---
Process Motors	---	---	---	---	---	---
ENERGY USE TOTAL	260.8	257.7	3.1	885.4	874.5	10.9

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 9 of 39)

C8. ENERGY USE INTENSITY (EUI)				
	Standard Design (kBtu/ft² / yr)	Proposed Design (kBtu/ft² / yr)	Margin (kBtu/ft² / yr)	Margin Percentage
GROSS EUI ¹	44.54	44.04	0.5	1.12
NET EUI ¹	41.72	41.21	0.51	1.22
¹ Notes: Gross EUI is Energy Use Total (not including PV)/Total Building Area. Net EUI is Energy Use Total (including PV)/Total Building Area.				

D1. EXCEPTIONAL CONDITIONS
- The aged solar reflectance and aged thermal emittance must be listed in the Cool Roof Rating Council database of certified products. For projects where initial reflectance is used, the initial reflectance must be listed, and the aged reflectance is calculated by the software program and used in the compliance model. - Verify that the space(s) defined with no lighting installed are either unconditioned spaces, or that the project has partial lighting compliance.

F1. REQUIRED PV SYSTEMS											
01	02	03	04	05	06	07	08	09	10	11	12
DC System Size (kWdc)	Exception¹	Module Type	Array Type	Power Electronics	CFI	Azimuth (deg)	Tilt Input	Array Angle (deg)	Tilt: (x in 12)	Inverter Eff. (%)	Annual Solar Access (%)
22.5		Standard (14-17%)	Fixed	none	true	150-270	n/a	n/a	<=7:12	96	98
¹ See Table D1 for any PV exceptions used.											

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 10 of 39)

F1B. PV BATTERY BUILDING TYPE(S)		
01	02	03
Building Occupancy Type* (From Table 140.10-A/B and 170.2-U/V)	Conditioned Floor Area (ft²)	Unconditioned Floor Area (ft²)
Grocery	0	0
High-Rise Multifamily	0	0
Office, Financial Institutions, Unleased Tenant Space	1404	0
Retail	0	0
School	0	0
Warehouse	0	0
Auditorium, Convention Center, Hotel/Motel, Library, Medical Office Building/Clinic, Restaurant, Theater	41150	0
None	0	0
<i>*Building Occupancy Types are defined in Section 100.1 of the Energy Code</i>		

F2. BATTERY SYSTEMS¹						
01	02	03	04	05	06	07
Control	Capacity (kWh)	Charging Efficiency	Charging Rate (kW)	Discharging Efficiency	Discharging Rate (kW)	Round Trip Efficiency
Basic	25.5	N/A	6.01	N/A	6.01	0.9
¹ See Table D1 for any Battery exceptions used.						

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 11 of 39)

G1. ENVELOPE GENERAL INFORMATION (conditioned spaces only)			
01	02	03	04
Opaque Surfaces & Orientation	Total Gross Surface Area (ft ²)	Total Fenestration Area (ft ²)	Window to Wall Ratio (%)
North-Facing ¹	6840.08	779.19	11.39
East-Facing ²	2280.08	71.26	3.13
South-Facing ³	6840.08	1042.31	15.24
West-Facing ⁴	2280.08	90.16	3.95
Total	18240.3	1982.92	10.87
Roof	10800.5	0	0
Notes ¹ North-Facing is oriented to within 45 degrees of true north, including 4500'00" east of north (NE), but excluding 4500'00" west of north (NW), ² East-Facing is oriented to within 45 degrees of true east, including 4500'00" south of east (SE), but excluding 4500'00" north of east (NE), ³ South-Facing is oriented to within 45 degrees of true south, including 4500'00" west of south (SW), but excluding 4500'00" east of south (SE), ⁴ West-Facing is oriented to within 45 degrees of true west, including 4500'00" north of west (NW), but excluding 4500'00" south of west (SW),			

G2A. ROOFING PRODUCT SUMMARY (NONRESIDENTIAL)					
01	02	03	04	05	06
Assembly Name	Roof Pitch	Roof Rise (x in 12)	Aged Solar Reflectance	Thermal Emittance	SRI
Base_CZ12-FlatNonresWoodFramingAndOtherRoofU034	LowSlope	N/A	0.63	0.75	N/A
Base_CZ12-FlatResWoodFramingAndOtherRoofU028	LowSlope	N/A	0.08	0.85	N/A

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 12 of 39)

G4. NONRESIDENTIAL AIR BARRIER	
01	02
Building Story Name	Air Barrier
Building Story 1	Air barrier - not verified
Building Story 2	Air barrier - not verified
Building Story 3	Air barrier - not verified
Building Story 4	Air barrier - not verified

Not useable for compliance

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 13 of 39)

G5. OPAQUE SURFACE ASSEMBLY SUMMARY										
01	02	03	04	05	06		07	08	09	10
Surface Name	Construction Type	Area (ft²)	Framing Type	Cavity R-Value	Continuous R-Value		Units	Value	Description of Assembly Layers	Status ¹
					Interior	Exterior				
Base_CZ12-NonresMetalFrameWallU055	Exterior Wall	8,291.26	Metal	0	N/A	16.05	U-factor	0.055	Stucco - 7/8 in. Compliance Insulation R14.60 Compliance Insulation R1.41 Compliance Insulation R0.02 Compliance Insulation R0.02 Air - Metal Wall Framing - 16 or 24 in. OC Gypsum Board - 1/2 in.	N
Base_CZ12-ResMetalFrameWallU069	Exterior Wall	9,949.07	Metal	0	N/A	12.36	U-factor	0.069	Stucco - 7/8 in. Compliance Insulation R10.06 Compliance Insulation R2.00 Compliance Insulation R0.20 Compliance Insulation R0.10 Air - Metal Wall Framing - 16 or 24 in. OC Gypsum Board - 1/2 in.	N
NACM_Interior Wall	Interior Wall	28,742.6	Metal	0	N/A	N/A	U-factor	0.3195	Gypsum Board - 5/8 in. Air - Metal Wall Framing - 16 or 24 in. OC Gypsum Board - 5/8 in.	N
Base_CZ12-FlatNonresWoodFramingAndOtherRoofU034	Roof	2,295.14	N/A	0	N/A	28.63	U-factor	0.034	Metal Standing Seam - 1/16 in. Compliance Insulation R28.63	N
Base_CZ12-FlatResWoodFramingAndOtherRoofU028	Roof	8,505.35	N/A	0	N/A	34.93	U-factor	0.028	Metal Standing Seam - 1/16 in. Compliance Insulation R34.93	N
Base_CZ12-NonresOtherFloorU071	Exterior Floor	9,045.41	N/A	0	N/A	9.83	U-factor	0.071	Compliance Insulation R9.83 Plywood - 5/8 in. Carpet - 3/4 in.	N
¹ Status: N - New, A - Altered, E - Existing										

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 14 of 39)

G5. OPAQUE SURFACE ASSEMBLY SUMMARY										
01	02	03	04	05	06		07	08	09	10
Surface Name	Construction Type	Area (ft²)	Framing Type	Cavity R-Value	Continuous R-Value		Units	Value	Description of Assembly Layers	Status ¹
					Interior	Exterior				
Base_CZ12-ResOtherFloor U039	Exterior Floor	1,755.08	N/A	0	N/A	21.39	U-factor	0.039	Compliance Insulation R21.39 Plywood - 5/8 in. Carpet - 3/4 in.	N
NACM_Interior Floor	Interior Floor	31,915.5	N/A	0	N/A	N/A	U-factor	0.2375	Metal Deck - 1/16 in. Concrete - 140 lb/ft3 - 4 in. Carpet - 3/4 in.	N
NACM_Droppe d Ceiling	Interior Floor	486	N/A	0	N/A	N/A	U-factor	0.2924	Acoustic Tile - 3/4 in.	N
¹ Status: N - New, A - Altered, E - Existing										

G7A. FENESTRATION ASSEMBLY SUMMARY (NONRESIDENTIAL)								
01	02	03	04	05	06	07	08	09
Fenestration Assembly Name	Fenestration Type/ Product Type / Frame Type	Certification Method ¹	Assembly Method	Area (ft ²)	Overall U-factor	Overall SHGC	Overall VT	Status ²
Base_AllCZ_FixedW inU34_NRes	Vertical fenestration Fixed window N/A	NFRC	Manufactured	562.46	0.34	0.22	0.42	N
Base_AllCZ_FixedW inU36_Res	Vertical fenestration Fixed window N/A	NFRC	Manufactured	1,420.45	0.36	0.25	0.42	N
¹ Notes: Newly installed fenestration shall have a certified NFRC Label Certificate or use the CEC default tables found in Table 110.6-A and Table 110.6-B. Center of Glass (COG) values are for the glass-only, determined by the manufacturer, and are shown for ease of verification. Site-built fenestration values are calculated per Nonresidential Appendix NA6 and are used in the analysis.								
² Status: N - New, A - Altered, E - Existing								

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 15 of 39)

H1. DRY SYSTEM EQUIPMENT (FURNACES, AIR HANDLING UNITS, HEAT PUMPS, VRF, ECONOMIZERS ETC.)											
01	02	03	04	05	06	07	08	09	10	11	12
Equipment Name	Equipment Type	Qty	Heating				Cooling			Economizer Type (if present)	Status ¹
			Total Heating Output (kBtu/h)	Supp Heat Output (kBtu/h)	Efficiency Unit	Efficiency	Total Cooling Output (kBtu/h)	Efficiency Unit	Efficiency		
BaseAirSys5	Package VAV Air System	1	280.19	0	N/A	NA - See Boiler	331.34	EER	9.8	Fixed DB	N
BaseAirSys5-2	Package VAV Air System	1	25.25	0	N/A	NA - See Boiler	23.03	SEER	14	No Economizer	N
BaseAirSys5-3	Package VAV Air System	1	25.36	0	N/A	NA - See Boiler	23.39	SEER	14	No Economizer	N
BaseAirSys5-4	Package VAV Air System	1	36.58	0	N/A	NA - See Boiler	34.2	SEER	14	Fixed DB	N
GuestRoom101_S ZAC	Single Zone Air Conditioner	1	7.06	0	AFUE	0	5.97	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom102_S ZAC	Single Zone Air Conditioner	1	7.08	0	AFUE	0	5.99	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom103_S ZAC	Single Zone Air Conditioner	1	7.12	0	AFUE	0	6.02	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom104_S ZAC	Single Zone Air Conditioner	1	7.12	0	AFUE	0	6.02	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom105_S ZAC	Single Zone Air Conditioner	1	7.08	0	AFUE	0	5.98	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom201_S ZAC	Single Zone Air Conditioner	1	7.69	0	AFUE	0	6.71	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom202_205_SZAC	Single Zone Air Conditioner	4	5.49	0	AFUE	0	5.07	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom206_208_SZAC	Single Zone Air Conditioner	3	5.93	0	AFUE	0	5.18	EER2 SEER2	11.7 14.3	N/A	N
¹ Status: N - New, A - Altered, E - Existing											

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 16 of 39)

H1. DRY SYSTEM EQUIPMENT (FURNACES, AIR HANDLING UNITS, HEAT PUMPS, VRF, ECONOMIZERS ETC.)											
01	02	03	04	05	06	07	08	09	10	11	12
Equipment Name	Equipment Type	Qty	Heating				Cooling			Economizer Type (if present)	Status ¹
			Total Heating Output (kBtu/h)	Supp Heat Output (kBtu/h)	Efficiency Unit	Efficiency	Total Cooling Output (kBtu/h)	Efficiency Unit	Efficiency		
GuestRoom209_212_SZAC	Single Zone Air Conditioner	4	5.46	0	AFUE	0	4.63	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom213_SZAC	Single Zone Air Conditioner	1	6.02	0	AFUE	0	5.09	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom214_SZAC	Single Zone Air Conditioner	1	6.02	0	AFUE	0	5.09	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom215_218_SZAC	Single Zone Air Conditioner	4	5.45	0	AFUE	0	4.6	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom219_SZAC	Single Zone Air Conditioner	1	5.94	0	AFUE	0	5.02	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom220_223_SZAC	Single Zone Air Conditioner	4	5.39	0	AFUE	0	4.56	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom224_SZAC	Single Zone Air Conditioner	1	5.91	0	AFUE	0	5	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom301_SZAC	Single Zone Air Conditioner	1	7.99	0	AFUE	0	6.75	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom302_305_SZAC	Single Zone Air Conditioner	4	5.63	0	AFUE	0	4.76	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom306_308_SZAC	Single Zone Air Conditioner	3	6.15	0	AFUE	0	5.2	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom309_312_SZAC	Single Zone Air Conditioner	4	5.61	0	AFUE	0	4.74	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom313_SZAC	Single Zone Air Conditioner	1	6.11	0	AFUE	0	5.17	EER2 SEER2	11.7 14.3	N/A	N
¹ Status: N - New, A - Altered, E - Existing											

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD										NRCC-PRF-E	
Nonresidential Performance Compliance Method										(Page 17 of 39)	

H1. DRY SYSTEM EQUIPMENT (FURNACES, AIR HANDLING UNITS, HEAT PUMPS, VRF, ECONOMIZERS ETC.)											
01	02	03	04	05	06	07	08	09	10	11	12
Equipment Name	Equipment Type	Qty	Heating				Cooling			Economizer Type (if present)	Status ¹
			Total Heating Output (kBtu/h)	Supp Heat Output (kBtu/h)	Efficiency Unit	Efficiency	Total Cooling Output (kBtu/h)	Efficiency Unit	Efficiency		
GuestRoom314_S_ZAC	Single Zone Air Conditioner	1	6.11	0	AFUE	0	5.16	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom315_318_SZAC	Single Zone Air Conditioner	4	5.6	0	AFUE	0	4.73	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom319_S_ZAC	Single Zone Air Conditioner	1	6.07	0	AFUE	0	5.14	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom320_323_SZAC	Single Zone Air Conditioner	4	5.54	0	AFUE	0	4.69	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom324_S_ZAC	Single Zone Air Conditioner	1	6.05	0	AFUE	0	5.11	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom401_S_ZAC	Single Zone Air Conditioner	1	8.73	0	AFUE	0	7.91	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom402_405_SZAC	Single Zone Air Conditioner	4	6.02	0	AFUE	0	6.02	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom406_408_SZAC	Single Zone Air Conditioner	3	6.58	0	AFUE	0	6.62	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom409_412_SZAC	Single Zone Air Conditioner	4	5.98	0	AFUE	0	6	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom413_S_ZAC	Single Zone Air Conditioner	1	6.55	0	AFUE	0	6.22	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom414_S_ZAC	Single Zone Air Conditioner	1	6.55	0	AFUE	0	5.54	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom415_418_SZAC	Single Zone Air Conditioner	4	5.96	0	AFUE	0	5.32	EER2 SEER2	11.7 14.3	N/A	N
¹ Status: N - New, A - Altered, E - Existing											

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 18 of 39)

H1. DRY SYSTEM EQUIPMENT (FURNACES, AIR HANDLING UNITS, HEAT PUMPS, VRF, ECONOMIZERS ETC.)											
01	02	03	04	05	06	07	08	09	10	11	12
Equipment Name	Equipment Type	Qty	Heating				Cooling			Economizer Type (if present)	Status ¹
			Total Heating Output (kBtu/h)	Supp Heat Output (kBtu/h)	Efficiency Unit	Efficiency	Total Cooling Output (kBtu/h)	Efficiency Unit	Efficiency		
GuestRoom419_S_ZAC	Single Zone Air Conditioner	1	6.54	0	AFUE	0	5.53	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom420_423_SZAC	Single Zone Air Conditioner	4	5.89	0	AFUE	0	5.31	EER2 SEER2	11.7 14.3	N/A	N
GuestRoom424_S_ZAC	Single Zone Air Conditioner	1	6.49	0	AFUE	0	5.49	EER2 SEER2	11.7 14.3	N/A	N
¹ Status: N - New, A - Altered, E - Existing											

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 19 of 39)

H3. NONRESIDENTIAL / COMMON USE AREA FAN SYSTEMS SUMMARY												
01	02	03	04	05	06	07	08	09	10	11	12	13
Name or Item Tag	Qty	Design OA CFM	Supply Fan				Return / Relief Fan					Status ¹
			CFM	Power	Power Units	Control	Fan Type	CFM	Power	Power Units	Control	
BaseAirSys5	1	2249.23	8,462.22	1.02	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
BaseAirSys5-2	1	319.97	560.6	1	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
BaseAirSys5-3	1	319.97	569.41	1	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
BaseAirSys5-4	1	319.97	841.13	1	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
GuestRoom101_SZAC	1	0	219.13	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom102_SZAC	1	0	219.72	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom103_SZAC	1	0	220.97	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom104_SZAC	1	0	220.89	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom105_SZAC	1	0	219.6	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom201_SZAC	1	0	246.34	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom202_205_SZAC	4	0	186.06	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom206_208_SZAC	3	0	190.14	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom209_212_SZAC	4	0	170.04	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom213_SZAC	1	0	186.84	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom214_SZAC	1	0	186.78	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom215_218_SZAC	4	0	169.01	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom219_SZAC	1	0	184.22	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom220_223_SZAC	4	0	167.29	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom224_SZAC	1	0	183.49	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
¹ Status: N - New, A - Altered, E - Existing												

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 20 of 39)

H3. NONRESIDENTIAL / COMMON USE AREA FAN SYSTEMS SUMMARY												
01	02	03	04	05	06	07	08	09	10	11	12	13
Name or Item Tag	Qty	Design OA CFM	Supply Fan				Return / Relief Fan					Status ¹
			CFM	Power	Power Units	Control	Fan Type	CFM	Power	Power Units	Control	
GuestRoom301_SZAC	1	0	247.85	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom302_305_SZAC	4	0	174.82	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom306_308_SZAC	3	0	190.79	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom309_312_SZAC	4	0	174.06	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom313_SZAC	1	0	189.6	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom314_SZAC	1	0	189.58	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom315_318_SZAC	4	0	173.74	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom319_SZAC	1	0	188.54	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom320_323_SZAC	4	0	172.1	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom324_SZAC	1	0	187.69	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom401_SZAC	1	0	290.44	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom402_405_SZAC	4	0	221.04	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom406_408_SZAC	3	0	243.04	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom409_412_SZAC	4	0	220.27	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom413_SZAC	1	0	228.17	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom414_SZAC	1	0	203.48	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom415_418_SZAC	4	0	195.18	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
¹ Status: N - New, A - Altered, E - Existing												

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 21 of 39)

H3. NONRESIDENTIAL / COMMON USE AREA FAN SYSTEMS SUMMARY												
01	02	03	04	05	06	07	08	09	10	11	12	13
Name or Item Tag	Qty	Design OA CFM	Supply Fan				Return / Relief Fan					Status ¹
			CFM	Power	Power Units	Control	Fan Type	CFM	Power	Power Units	Control	
GuestRoom419_SZAC	1	0	202.94	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom420_423_SZAC	4	0	194.92	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom424_SZAC	1	0	201.41	0.45	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom101-Exh ZnSys	1	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom102-Exh ZnSys	1	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom103-Exh ZnSys	1	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom104-Exh ZnSys	1	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom105-Exh ZnSys	1	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom201-Exh ZnSys	1	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom202_205-Exh ZnSys	4	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom206_208-Exh ZnSys	3	56.7	56.7	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom209_212-Exh ZnSys	4	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom213-Exh ZnSys	1	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom214-Exh ZnSys	1	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
¹ Status: N - New, A - Altered, E - Existing												

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 22 of 39)

H3. NONRESIDENTIAL / COMMON USE AREA FAN SYSTEMS SUMMARY												
01	02	03	04	05	06	07	08	09	10	11	12	13
Name or Item Tag	Qty	Design OA CFM	Supply Fan				Return / Relief Fan					Status ¹
			CFM	Power	Power Units	Control	Fan Type	CFM	Power	Power Units	Control	
GuestRoom215_218-Exh ZnSys	4	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom219-Exh ZnSys	1	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom220_223-Exh ZnSys	4	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom224-Exh ZnSys	1	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom301-Exh ZnSys	1	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom302_305-Exh ZnSys	4	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom306_308-Exh ZnSys	3	56.7	56.7	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom309_312-Exh ZnSys	4	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom313-Exh ZnSys	1	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom314-Exh ZnSys	1	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom315_318-Exh ZnSys	4	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom319-Exh ZnSys	1	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom320_323-Exh ZnSys	4	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
¹ Status: N - New, A - Altered, E - Existing												

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 23 of 39)

H3. NONRESIDENTIAL / COMMON USE AREA FAN SYSTEMS SUMMARY												
01	02	03	04	05	06	07	08	09	10	11	12	13
Name or Item Tag	Qty	Design OA CFM	Supply Fan				Return / Relief Fan					Status ¹
			CFM	Power	Power Units	Control	Fan Type	CFM	Power	Power Units	Control	
GuestRoom324-Exh ZnSys	1	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom401-Exh ZnSys	1	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom402_405-Exh ZnSys	4	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom406_408-Exh ZnSys	3	56.7	56.7	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom409_412-Exh ZnSys	4	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom413-Exh ZnSys	1	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom414-Exh ZnSys	1	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom415_418-Exh ZnSys	4	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom419-Exh ZnSys	1	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom420_423-Exh ZnSys	4	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
GuestRoom424-Exh ZnSys	1	52.65	52.65	0.58	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
¹ Status: N - New, A - Altered, E - Existing												

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 24 of 39)

H5. GENERAL EXHAUST FAN SUMMARY							
01	02	03	04	05	06	07	08
System ID	Zone Name	Qty	CFM	Power	Power Units	Continuous Operation?	Status¹
GuestRoom101-Exh ZnSys	GuestRoom101 Thermal Zone	1	52.65	0.58	WattsPerCFM	No	N
GuestRoom102-Exh ZnSys	GuestRoom102 Thermal Zone	1	52.65	0.58	WattsPerCFM	No	N
GuestRoom103-Exh ZnSys	GuestRoom103 Thermal Zone	1	52.65	0.58	WattsPerCFM	No	N
GuestRoom104-Exh ZnSys	GuestRoom104 Thermal Zone	1	52.65	0.58	WattsPerCFM	No	N
GuestRoom105-Exh ZnSys	GuestRoom105 Thermal Zone	1	52.65	0.58	WattsPerCFM	No	N
GuestRoom201-Exh ZnSys	GuestRoom201 Thermal Zone	1	52.65	0.58	WattsPerCFM	No	N
GuestRoom202_205-Exh ZnSys	GuestRoom202_205 Thermal Zone	4	52.65	0.58	WattsPerCFM	No	N
GuestRoom206_208-Exh ZnSys	GuestRoom206_208 Thermal Zone	3	56.7	0.58	WattsPerCFM	No	N
GuestRoom209_212-Exh ZnSys	GuestRoom209_212 Thermal Zone	4	52.65	0.58	WattsPerCFM	No	N
GuestRoom213-Exh ZnSys	GuestRoom213 Thermal Zone	1	52.65	0.58	WattsPerCFM	No	N
GuestRoom214-Exh ZnSys	GuestRoom214 Thermal Zone	1	52.65	0.58	WattsPerCFM	No	N
GuestRoom215_218-Exh ZnSys	GuestRoom215_218 Thermal Zone	4	52.65	0.58	WattsPerCFM	No	N
GuestRoom219-Exh ZnSys	GuestRoom219 Thermal Zone	1	52.65	0.58	WattsPerCFM	No	N
¹ Status: N - New, A - Altered, E - Existing							

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 25 of 39)

H5. GENERAL EXHAUST FAN SUMMARY							
01	02	03	04	05	06	07	08
System ID	Zone Name	Qty	CFM	Power	Power Units	Continuous Operation?	Status¹
GuestRoom220_223-Exh ZnSys	GuestRoom220_223 Thermal Zone	4	52.65	0.58	WattsPerCFM	No	N
GuestRoom224-Exh ZnSys	GuestRoom224 Thermal Zone	1	52.65	0.58	WattsPerCFM	No	N
GuestRoom301-Exh ZnSys	GuestRoom301 Thermal Zone	1	52.65	0.58	WattsPerCFM	No	N
GuestRoom302_305-Exh ZnSys	GuestRoom302_305 Thermal Zone	4	52.65	0.58	WattsPerCFM	No	N
GuestRoom306_308-Exh ZnSys	GuestRoom306_308 Thermal Zone	3	56.7	0.58	WattsPerCFM	No	N
GuestRoom309_312-Exh ZnSys	GuestRoom309_312 Thermal Zone	4	52.65	0.58	WattsPerCFM	No	N
GuestRoom313-Exh ZnSys	GuestRoom313 Thermal Zone	1	52.65	0.58	WattsPerCFM	No	N
GuestRoom314-Exh ZnSys	GuestRoom314 Thermal Zone	1	52.65	0.58	WattsPerCFM	No	N
GuestRoom315_318-Exh ZnSys	GuestRoom315_318 Thermal Zone	4	52.65	0.58	WattsPerCFM	No	N
GuestRoom319-Exh ZnSys	GuestRoom319 Thermal Zone	1	52.65	0.58	WattsPerCFM	No	N
GuestRoom320_323-Exh ZnSys	GuestRoom320_323 Thermal Zone	4	52.65	0.58	WattsPerCFM	No	N
GuestRoom324-Exh ZnSys	GuestRoom324 Thermal Zone	1	52.65	0.58	WattsPerCFM	No	N
GuestRoom401-Exh ZnSys	GuestRoom401 Thermal Zone	1	52.65	0.58	WattsPerCFM	No	N
¹ Status: N - New, A - Altered, E - Existing							

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 26 of 39)

H5. GENERAL EXHAUST FAN SUMMARY							
01	02	03	04	05	06	07	08
System ID	Zone Name	Qty	CFM	Power	Power Units	Continuous Operation?	Status¹
GuestRoom402_405-Exh ZnSys	GuestRoom402_405 Thermal Zone	4	52.65	0.58	WattsPerCFM	No	N
GuestRoom406_408-Exh ZnSys	GuestRoom406_408 Thermal Zone	3	56.7	0.58	WattsPerCFM	No	N
GuestRoom409_412-Exh ZnSys	GuestRoom409_412 Thermal Zone	4	52.65	0.58	WattsPerCFM	No	N
GuestRoom413-Exh ZnSys	GuestRoom413 Thermal Zone	1	52.65	0.58	WattsPerCFM	No	N
GuestRoom414-Exh ZnSys	GuestRoom414 Thermal Zone	1	52.65	0.58	WattsPerCFM	No	N
GuestRoom415_418-Exh ZnSys	GuestRoom415_418 Thermal Zone	4	52.65	0.58	WattsPerCFM	No	N
GuestRoom419-Exh ZnSys	GuestRoom419 Thermal Zone	1	52.65	0.58	WattsPerCFM	No	N
GuestRoom420_423-Exh ZnSys	GuestRoom420_423 Thermal Zone	4	52.65	0.58	WattsPerCFM	No	N
GuestRoom424-Exh ZnSys	GuestRoom424 Thermal Zone	1	52.65	0.58	WattsPerCFM	No	N
¹ Status: N - New, A - Altered, E - Existing							

H6. WET SYSTEM EQUIPMENT (boilers, chillers, cooling towers, etc.)									
01	02	03	04	05	06	07	08	09	10
Name or Item Tag	Equipment Type	Parent Fluid System Name	Qty	Vol (gal)	Rated Capacity	Capacity Unit	Rating	Rating Unit	Status¹
Base Blr	Hot Water	BaseHWSys	1	N/A	157.32	kBtu/Hr	0.82	AFUE	N
Base Blr-2	Hot Water	BaseHWSys	1	N/A	157.32	kBtu/Hr	0.82	AFUE	N
¹ Status: N - New, A - Altered, E - Existing									

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 27 of 39)

H7. PUMPS							
01	02	03	04	05	06	07	08
Name or Item Tag	Parent Equipment	Qty	Power	Power Units	GPM	VSD	Status¹
Base HW Pump	Base Blr	1	0.25	BHP	7.86	☒	N
Base HW Pump-2	Base Blr-2	1	0.25	BHP	7.86	☒	N
¹ Status: N - New, A - Altered, E - Existing							

H8. SYSTEM SPECIAL FEATURES			
01	02	03	04
System Name	Equipment Type	Interlocks per 140.4(n)¹	Other Special Features and Controls
BaseAirSys5	Package VAV Air System	N/A	DDC Controls Dual Maximum Reheat Controls Zone(s) With CO2 Sensor Vent. Control Warmest Zone Supply Air Temp. Reset Optimum Start Fixed DB
BaseAirSys5-2	Package VAV Air System	N/A	DDC Controls Dual Maximum Reheat Controls Warmest Zone Supply Air Temp. Reset Optimum Start
BaseAirSys5-3	Package VAV Air System	N/A	DDC Controls Dual Maximum Reheat Controls Warmest Zone Supply Air Temp. Reset Optimum Start
Notes: This table includes controls related to the performance path only. For projects using the prescriptive path, mandatory and prescriptive controls requirements are documented on the NRCC-MCH-E.			
¹ Yes = interlocks are provided, No = interlocks are not provided, NA means no operable openings.			

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 28 of 39)

H8. SYSTEM SPECIAL FEATURES			
01	02	03	04
System Name	Equipment Type	Interlocks per 140.4(n)¹	Other Special Features and Controls
BaseAirSys5-4	Package VAV Air System	N/A	DDC Controls Dual Maximum Reheat Controls Warmest Zone Supply Air Temp. Reset Optimum Start Fixed DB
SHWFluidSysGas	Service Hot Water	N/A	Fixed Temperature Control
SHWFluidSysElec	Service Hot Water	N/A	Fixed Temperature Control
BaseHWSysSystem	Hot Water System	N/A	DDC Controls Fixed Temperature Control
Notes: This table includes controls related to the performance path only. For projects using the prescriptive path, mandatory and prescriptive controls requirements are documented on the NRCC-MCH-E.			
¹ Yes = interlocks are provided, No = interlocks are not provided, NA means no operable openings.			

H9. NONRESIDENTIAL / COMMON USE AREA & HOTEL/MOTEL VENTILATION						
01	02	03	04	05	06	07
Zone Name	Mechanical Ventilation				Conditioned Area (sf)	DCV or Occupant Sensor Controls, or Both
	Ventilation Function	# of People	Supply OA CFM	Exhaust CFM		
CorridorFlr1 Thermal Zone	General - Corridors NA	8.1	243	0	1620.03	N/A
EmployeeLoungeFlr1 Thermal Zone	General - Corridors	1.75	52.65	0	351	N/A
ExerciseCenterFlr1 Thermal Zone	General - Corridors	1.75	52.65	0	351	N/A
FrontLoungeFlr1 Thermal Zone	Lodging - Multipurpose assembly	125.37	877.57	0	1755.13	DCV
FrontOfficeFlr1 Thermal Zone	Office - Office space	7.02	210.6	0	1404	N/A

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 29 of 39)

H9. NONRESIDENTIAL / COMMON USE AREA & HOTEL/MOTEL VENTILATION						
01	02	03	04	05	06	07
Zone Name	Mechanical Ventilation				Conditioned Area (sf)	DCV or Occupant Sensor Controls, or Both
	Ventilation Function	# of People	Supply OA CFM	Exhaust CFM		
LaundryRoomFlr1 Thermal Zone	Lodging - Laundry rooms, central	5.27	157.95	0	1053.01	N/A
MechanicalRoomFlr1 Thermal Zone	Misc - Telephone closets	0.53	52.65	0	351.03	N/A
MeetingRoomFlr1 Thermal Zone	Lodging - Multipurpose assembly	61.72	432.03	0	864.07	DCV
FrontStairsFlr1 Thermal Zone	General - Corridors	1.08	32.4	0	216	N/A
FrontStorageFlr1 Thermal Zone	General - Corridors	0.68	20.25	0	135	N/A
RearStairsFlr1 Thermal Zone	General - Corridors	1.08	32.41	0	216.05	N/A
RearStorageFlr1 Thermal Zone	General - Corridors	1.08	32.41	0	216.07	N/A
RestroomFlr1 Thermal Zone	General - Corridors	1.76	52.65	0	351.03	N/A
CorridorFlr2 Thermal Zone	General - Corridors NA	6.75	202.5	0	1350.01	N/A
FrontStairsFlr2 Thermal Zone	General - Corridors	1.08	32.4	0	216	N/A
FrontStorageFlr2 Thermal Zone	General - Corridors	0.68	20.25	0	135	N/A
RearStairsFlr2 Thermal Zone	General - Corridors	1.08	32.41	0	216.05	N/A
RearStorageFlr2 Thermal Zone	General - Corridors	1.08	32.41	0	216.07	N/A
CorridorFlr3 Thermal Zone	General - Corridors NA	6.75	202.5	0	1350.01	N/A

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 30 of 39)

H9. NONRESIDENTIAL / COMMON USE AREA & HOTEL/MOTEL VENTILATION						
01	02	03	04	05	06	07
Zone Name	Mechanical Ventilation				Conditioned Area (sf)	DCV or Occupant Sensor Controls, or Both
	Ventilation Function	# of People	Supply OA CFM	Exhaust CFM		
FrontStairsFlr3 Thermal Zone	General - Corridors	1.08	32.4	0	216	N/A
FrontStorageFlr3 Thermal Zone	General - Corridors	0.68	20.25	0	135	N/A
RearStairsFlr3 Thermal Zone	General - Corridors	1.08	32.41	0	216.05	N/A
RearStorageFlr3 Thermal Zone	General - Corridors	1.08	32.41	0	216.07	N/A
CorridorFlr4 Thermal Zone	General - Corridors NA	6.75	202.5	0	1350.01	N/A
FrontStairsFlr4 Thermal Zone	General - Corridors	1.08	32.4	0	216	N/A
FrontStorageFlr4 Thermal Zone	General - Corridors	0.68	20.25	0	135	N/A
RearStairsFlr4 Thermal Zone	General - Corridors	1.08	32.41	0	216.05	N/A
RearStorageFlr4 Thermal Zone	General - Corridors	1.08	32.41	0	216.07	N/A

H11. ZONAL SYSTEM AND TERMINAL UNIT SUMMARY											
01	02	03	04	05	06	07	08	09	10	11	12
System ID	System Type	Qty	Rated Capacity (kBtuh)		Airflow (cfm)			Fan			VSD
			Heating	Cooling	Design	Min.	Min. Ratio	Power	Power Units	Cycles	
BaseVAVTrmlUnit	Variable Air Volume Reheat Box	1	43.21	N/A	991.74	243	0.25	N/A	N/A	N/A	☐

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 31 of 39)

H11. ZONAL SYSTEM AND TERMINAL UNIT SUMMARY											
01	02	03	04	05	06	07	08	09	10	11	12
System ID	System Type	Qty	Rated Capacity (kBtuh)		Airflow (cfm)			Fan			VSD
			Heating	Cooling	Design	MIn.	Min. Ratio	Power	Power Units	Cycles	
BaseVAVTrmlUnit-5	Variable Air Volume Reheat Box	1	8.44	N/A	149.17	52.65	0.35	N/A	N/A	N/A	☐
BaseVAVTrmlUnit-6	Variable Air Volume Reheat Box	1	8.25	N/A	154.69	52.65	0.34	N/A	N/A	N/A	☐
BaseVAVTrmlUnit-7	Variable Air Volume Reheat Box	1	39.74	N/A	2,228.44	263.27	0.12	N/A	N/A	N/A	☐
BaseVAVTrmlUnit-8	Variable Air Volume Reheat Box	1	26.35	N/A	889.56	210.6	0.24	N/A	N/A	N/A	☐
BaseVAVTrmlUnit-9	Variable Air Volume Reheat Box	1	20.31	N/A	915.49	157.95	0.17	N/A	N/A	N/A	☐
BaseVAVTrmlUnit-10	Variable Air Volume Reheat Box	1	8	N/A	424.68	52.65	0.12	N/A	N/A	N/A	☐
BaseVAVTrmlUnit-11	Variable Air Volume Reheat Box	1	19.29	N/A	1,080.25	129.61	0.12	N/A	N/A	N/A	☐
BaseVAVTrmlUnit-12	Variable Air Volume Reheat Box	1	7.44	N/A	159.32	32.4	0.2	N/A	N/A	N/A	☐
BaseVAVTrmlUnit-16	Variable Air Volume Reheat Box	1	4.52	N/A	112.2	20.25	0.18	N/A	N/A	N/A	☐
BaseVAVTrmlUnit-20	Variable Air Volume Reheat Box	1	7.54	N/A	141.45	32.41	0.23	N/A	N/A	N/A	☐
BaseVAVTrmlUnit-24	Variable Air Volume Reheat Box	1	7.54	N/A	148.22	32.41	0.22	N/A	N/A	N/A	☐
BaseVAVTrmlUnit-28	Variable Air Volume Reheat Box	1	7.99	N/A	234.74	52.65	0.22	N/A	N/A	N/A	☐
BaseVAVTrmlUnit-2	Variable Air Volume Reheat Box	1	8.96	N/A	239.69	202.5	0.84	N/A	N/A	N/A	☐

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 32 of 39)

H11. ZONAL SYSTEM AND TERMINAL UNIT SUMMARY											
01	02	03	04	05	06	07	08	09	10	11	12
System ID	System Type	Qty	Rated Capacity (kBtuh)		Airflow (cfm)			Fan			VSD
			Heating	Cooling	Design	MIn.	Min. Ratio	Power	Power Units	Cycles	
BaseVAVTrmlUnit-13	Variable Air Volume Reheat Box	1	1.71	N/A	85.4	32.4	0.38	N/A	N/A	N/A	☐
BaseVAVTrmlUnit-17	Variable Air Volume Reheat Box	1	0.84	N/A	31.19	20.25	0.65	N/A	N/A	N/A	☐
BaseVAVTrmlUnit-21	Variable Air Volume Reheat Box	1	2.08	N/A	73.74	32.41	0.44	N/A	N/A	N/A	☐
BaseVAVTrmlUnit-25	Variable Air Volume Reheat Box	1	2.08	N/A	78.44	32.41	0.41	N/A	N/A	N/A	☐
BaseVAVTrmlUnit-3	Variable Air Volume Reheat Box	1	9.02	N/A	237.08	202.5	0.85	N/A	N/A	N/A	☐
BaseVAVTrmlUnit-14	Variable Air Volume Reheat Box	1	1.67	N/A	88.28	32.4	0.37	N/A	N/A	N/A	☐
BaseVAVTrmlUnit-18	Variable Air Volume Reheat Box	1	0.84	N/A	32.2	20.25	0.63	N/A	N/A	N/A	☐
BaseVAVTrmlUnit-22	Variable Air Volume Reheat Box	1	2.05	N/A	75.14	32.41	0.43	N/A	N/A	N/A	☐
BaseVAVTrmlUnit-26	Variable Air Volume Reheat Box	1	2.05	N/A	79.89	32.41	0.41	N/A	N/A	N/A	☐
BaseVAVTrmlUnit-4	Variable Air Volume Reheat Box	1	14.15	N/A	377.75	202.5	0.54	N/A	N/A	N/A	☐
BaseVAVTrmlUnit-15	Variable Air Volume Reheat Box	1	2.15	N/A	114.24	32.4	0.28	N/A	N/A	N/A	☐
BaseVAVTrmlUnit-19	Variable Air Volume Reheat Box	1	1.25	N/A	48.26	20.25	0.42	N/A	N/A	N/A	☐
BaseVAVTrmlUnit-23	Variable Air Volume Reheat Box	1	2.7	N/A	102.52	32.41	0.32	N/A	N/A	N/A	☐

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 33 of 39)

H11. ZONAL SYSTEM AND TERMINAL UNIT SUMMARY											
01	02	03	04	05	06	07	08	09	10	11	12
System ID	System Type	Qty	Rated Capacity (kBtuh)		Airflow (cfm)			Fan			VSD
			Heating	Cooling	Design	Min.	Min. Ratio	Power	Power Units	Cycles	
BaseVAVTrmlUnit-27	Variable Air Volume Reheat Box	1	2.7	N/A	109.13	32.41	0.3	N/A	N/A	N/A	☐
GuestRoom101_SZAC	Single Zone Air Conditioner	1	7.06	5.97	219.13	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom102_SZAC	Single Zone Air Conditioner	1	7.08	5.99	219.72	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom103_SZAC	Single Zone Air Conditioner	1	7.12	6.02	220.97	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom104_SZAC	Single Zone Air Conditioner	1	7.12	6.02	220.89	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom105_SZAC	Single Zone Air Conditioner	1	7.08	5.98	219.6	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom201_SZAC	Single Zone Air Conditioner	1	7.69	6.71	246.34	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom202_205_SZAC	Single Zone Air Conditioner	4	5.49	5.07	186.06	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom206_208_SZAC	Single Zone Air Conditioner	3	5.93	5.18	190.14	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom209_212_SZAC	Single Zone Air Conditioner	4	5.46	4.63	170.04	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom213_SZAC	Single Zone Air Conditioner	1	6.02	5.09	186.84	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom214_SZAC	Single Zone Air Conditioner	1	6.02	5.09	186.78	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom215_218_SZAC	Single Zone Air Conditioner	4	5.45	4.6	169.01	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom219_SZAC	Single Zone Air Conditioner	1	5.94	5.02	184.22	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom220_223_SZAC	Single Zone Air Conditioner	4	5.39	4.56	167.29	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom224_SZAC	Single Zone Air Conditioner	1	5.91	5	183.49	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom301_SZAC	Single Zone Air Conditioner	1	7.99	6.75	247.85	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom302_305_SZAC	Single Zone Air Conditioner	4	5.63	4.76	174.82	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom306_308_SZAC	Single Zone Air Conditioner	3	6.15	5.2	190.79	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom309_312_SZAC	Single Zone Air Conditioner	4	5.61	4.74	174.06	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom313_SZAC	Single Zone Air Conditioner	1	6.11	5.17	189.6	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom314_SZAC	Single Zone Air Conditioner	1	6.11	5.16	189.58	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom315_318_SZAC	Single Zone Air Conditioner	4	5.6	4.73	173.74	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom319_SZAC	Single Zone Air Conditioner	1	6.07	5.14	188.54	N/A	N/A	0.45	W/cfm	Cycling	☐

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 34 of 39)

H11. ZONAL SYSTEM AND TERMINAL UNIT SUMMARY											
01	02	03	04	05	06	07	08	09	10	11	12
System ID	System Type	Qty	Rated Capacity (kBtuh)		Airflow (cfm)			Fan			VSD
			Heating	Cooling	Design	MIn.	Min. Ratio	Power	Power Units	Cycles	
GuestRoom320_323_SZAC	Single Zone Air Conditioner	4	5.54	4.69	172.1	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom324_SZAC	Single Zone Air Conditioner	1	6.05	5.11	187.69	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom401_SZAC	Single Zone Air Conditioner	1	8.73	7.91	290.44	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom402_405_SZAC	Single Zone Air Conditioner	4	6.02	6.02	221.04	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom406_408_SZAC	Single Zone Air Conditioner	3	6.58	6.62	243.04	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom409_412_SZAC	Single Zone Air Conditioner	4	5.98	6	220.27	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom413_SZAC	Single Zone Air Conditioner	1	6.55	6.22	228.17	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom414_SZAC	Single Zone Air Conditioner	1	6.55	5.54	203.48	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom415_418_SZAC	Single Zone Air Conditioner	4	5.96	5.32	195.18	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom419_SZAC	Single Zone Air Conditioner	1	6.54	5.53	202.94	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom420_423_SZAC	Single Zone Air Conditioner	4	5.89	5.31	194.92	N/A	N/A	0.45	W/cfm	Cycling	☐
GuestRoom424_SZAC	Single Zone Air Conditioner	1	6.49	5.49	201.41	N/A	N/A	0.45	W/cfm	Cycling	☐

I1. WATER HEATER EQUIPMENT SUMMARY													
01	02	03	04	05	06	07	08	09	10	11	12	13	14
Name	Heater Element Type	Tank Type	Qty	Tank Vol (gal)	Rated Input	Rated Input Unit	Efficiency	Efficiency Unit	Tank Insulation R-value Int/Ext	Standby Loss Fraction	1st Hr. Rating or Flow Rate (gal)	Heat Pump Type	Tank Location or Ambient Condition
GuestRm WaterHeater	Natural Gas	Commercial Instantaneous (TE)	1	1,000	N/A	N/A	0.8	TE	N/A	N/A	N/A	N/A	N/A
WaterHeaterGas	Natural Gas	Storage	1	28.18	35.03	kBtu/Hr	0.68	UEF	N/A	N/A	80	N/A	N/A
WaterHeaterElec	Electricity	Instantaneous	1	1.82	8.74	kW	0.92	UEF	N/A	N/A	2	N/A	N/A

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 35 of 39)

12. MULTI-FAMILY WATER HEATING SYSTEM DETAIL							
01	02	03	04	05	06	07	08
System Name	Configuration	Type	Qty in System	Dwelling Unit Distribution Type	Water Heater Name	Solar Heating System	Is Compact Distribution
GuestRm DHW Sys	Domestic Hot Water (DHW)	Central	1	Standard Distribution System	GuestRm WaterHeater	DHW Solar System 1	N/A

15. RECIRCULATION LOOPS					
01	02	03	04	05	06
Water Heating System Name	Number of Recirculation Loops	Loop Insulation Thickness (in)	Recirculation Loop Location	Recirculation Pump Power	Recirculation Pump Power Units
GuestRm DHW Sys	1	1.5	Conditioned	4	Watts

16. SOLAR HOT WATER HEATING SUMMARY								
01	02	03	04	05	06	07	08	09
System Name	Collector							
	Manufacturer	Brand	Model	Count	Area (ft ²)	Solar Savings Fraction	Azimuth from N (deg)	Tilt from Horz. (deg)
DHW Solar System 1	SunEarth, Inc.	Empire	EC-40-1.5	12	41	N/A	180	40
10		11		12		13		
Name of program used		Program Version		Tank Volume (gal)		Tank Volume (gal)		
CSE		CSE 0.923.1 EXE		735		77		

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 36 of 39)

K1. INDOOR CONDITIONED LIGHTING GENERAL INFO					
01	02	03	04	05	06
Occupancy Type¹	Conditioned Floor Area² (ft²)	Installed Lighting Power (Watts)	Lighting Control Credits (Watts)	Additional (Custom) Allowance	
				Area Category Footnotes (Watts)	Area Category Footnotes (Watts)
Corridor	9855.6	3942.24	0	0	0
Electrical Mechanical Telephone Room	351.03	0	0	0	0
Hotel Function	2619.2	2226.32	0	0	0
Laundry	1053.01	473.85	0	0	0
Office (250 square feet)	1404	842.4	0	0	0
Building Totals:	15282.8	7484.81	0	0	0
¹ See Table 140.6-C ² See NRCC-LTI-E for unconditioned spaces ³ Lighting information for existing spaces modeled is not included in this table					

K4. INDOOR CONDITIONED LIGHTING MANDATORY LIGHTING CONTROL
See NRCC-LTI-E for mandatory controls

L. DECLARATION OF REQUIRED CERTIFICATES OF INSTALLATION	
Selections made by Documentation Author indicate which Certificates of Installation must be submitted for the features to be recognized for compliance. These documents must be retained and provided to the building inspector during construction and can be found online	
Building Component	Form/Title
Envelope	NRCI-ENV-E - Envelope (for all buildings)
Mechanical	NRCI-MCH-E - For all buildings with Mechanical Systems
Plumbing	NRCI-PLB-E - For all buildings with Plumbing Systems
	NRCI-SAB-E - Solar Water Heating, PV and Battery Storage Systems
Indoor Lighting	NRCI-LTI-E - Indoor Lighting (for all buildings)

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 37 of 39)

M. DECLARATION OF REQUIRED CERTIFICATES OF ACCEPTANCE	
Selections made by Documentation Author indicate which Certificates of Acceptance must be submitted for the features to be recognized for compliance. These documents must be provided to the building inspector during construction and must be completed through an Acceptance Test Technician Certification Provider (ATTCP).	
Building Component	Form/Title & System Name(s)
Envelope	NRCA-ENV-02-F - NRFC label verification for fenestration
Indoor Lighting	NRCA-LTI-02-A - Occupancy Sensors and Automatic Time Switch Controls.
Indoor Lighting	NRCA-LTI-03-A - Automatic Daylight Controls.
Indoor Lighting	NRCA-LTI-04-A - Demand Responsive Lighting Controls.
Mechanical	NRCA-MCH-02-A - Outdoor Air must be submitted for all newly installed HVAC units. Note: MCH-02-A can be performed in conjunction with MCH-07-A Supply Fan VFD Acceptance (if applicable) since testing activities overlap
	BaseAirSys5, BaseAirSys5-2, BaseAirSys5-3 and BaseAirSys5-4., GuestRoom101-Exh ZnSys, GuestRoom102-Exh ZnSys, GuestRoom103-Exh ZnSys, GuestRoom104-Exh ZnSys, GuestRoom105-Exh ZnSys, GuestRoom201-Exh ZnSys, GuestRoom202_205-Exh ZnSys, GuestRoom206_208-Exh ZnSys, GuestRoom209_212-Exh ZnSys, GuestRoom213-Exh ZnSys, GuestRoom214-Exh ZnSys, GuestRoom215_218-Exh ZnSys, GuestRoom219-Exh ZnSys, GuestRoom220_223-Exh ZnSys, GuestRoom224-Exh ZnSys, GuestRoom301-Exh ZnSys, GuestRoom302_305-Exh ZnSys, GuestRoom306_308-Exh ZnSys, GuestRoom309_312-Exh ZnSys, GuestRoom313-Exh ZnSys, GuestRoom314-Exh ZnSys, GuestRoom315_318-Exh ZnSys, GuestRoom319-Exh ZnSys, GuestRoom320_323-Exh ZnSys, GuestRoom324-Exh ZnSys, GuestRoom401-Exh ZnSys, GuestRoom402_405-Exh ZnSys, GuestRoom406_408-Exh ZnSys, GuestRoom409_412-Exh ZnSys, GuestRoom413-Exh ZnSys, GuestRoom414-Exh ZnSys, GuestRoom415_418-Exh ZnSys, GuestRoom419-Exh ZnSys, GuestRoom420_423-Exh ZnSys and GuestRoom424-Exh ZnSys.
Mechanical	NRCA-MCH-03-A - Constant Volume Single Zone HVAC
	GuestRoom101_SZAC, GuestRoom102_SZAC, GuestRoom103_SZAC, GuestRoom104_SZAC, GuestRoom105_SZAC, GuestRoom201_SZAC, GuestRoom202_205_SZAC, GuestRoom206_208_SZAC, GuestRoom209_212_SZAC, GuestRoom213_SZAC, GuestRoom214_SZAC, GuestRoom215_218_SZAC, GuestRoom219_SZAC, GuestRoom220_223_SZAC, GuestRoom224_SZAC, GuestRoom301_SZAC, GuestRoom302_305_SZAC, GuestRoom306_308_SZAC, GuestRoom309_312_SZAC, GuestRoom313_SZAC, GuestRoom314_SZAC, GuestRoom315_318_SZAC, GuestRoom319_SZAC, GuestRoom320_323_SZAC, GuestRoom324_SZAC, GuestRoom401_SZAC, GuestRoom402_405_SZAC, GuestRoom406_408_SZAC, GuestRoom409_412_SZAC, GuestRoom413_SZAC, GuestRoom414_SZAC, GuestRoom415_418_SZAC, GuestRoom419_SZAC, GuestRoom420_423_SZAC and GuestRoom424_SZAC.
Mechanical	NRCA-MCH-05-A - Air Economizer Controls
	BaseAirSys5 and BaseAirSys5-4.
Mechanical	NRCA-MCH-06-A Demand Control Ventilation Systems must be submitted for all systems required to employ demand controlled ventilation (refer to) can vary outside ventilation flow rates based on maintaining interior carbon dioxide (CO2) concentration setpoints.
	BaseAirSys5

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 38 of 39)

M. DECLARATION OF REQUIRED CERTIFICATES OF ACCEPTANCE	
Selections made by Documentation Author indicate which Certificates of Acceptance must be submitted for the features to be recognized for compliance. These documents must be provided to the building inspector during construction and must be completed through an Acceptance Test Technician Certification Provider (ATTCP).	
Building Component	Form/Title & System Name(s)
Mechanical	NRCA-MCH-07-A Supply Fan Variable Flow Controls
	BaseAirSys5, BaseAirSys5-2, BaseAirSys5-3 and BaseAirSys5-4.
Mechanical	NRCA-MCH-08-A Valve Leakage Test
	BaseHWSysSystem
Mechanical	NRCA-MCH-10-A Hydronic System Variable Flow Controls
	BaseHWSysSystem
Mechanical	NRCA-MCH-11-A Automatic Demand Shed Controls
	BaseAirSys5, BaseAirSys5-2, BaseAirSys5-3 and BaseAirSys5-4., BaseHWSysSystem
Mechanical	NRCA-MCH-12-A FDD for Packaged Direct Expansion Units
	BaseAirSys5 and BaseAirSys5-4.
Mechanical	NRCA-MCH-16-A Supply Air Temperature Reset Controls
	BaseAirSys5, BaseAirSys5-2, BaseAirSys5-3 and BaseAirSys5-4.
Mechanical	NRCA-MCH-19-A Occupancy Sensor Controls
	BaseAirSys5, BaseAirSys5-2, BaseAirSys5-3 and BaseAirSys5-4.

N. DECLARATION OF REQUIRED CERTIFICATES OF VERIFICATION	
Selections made by Documentation Author indicate which Certificates of Verification must be submitted for the features to be recognized for compliance. These documents must be retained and provided to the building inspector during construction and can be found online	
Building Component	Form/Title
Mechanical	NRCV-MCH-27 Indoor Air Quality & Mechanical Ventilation
Mechanical	NRCV-MCH-32 Local Mechanical Exhaust

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 39 of 39)

Documentation Author's Declaration Statement

1. I certify that this Certificate of Compliance documentation is accurate and complete.	
Documentation Author Name:	Documentation Author Signature:
Company:	Signature Date:
Address:	CEA/HERS Certification Identification (if applicable):
City/State/Zip: ,	Phone:

Responsible Person's Declaration statement

I certify the following under penalty of perjury, under the laws of the State of California:		
- The information provided on this Certificate of Compliance is true and correct. - I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer) - The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations. - The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application. - I understand that a registered copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections, and I will take the necessary steps to accomplish this requirement. - I understand that a registered copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy, and I will take the necessary steps to accomplish these requirements.		
Responsible Designer Name:	Responsible Designer Signature:	
Company:		
Address:	Date Signed:	
City/State/Zip: ,	License #:	
Phone:	Title:	Scope: