

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD		NRCC-PRF-E
Nonresidential Performance Compliance Method		(Page 1 of 23)
Project Name:	090012-RetlLrg-CECStd22	Date Prepared: 2025-12-23

A. General Information				
1	Project Name	090012-RetlLrg-CECStd22		
2	Run Title			
3	Project Location	- specify -		
4	City	- specify -	5	Standards Version
6	Zip code	95814	7	Compliance Software (version)
8	Climate Zone	12	9	Building Orientation (deg)
10	Building Type(s)	• Nonresidential	11	Weather File
12	Project Scope	• New complete scope	13	Number of Dwelling Units
14	Total Conditioned Floor Area in Scope (ft²)	240000	15	Total # of hotel/motel rooms
16	Total Unconditioned Floor Area (ft²)	0	17	Fuel Type
18	Nonresidential Conditioned Floor Area	240000	19	Total # of Stories (Habitable Above Grade)
20	Residential Conditioned Floor Area	0		

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 2 of 23)

B. PROJECT SUMMARY							
Table B shows which building components are included in the performance calculation. If indicated as not included, the project must show compliance prescriptively if within the permit application.							
Building Components Complying via Performance					Building Components Complying Prescriptively		
Envelope (See Table G)	Nonres	Performance	Solar Thermal Water Heating (See Table I3)	☐	Performance	The following building components are ONLY eligible for prescriptive compliance and should be documented on the NRCC form listed if within the scope of the permit application (i.e. compliance will not be shown on the NRCC-PRF-E).	
	MultiFam	Not Included		☒	Not Included		
Mechanical (See Table H)	Nonres	Performance	Covered Process: Commercial Kitchens (see Table J)	☐	Performance	Indoor Lighting (Unconditioned) 140.6 & 170.2(e)	NRCC-LTI-E is required
	MultiFam	Not Included		☒	Not Included	Outdoor Lighting 140.7 & 170.2(e)	NRCC-LTO-E is required
Domestic Hot Water (See Table I)	Nonres	Performance	Covered Process: Laboratory Exhaust (see Table J)	☐	Performance	Sign Lighting 140.8 & 170.2(e)	NRCC-LTS-E is required
	MultiFam	Not Included		☒	Not Included	Building Components Complying with Mandatory Measures	
Lighting (Indoor Conditioned, see Table K)	Nonres	Performance	Photovoltaics (see Table F)	☒	Performance	Electrical power systems, commissioning, solar ready, elevator and escalator requirements are mandatory and should be documented on the NRCC form listed if applicable (i.e. compliance will not be shown on the NRCC-PRF-E.)	
	MultiFam	Not Included		☐	Not Included	Electrical Power Distribution 110.11	NRCC-ELC-E is required
			Battery (see Table F)	☒	Performance	Commissioning 120.8	NRCC-CXR-E is required
				☐	Not Included	Solar and Battery 110.10	NRCC-SAB-E is required

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 3 of 23)

C1. COMPLIANCE SUMMARY			
COMPLIES ³			
	Time Dependent Valuaton (TDV)		Source Energy Use
	Efficiency ¹ (kBtu/ft ² - yr)	Total ² (kBtu/ft ² - yr)	Total ² (kBtu/ft ² - yr)
Standard Design	157.85	81.31	8.65
Proposed Design	157.85	81.31	8.65
Compliance Margins	0	0	0
	Pass	Pass	Pass
¹ Efficiency measures include improvements like a better building envelope and more efficient equipment ² Compliance Totals include efficiency, photovoltaics and batteries ³ New Construction, Complete Addition Scope: Building complies when all efficiency and total compliance margins are greater than or equal to zero and unmet load hour limits are not exceeded Existing, Addition and Alteration Scope: Building complies when efficiency compliance margin is greater than or equal to zero and unmet load hour limits are not exceeded			

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 4 of 23)

C2. TDV ENERGY COMPLIANCE RESULTS FOR PERFORMANCE COMPONENTS (Annual TDV Energy Use, kBtu/ft² - yr)			
COMPLIES²			
Energy Component	Standard Design (TDV)	Proposed Design (TDV)	Compliance Margin (TDV)¹
Space Heating	18.37	18.37	0
Space Cooling	47.95	47.95	0
Indoor Fans	19.08	19.08	0
Heat Rejection	0	0	0
Pumps & Misc.	0	0	0
Domestic Hot Water	15.27	15.27	0
Indoor Lighting	57.18	57.18	0
Flexibility	---	---	---
EFFICIENCY COMPLIANCE TOTAL	157.85	157.85	0 (0%)
Photovoltaics	-74.44	-74.44	---
Batteries	-2.1	-2.1	---
TOTAL COMPLIANCE	81.31	81.31	0 (0%)
¹ Notes: This number in parenthesis following the Compliance Margin in column 4, represents the Percent Better than Standard.			

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 5 of 23)

C3. TDV ENERGY RESULTS FOR NON-REGULATED COMPONENTS¹			
Non-Regulated Energy Component	Standard Design (TDV)	Proposed Design (TDV)	Compliance Margin (TDV)¹
Receptacle	72.29	72.29	---
Process	---	---	---
Other Ltg	---	---	---
Process Motors	0.12	0.12	---
TOTAL (TOTAL COMPLIANCE + NON-REGULATED COMPONENTS)	153.72	153.72	0 (0%)
¹ Notes: This table is not used for Energy Code Compliance.			

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 6 of 23)

C4. SOURCE ENERGY COMPLIANCE RESULTS FOR PERFORMANCE COMPONENTS (Annual SOURCE Energy Use, kBtu/ft² /yr)			
COMPLIES²			
Energy Component	Standard Design (SOURCE)	Proposed Design (SOURCE)	Compliance Margin (SOURCE)¹
Space Heating	2.4	2.4	0
Space Cooling	1.88	1.88	0
Indoor Fans	1.5	1.5	0
Heat Rejection	0	0	0
Pumps & Misc.	0	0	0
Domestic Hot Water	1.28	1.28	0
Indoor Lighting	4.81	4.81	0
Flexibility	---	---	---
EFFICIENCY COMPLIANCE TOTAL	11.87	11.87	0 (0%)
Photovoltaics	-2.65	-2.65	---
Batteries	-0.57	-0.57	---
TOTAL COMPLIANCE	8.65	8.65	0 (0%)
¹ Notes: This number in parenthesis following the Compliance Margin in column 4, represents the Percent Better than Standard.			

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 7 of 23)

C5. SOURCE ENERGY RESULTS FOR NON-REGULATED COMPONENTS¹			
Non-Regulated Energy Component	Standard Design (SOURCE)	Proposed Design (SOURCE)	Compliance Margin (SOURCE)¹
Receptacle	5.4	5.4	---
Process	---	---	---
Other Ltg	---	---	---
Process Motors	0.01	0.01	---
TOTAL (TOTAL COMPLIANCE + NON-REGULATED COMPONENTS)	14.06	14.06	0 (0%)
¹ Notes: This table is not used for Energy Code Compliance.			

C6. 'ABOVE CODE' QUALIFICATIONS	
☐ This project is pursuing CalGreen Tier 1	☐ This project is pursuing CalGreen Tier 2

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 8 of 23)

C7. ENERGY USE SUMMARY						
Energy Component	Standard Design Site (MWh)	Proposed Design Site (MWh)	Margin (MWh)	Standard Design Site (MBtu)	Proposed Design Site (MBtu)	Margin (MBtu)
Space Heating	147.6	147.6	0	---	---	---
Space Cooling	273.7	273.7	0	---	---	---
Indoor Fans	166.6	166.6	0	---	---	---
Heat Rejection	---	---	---	---	---	---
Pumps & Misc.	---	---	---	---	---	---
Domestic Hot Water	138.3	138.3	0	---	---	---
Indoor Lighting	510.9	510.9	0	---	---	---
Flexibility	---	---	---	---	---	---
EFFICIENCY TOTAL	1237.1	1237.1	0	0	0	0
Photovoltaics	-915.5	-915.5	0	---	---	---
Batteries	4.4	4.4	0	---	---	---
ENERGY USE SUBTOTAL	326	326	0	0	0	0
Receptacle	683	683	0	---	---	---
Process	---	---	---	---	---	---
Other Ltg	---	---	---	---	---	---
Process Motors	1.1	1.1	0	---	---	---
ENERGY USE TOTAL	1010.1	1010.1	0	0	0	0

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 9 of 23)

C8. ENERGY USE INTENSITY (EUI)				
	Standard Design (kBtu/ft ² / yr)	Proposed Design (kBtu/ft ² / yr)	Margin (kBtu/ft ² / yr)	Margin Percentage
GROSS EUI ¹	27.38	27.38	0	0
NET EUI ¹	14.36	14.36	0	0
¹ Notes: Gross EUI is Energy Use Total (not including PV)/Total Building Area. Net EUI is Energy Use Total (including PV)/Total Building Area.				

D1. EXCEPTIONAL CONDITIONS
The aged solar reflectance and aged thermal emittance must be listed in the Cool Roof Rating Council database of certified products. For projects where initial reflectance is used, the initial reflectance must be listed, and the aged reflectance is calculated by the software program and used in the compliance model.

F1. REQUIRED PV SYSTEMS											
01	02	03	04	05	06	07	08	09	10	11	12
DC System Size (kWdc)	Exception ¹	Module Type	Array Type	Power Electronics	CFI	Azimuth (deg)	Tilt Input	Array Angle (deg)	Tilt: (x in 12)	Inverter Eff. (%)	Annual Solar Access (%)
585.44		Standard (14-17%)	Fixed	none	true	150-270	n/a	n/a	<=7:12	96	98
¹ See Table D1 for any PV exceptions used.											

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 10 of 23)

F1B. PV BATTERY BUILDING TYPE(S)		
01	02	03
Building Occupancy Type* (From Table 140.10-A/B and 170.2-U/V)	Conditioned Floor Area (ft²)	Unconditioned Floor Area (ft²)
Grocery	0	0
High-Rise Multifamily	0	0
Office, Financial Institutions, Unleased Tenant Space	3000	0
Retail	191000	0
School	0	0
Warehouse	46000	0
Auditorium, Convention Center, Hotel/Motel, Library, Medical Office Building/Clinic, Restaurant, Theater	0	0
None	0	0
<i>*Building Occupancy Types are defined in Section 100.1 of the Energy Code</i>		

F2. BATTERY SYSTEMS¹						
01	02	03	04	05	06	07
Control	Capacity (kWh)	Charging Efficiency	Charging Rate (kW)	Discharging Efficiency	Discharging Rate (kW)	Round Trip Efficiency
TOU	639.03	N/A	153.11	N/A	153.11	0.9
¹ See Table D1 for any Battery exceptions used.						

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 11 of 23)

G1. ENVELOPE GENERAL INFORMATION (conditioned spaces only)			
01	02	03	04
Opaque Surfaces & Orientation	Total Gross Surface Area (ft²)	Total Fenestration Area (ft²)	Window to Wall Ratio (%)
North-Facing ¹	15000	0	0
East-Facing ²	10000	420	4.2
South-Facing ³	15000	5040.01	33.6
West-Facing ⁴	10000	420	4.2
Total	50000	5880.02	11.76
Roof	240000	3376	1.41
Notes ¹ North-Facing is oriented to within 45 degrees of true north, including 4500'00" east of north (NE), but excluding 4500'00" west of north (NW), ² East-Facing is oriented to within 45 degrees of true east, including 4500'00" south of east (SE), but excluding 4500'00" north of east (NE), ³ South-Facing is oriented to within 45 degrees of true south, including 4500'00" west of south (SW), but excluding 4500'00" east of south (SE), ⁴ West-Facing is oriented to within 45 degrees of true west, including 4500'00" north of west (NW), but excluding 4500'00" south of west (SW),			

G2A. ROOFING PRODUCT SUMMARY (NONRESIDENTIAL)					
01	02	03	04	05	06
Assembly Name	Roof Pitch	Roof Rise (x in 12)	Aged Solar Reflectance	Thermal Emittance	SRI
Base_CZ12-FlatNonresWoodFramingAndOtherRoofU034	LowSlope	N/A	0.63	0.75	N/A

G4. NONRESIDENTIAL AIR BARRIER	
01	02
Building Story Name	Air Barrier
Building Story 1	Air barrier - not verified

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 12 of 23)

G5. OPAQUE SURFACE ASSEMBLY SUMMARY										
01	02	03	04	05	06		07	08	09	10
Surface Name	Construction Type	Area (ft²)	Framing Type	Cavity R-Value	Continuous R-Value		Units	Value	Description of Assembly Layers	Status ¹
					Interior	Exterior				
Base_CZ12-SlabOnOrBelow GradeF073	Underground Floor	240,000	N/A	0	N/A	N/A	F-factor	0.73	Slab Type =Unheated slab on grade Insulation Orientation =None Insulation R-Value =none	N
Base_CZ12-NonresMetalFrameWallU055	Exterior Wall	50,000	Metal	0	N/A	16.05	U-factor	0.055	Stucco - 7/8 in. Compliance Insulation R14.60 Compliance Insulation R1.41 Compliance Insulation R0.02 Compliance Insulation R0.02 Air - Metal Wall Framing - 16 or 24 in. OC Gypsum Board - 1/2 in.	N
NACM_Interior Wall	Interior Wall	93,000	Metal	0	N/A	N/A	U-factor	0.3195	Gypsum Board - 5/8 in. Air - Metal Wall Framing - 16 or 24 in. OC Gypsum Board - 5/8 in.	N
Base_CZ12-FlatNonresWoodFramingAndOtherRoofU034	Roof	240,000	N/A	0	N/A	28.63	U-factor	0.034	Metal Standing Seam - 1/16 in. Compliance Insulation R28.63	N
¹ Status: N - New, A - Altered, E - Existing										

G6A. OPAQUE DOOR SUMMARY (NONRESIDENTIAL)			
01	02	03	04
Assembly Name	Area (ft ²)	Overall U-factor	Status ¹
Base_AllCZ_NSwnG-ExtDoorU145	880	1.45	N
¹ Status: N - New, A - Altered, E - Existing			

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 13 of 23)

G7A. FENESTRATION ASSEMBLY SUMMARY (NONRESIDENTIAL)								
01	02	03	04	05	06	07	08	09
Fenestration Assembly Name	Fenestration Type/ Product Type / Frame Type	Certification Method ¹	Assembly Method	Area (ft ²)	Overall U-factor	Overall SHGC	Overall VT	Status ²
Base_AllCZ_FixedWindowU34	Vertical fenestration Fixed window N/A	NFRC	Manufactured	5,880.02	0.34	0.22	0.42	N
Base_AllCZ_Skylt-Gl-CurbMntU58	Skylight Fixed window N/A	NFRC	Manufactured	3,376	0.58	0.25	0.49	N
¹ Notes: Newly installed fenestration shall have a certified NFRC Label Certificate or use the CEC default tables found in Table 110.6-A and Table 110.6-B. Center of Glass (COG) values are for the glass-only, determined by the manufacturer, and are shown for ease of verification. Site-built fenestration values are calculated per Nonresidential Appendix NA6 and are used in the analysis. ² Status: N - New, A - Altered, E - Existing								

H1. DRY SYSTEM EQUIPMENT (FURNACES, AIR HANDLING UNITS, HEAT PUMPS, VRF, ECONOMIZERS ETC.)											
01	02	03	04	05	06	07	08	09	10	11	12
Equipment Name	Equipment Type	Qty	Heating				Cooling			Economizer Type (if present)	Status ¹
			Total Heating Output (kBtu/h)	Supp Heat Output (kBtu/h)	Efficiency Unit	Efficiency	Total Cooling Output (kBtu/h)	Efficiency Unit	Efficiency		
Back_Office_SZVAV	Package SZ VAV Heat Pump Air System	1	109.47	78.03	COP	3.4	100.75	EER	11	Fixed DB	N
Back_Shelving/Refrig_SZVAV	Package SZ VAV Heat Pump Air System	8	195.42	173.62	COP	3.3	179.85	EER	10.6	Fixed DB	N
¹ Status: N - New, A - Altered, E - Existing											

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 14 of 23)

H1. DRY SYSTEM EQUIPMENT (FURNACES, AIR HANDLING UNITS, HEAT PUMPS, VRF, ECONOMIZERS ETC.)											
01	02	03	04	05	06	07	08	09	10	11	12
Equipment Name	Equipment Type	Qty	Heating				Cooling			Economizer Type (if present)	Status ¹
			Total Heating Output (kBtu/h)	Supp Heat Output (kBtu/h)	Efficiency Unit	Efficiency	Total Cooling Output (kBtu/h)	Efficiency Unit	Efficiency		
Back_Storage_SZ VAV	Package SZ VAV Heat Pump Air System	4	141.11	125.24	COP	3.4	129.86	EER	11	Fixed DB	N
Main_Entry_SZV AV	Package SZ VAV Heat Pump Air System	2	148.41	159.52	COP	3.3	136.58	EER	10.6	Fixed DB	N
Registers/Aisle_SZVAV	Package SZ VAV Heat Pump Air System	8	255.11	222.33	COP	3.3	234.78	EER	10.6	Fixed DB	N
Side_Entry_1_SZ VAV	Package SZ VAV Heat Pump Air System	2	152.98	158.92	COP	3.3	140.78	EER	10.6	Fixed DB	N
Side_Entry_2_SZ VAV	Package SZ VAV Heat Pump Air System	2	158.58	161.86	COP	3.3	145.94	EER	10.6	Fixed DB	N
Side_Shelving_East_SZVAV	Package SZ VAV Heat Pump Air System	4	252	221.2	COP	3.3	231.91	EER	10.6	Fixed DB	N
Side_Shelving_West_SZVAV	Package SZ VAV Heat Pump Air System	4	250.88	220.73	COP	3.3	230.88	EER	10.6	Fixed DB	N
Side_Storage_1_SZVAV	Package SZ VAV Heat Pump Air System	2	128.81	113.09	COP	3.4	118.54	EER	11	Fixed DB	N
¹ Status: N - New, A - Altered, E - Existing											

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD											NRCC-PRF-E
Nonresidential Performance Compliance Method											(Page 15 of 23)
H1. DRY SYSTEM EQUIPMENT (FURNACES, AIR HANDLING UNITS, HEAT PUMPS, VRF, ECONOMIZERS ETC.)											
01	02	03	04	05	06	07	08	09	10	11	12
Equipment Name	Equipment Type	Qty	Heating				Cooling			Economizer Type (if present)	Status ¹
			Total Heating Output (kBtu/h)	Supp Heat Output (kBtu/h)	Efficiency Unit	Efficiency	Total Cooling Output (kBtu/h)	Efficiency Unit	Efficiency		
Side_Storage_2_ SZVAV	Package SZ VAV Heat Pump Air System	1	144.63	110.85	COP	3.4	133.1	EER	11	Fixed DB	N
¹ Status: N - New, A - Altered, E - Existing											

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 16 of 23)

H3. NONRESIDENTIAL / COMMON USE AREA FAN SYSTEMS SUMMARY												
01	02	03	04	05	06	07	08	09	10	11	12	13
Name or Item Tag	Qty	Design OA CFM	Supply Fan				Return / Relief Fan					Status ¹
			CFM	Power	Power Units	Control	Fan Type	CFM	Power	Power Units	Control	
Back_Office_SZVAV	1	450	3,553.64	0.74	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
Back_Shelving/Refrig_SZVAV	8	1468.75	6,363.94	0.72	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
Back_Storage_SZVAV	4	1057.5	4,580.59	0.74	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
Main_Entry_SZVAV	2	1687.5	4,817.57	0.74	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
Registers/Aisle_SZVAV	8	1828.13	8,307.75	0.72	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
Side_Entry_1_SZVAV	2	1687.5	4,778.42	0.74	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
Side_Entry_2_SZVAV	2	1687.5	4,968.26	0.74	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
Side_Shelving_East_SZVAV	4	1828.13	8,206.22	0.72	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
Side_Shelving_West_SZVAV	4	1828.13	8,169.76	0.72	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
Side_Storage_1_SZVAV	2	960	4,548.64	0.74	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
Side_Storage_2_SZVAV	1	750	4,694.96	0.74	W/cfm	VSD	N/A	N/A	N/A	N/A	N/A	N
Restroom_1_Exhaust	1	0	500	0.2	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
Restroom_2_Exhaust	1	0	500	0.2	W/cfm	Constant Vol	N/A	N/A	N/A	N/A	N/A	N
¹ Status: N - New, A - Altered, E - Existing												

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 17 of 23)

H5. GENERAL EXHAUST FAN SUMMARY							
01	02	03	04	05	06	07	08
System ID	Zone Name	Qty	CFM	Power	Power Units	Continuous Operation?	Status¹
Restroom_1_Exhaust	Restroom_1 Zone	1	500	0.2	WattsPerCFM	No	N
Restroom_2_Exhaust	Restroom_2 Zone	1	500	0.2	WattsPerCFM	No	N
¹ Status: N - New, A - Altered, E - Existing							

H8. SYSTEM SPECIAL FEATURES			
01	02	03	04
System Name	Equipment Type	Interlocks per 140.4(n)¹	Other Special Features and Controls
Back_Office_SZVAV	Package SZ VAV Heat Pump Air System	N/A	Fixed DB
Back_Shelving/Refrig_SZVAV	Package SZ VAV Heat Pump Air System	N/A	Fixed DB
Back_Storage_SZVAV	Package SZ VAV Heat Pump Air System	N/A	Fixed DB
Main_Entry_SZVAV	Package SZ VAV Heat Pump Air System	N/A	Zone(s) With CO2 Sensor Vent. Control Fixed DB
Registers/Aisle_SZVAV	Package SZ VAV Heat Pump Air System	N/A	Fixed DB
Side_Entry_1_SZVAV	Package SZ VAV Heat Pump Air System	N/A	Zone(s) With CO2 Sensor Vent. Control Fixed DB
Side_Entry_2_SZVAV	Package SZ VAV Heat Pump Air System	N/A	Zone(s) With CO2 Sensor Vent. Control Fixed DB
Side_Shelving_East_SZVAV	Package SZ VAV Heat Pump Air System	N/A	Fixed DB
Side_Shelving_West_SZVAV	Package SZ VAV Heat Pump Air System	N/A	Fixed DB
Side_Storage_1_SZVAV	Package SZ VAV Heat Pump Air System	Yes	Fixed DB
Side_Storage_2_SZVAV	Package SZ VAV Heat Pump Air System	Yes	Fixed DB
SHWFluidSysElec	Service Hot Water	N/A	Fixed Temperature Control
Notes: This table includes controls related to the performance path only. For projects using the prescriptive path, mandatory and prescriptive controls requirements are documented on the NRCC-MCH-E.			
¹ Yes = interlocks are provided, No = interlocks are not provided, NA means no operable openings.			

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 18 of 23)

H9. NONRESIDENTIAL / COMMON USE AREA & HOTEL/MOTEL VENTILATION						
01	02	03	04	05	06	07
Zone Name	Mechanical Ventilation				Conditioned Area (sf)	DCV or Occupant Sensor Controls, or Both
	Ventilation Function	# of People	Supply OA CFM	Exhaust CFM		
Back_Office Zone	Office - Office space	15	450	0	3000	N/A
Back_Shelving/Refrig Zone	Retail - Sales	391.75	11750	0	47000	N/A
Back_Storage Zone	Misc - Warehouses	28.2	4230	0	28200	N/A
Main_Entry Zone	Office - Main entry lobbies	225.01	3375	0	6750	DCV
Registers/Aisle Zone	Retail - Sales	487.6	14625	0	58500	N/A
Restroom_1 Zone	Exhaust - Toilets, public	16.88	0	500	3375	N/A
Restroom_2 Zone	Exhaust - Toilets, public	16.88	0	500	3375	N/A
Side_Entry_1 Zone	Office - Main entry lobbies	225.01	3375	0	6750	DCV
Side_Entry_2 Zone	Office - Main entry lobbies	225.01	3375	0	6750	DCV
Side_Shelving_East Zone	Retail - Sales	243.8	7312.5	0	29250	N/A
Side_Shelving_West Zone	Retail - Sales	243.8	7312.5	0	29250	N/A
Side_Storage_1 Zone	Misc - Warehouses	12.8	1920	0	12800	N/A
Side_Storage_2 Zone	Misc - Warehouses	5	750	0	5000	N/A

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 19 of 23)

H11. ZONAL SYSTEM AND TERMINAL UNIT SUMMARY											
01	02	03	04	05	06	07	08	09	10	11	12
System ID	System Type	Qty	Rated Capacity (kBtuh)		Airflow (cfm)			Fan			VSD
			Heating	Cooling	Design	MIn.	Min. Ratio	Power	Power Units	Cycles	
Back_Office_TU	Variable Air Volume No Reheat Box	1	N/A	N/A	3,553.64	1,776.82	0.5	N/A	N/A	N/A	☐
Back_Shelving/Refrig_TU	Variable Air Volume No Reheat Box	8	N/A	N/A	6,363.94	3,181.97	0.5	N/A	N/A	N/A	☐
Back_Storage_TU	Variable Air Volume No Reheat Box	4	N/A	N/A	4,580.59	2,290.29	0.5	N/A	N/A	N/A	☐
Main_Entry_TU	Variable Air Volume No Reheat Box	2	N/A	N/A	4,817.57	2,408.78	0.5	N/A	N/A	N/A	☐
Registers/Aisle_TU	Variable Air Volume No Reheat Box	8	N/A	N/A	8,307.75	4,153.88	0.5	N/A	N/A	N/A	☐
Side_Entry_1_TU	Variable Air Volume No Reheat Box	2	N/A	N/A	4,778.42	2,389.21	0.5	N/A	N/A	N/A	☐
Side_Entry_2_TU	Variable Air Volume No Reheat Box	2	N/A	N/A	4,968.26	2,484.13	0.5	N/A	N/A	N/A	☐
Side_Shelving_East_TU	Variable Air Volume No Reheat Box	4	N/A	N/A	8,206.22	4,103.11	0.5	N/A	N/A	N/A	☐
Side_Shelving_West_TU	Variable Air Volume No Reheat Box	4	N/A	N/A	8,169.76	4,084.88	0.5	N/A	N/A	N/A	☐
Side_Storage_1_TU	Variable Air Volume No Reheat Box	2	N/A	N/A	4,548.64	2,274.32	0.5	N/A	N/A	N/A	☐
Side_Storage_2_TU	Variable Air Volume No Reheat Box	1	N/A	N/A	4,694.96	2,347.48	0.5	N/A	N/A	N/A	☐

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 20 of 23)

I1. WATER HEATER EQUIPMENT SUMMARY													
01	02	03	04	05	06	07	08	09	10	11	12	13	14
Name	Heater Element Type	Tank Type	Qty	Tank Vol (gal)	Rated Input	Rated Input Unit	Efficiency	Efficiency Unit	Tank Insulation R-value Int/Ext	Standby Loss Fraction	1st Hr. Rating or Flow Rate (gal)	Heat Pump Type	Tank Location or Ambient Condition
WaterHeaterElec	Electricity	Storage	1	127.11	37.05	kW	1	TE	N/A	0.01	N/A	N/A	N/A

K1. INDOOR CONDITIONED LIGHTING GENERAL INFO					
01	02	03	04	05	06
Occupancy Type ¹	Conditioned Floor Area ² (ft ²)	Installed Lighting Power (Watts)	Lighting Control Credits (Watts)	Additional (Custom) Allowance	
				Area Category Footnotes (Watts)	Area Category Footnotes (Watts)
Main Entry Lobby	20250	14175	0	0	0
Office (250 square feet)	3000	1800	0	0	0
Retail Merchandise Sales	164000	155800	0	0	0
Restroom	6750	4387.5	0	0	0
Commercial Industrial Warehouse	46000	18400	0	0	0
Building Totals:	240000	194563	0	0	0
¹ See Table 140.6-C ² See NRCC-LTI--E for unconditioned spaces ³ Lighting information for existing spaces modeled is not included in this table					

K4. INDOOR CONDITIONED LIGHTING MANDATORY LIGHTING CONTROL
See NRCC-LTI-E for mandatory controls

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 21 of 23)

L. DECLARATION OF REQUIRED CERTIFICATES OF INSTALLATION	
Selections made by Documentation Author indicate which Certificates of Installation must be submitted for the features to be recognized for compliance. These documents must be retained and provided to the building inspector during construction and can be found online	
Building Component	Form/Title
Envelope	NRCI-ENV-E - Envelope (for all buildings)
Mechanical	NRCI-MCH-E - For all buildings with Mechanical Systems
Plumbing	NRCI-PLB-E - For all buildings with Plumbing Systems
	NRCI-SAB-E - Solar Water Heating, PV and Battery Storage Systems
Indoor Lighting	NRCI-LTI-E - Indoor Lighting (for all buildings)

M. DECLARATION OF REQUIRED CERTIFICATES OF ACCEPTANCE	
Selections made by Documentation Author indicate which Certificates of Acceptance must be submitted for the features to be recognized for compliance. These documents must be provided to the building inspector during construction and must be completed through an Acceptance Test Technician Certification Provider (ATTCP).	
Building Component	Form/Title & System Name(s)
Envelope	NRCA-ENV-02-F - NRFC label verification for fenestration
Indoor Lighting	NRCA-LTI-02-A - Occupancy Sensors and Automatic Time Switch Controls.
Indoor Lighting	NRCA-LTI-03-A - Automatic Daylight Controls.
Indoor Lighting	NRCA-LTI-04-A - Demand Responsive Lighting Controls.
Mechanical	NRCA-MCH-02-A - Outdoor Air must be submitted for all newly installed HVAC units. Note: MCH-02-A can be performed in conjunction with MCH-07-A Supply Fan VFD Acceptance (if applicable) since testing activities overlap
	Back_Office_SZVAV, Back_Shelving/Refrig_SZVAV, Back_Storage_SZVAV, Main_Entry_SZVAV, Registers/Aisle_SZVAV, Side_Entry_1_SZVAV, Side_Entry_2_SZVAV, Side_Shelving_East_SZVAV, Side_Shelving_West_SZVAV, Side_Storage_1_SZVAV and Side_Storage_2_SZVAV.
Mechanical	NRCA-MCH-05-A - Air Economizer Controls
	Back_Office_SZVAV, Back_Shelving/Refrig_SZVAV, Back_Storage_SZVAV, Main_Entry_SZVAV, Registers/Aisle_SZVAV, Side_Entry_1_SZVAV, Side_Entry_2_SZVAV, Side_Shelving_East_SZVAV, Side_Shelving_West_SZVAV, Side_Storage_1_SZVAV and Side_Storage_2_SZVAV.
Mechanical	NRCA-MCH-06-A Demand Control Ventilation Systems must be submitted for all systems required to employ demand controlled ventilation (refer to) can vary outside ventilation flow rates based on maintaining interior carbon dioxide (CO2) concentration setpoints.
	Main_Entry_SZVAV, Side_Entry_1_SZVAV and Side_Entry_2_SZVAV.
Mechanical	NRCA-MCH-07-A Supply Fan Variable Flow Controls
	Back_Office_SZVAV, Back_Shelving/Refrig_SZVAV, Back_Storage_SZVAV, Main_Entry_SZVAV, Registers/Aisle_SZVAV, Side_Entry_1_SZVAV, Side_Entry_2_SZVAV, Side_Shelving_East_SZVAV, Side_Shelving_West_SZVAV, Side_Storage_1_SZVAV and Side_Storage_2_SZVAV.

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 22 of 23)

M. DECLARATION OF REQUIRED CERTIFICATES OF ACCEPTANCE	
Selections made by Documentation Author indicate which Certificates of Acceptance must be submitted for the features to be recognized for compliance. These documents must be provided to the building inspector during construction and must be completed through an Acceptance Test Technician Certification Provider (ATTCP).	
Building Component	Form/Title & System Name(s)
Mechanical	NRCA-MCH-12-A FDD for Packaged Direct Expansion Units
	Back_Office_SZVAV, Back_Shelving/Refrig_SZVAV, Back_Storage_SZVAV, Main_Entry_SZVAV, Registers/Aisle_SZVAV, Side_Entry_1_SZVAV, Side_Entry_2_SZVAV, Side_Shelving_East_SZVAV, Side_Shelving_West_SZVAV, Side_Storage_1_SZVAV and Side_Storage_2_SZVAV.

N. DECLARATION OF REQUIRED CERTIFICATES OF VERIFICATION	
Selections made by Documentation Author indicate which Certificates of Verification must be submitted for the features to be recognized for compliance. These documents must be retained and provided to the building inspector during construction and can be found online	
Building Component	Form/Title
Mechanical	NRCV-MCH-27 Indoor Air Quality & Mechanical Ventilation
Mechanical	NRCV-MCH-32 Local Mechanical Exhaust

CERTIFICATE OF COMPLIANCE - NONRESIDENTIAL PERFORMANCE COMPLIANCE METHOD	NRCC-PRF-E
Nonresidential Performance Compliance Method	(Page 23 of 23)

Documentation Author's Declaration Statement

1. I certify that this Certificate of Compliance documentation is accurate and complete.	
Documentation Author Name:	Documentation Author Signature:
Company:	Signature Date:
Address:	CEA/HERS Certification Identification (if applicable):
City/State/Zip: ,	Phone:

Responsible Person's Declaration statement

I certify the following under penalty of perjury, under the laws of the State of California:		
- The information provided on this Certificate of Compliance is true and correct. - I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer) - The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations. - The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application. - I understand that a registered copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections, and I will take the necessary steps to accomplish this requirement. - I understand that a registered copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy, and I will take the necessary steps to accomplish these requirements.		
Responsible Designer Name:	Responsible Designer Signature:	
Company:		
Address:	Date Signed:	
City/State/Zip: ,	License #:	
Phone:	Title:	Scope: