



## Report on:

**ERCOT** PNNL Contract 401882: *Start Date 3/19/2018*

## Development of an Integrated Transmission and Distribution Test System to Evaluate Transactive Energy Systems

### ISU Project Team:

PI Leigh Tesfatsion & Co-PI Zhaoyu Wang

Grad Research Assistant: Swathi Battula

PNNL/ISU Web Conference, 08 February 2019

# ERCOT Contract: Presentation Outline

- ❑ **Original Task/Milestone Schedule: M1-M3**
- ❑ **Updated Task/Milestone Schedule: M1-M3**
- ❑ **M3.2 Work to Date:** Summary of AMES V5.0 Work to Date for Milestone M3.2
- ❑ **M3.2 Work in Progress:** Summary of AMES V5.0 Work in Progress for Milestone M3.2
- ❑ **M3.2: Report on AMES V5.0 Verification Test Cases**
  - Notes on AMES V5.0 Verification Test-Case Data Files
  - AMES – PSST : Sequence of Events
  - Summary of Previous AMES V5.0 Verification Test Cases
  - Summary of Previous and Ongoing AMES V5.0 Verification Test Cases
  - Total Production Cost Modeling in AMES V5.0 for SCUC/SECD operations
  - Brief Summary of Planned Future AMES V5.0 Verification Test Cases

# Original Task & Milestone Schedule

---

Milestone	Date Due	Original Description
M1	May 31, 2018	5-zone model of the old ERCOT system, posted to a web repository.
M2	Sep 30, 2018	Nodal model of the new ERCOT system, posted to a web repository.
M3	Sep 30, 2018	Submitted conference or journal paper on this work.

# Updated Task & Milestone Schedule

Milestone	Date Due	Date Delivered	Fuller Descriptions of Actual Work
M1* DONE	May 31, 2018	June 5, 2018	Development of 8-Bus ERCOT model (with nodal locational marginal pricing); grid/load/gen data posted at PNNL repository
M2.1 DONE	Sept 30, 2018	August 1, 2018	Basic 8-Bus ERCOT Test System, implemented via AMES V3.1, posted at <a href="https://github.com/ITDProject/ERCOTTestSystem">https://github.com/ITDProject/ERCOTTestSystem</a>
M2.2 DONE	Sept 30, 2018	August 24, 2018	8-Bus ERCOT Test System (with wind power), implemented via AMES V3.2, posted at <a href="https://github.com/ITDProject/ERCOTTestSystem">https://github.com/ITDProject/ERCOTTestSystem</a>
M3.1 DONE	Sept 30, 2018	August 31, 2018	200-Bus ERCOT Test System (with wind power), implemented via AMES V3.2, posted at <a href="https://github.com/ITDProject/ERCOTTestSystem/tree/master/ERCOT_Test_Systems/The_200Bus_ERCOT_Test_System">https://github.com/ITDProject/ERCOTTestSystem/tree/master/ERCOT_Test_Systems/The_200Bus_ERCOT_Test_System</a>
M3.2**	Feb 28, 2019		200-Bus ERCOT Test System (with wind power), implemented via AMES V5.0, to be posted at PNNL/ISU repositories.
M3.3**	Feb 28, 2019		Paper to be submitted that focuses on the development of the ERCOT Test Systems

- \* **M1 Modification (Ok'd by PNNL):** For M1 we have skipped the modeling of the old (zonal) ERCOT system and instead directly worked to develop an 8-bus model of the new (nodal) ERCOT system.
- \*\* **M3 Modification:** Contract extension through Feb 28, 2019 received from PNNL on Dec 21, 2018, for completion of task M3

# Summary of AMES V5.0 Work to Date for M3.2

---

## ❑ Extension of AMES V5.0 Capabilities for Milestone M3.2

- [DONE] Coding for Daily DAM SCUC optimization
- [DONE] Coding for RTM SCED optimization every M minutes (M user specified).
- [DONE] Coding for FNCS integration to enable network co-simulation.
- [DONE] Detailed documentation for analytical DAM SCUC/SCED optimization in AMES V5.0
- [DONE] Basic documentation for AMES V5.0, including a detailed list for all parameters/flags and initial state variables that need user configuration.

# Summary of AMES V5.0 Work to Date for M3.2 ... Continued

## ■ [ DONE ]

### — Modified 'PSST' Code

- To ensure correct refreshing of initial DAM/RTM conditions for multiple-day runs.
- To report DAM LMPs and GenCo Commitments back to the user.
- To read 'startup' and 'shutdown' cost components from AMES
- To produce output messages related to solver, e.g. status of the solver, termination condition of the solver
- To include the parameter 'Maximum Time Limit' – to allow the solver to terminate after the prescribed time has elapsed

### — Verification Tests Done

- Verified 'DAM SCUC' outcomes for their correctness for simple test cases
- Verified 'RTM SCED' outcomes for their correctness for simple test cases with RTM running every five minutes (i.e.,  $M=5$ )
- Verified that AMES V5.0 runs for multiple days
- Verified that all the cost components from AMES are read correctly into the SCUC formulation

# Summary of Work in Progress for Milestone M3.2

---

- **[IN PROGRESS] Additional Verification Checks for AMES V5.0 Code**
  - Additional DAM/RTM verification test cases are being formulated and conducted.
    - *Example:* Formulation of test cases with varied generator production cost coefficients and minimum generating capacity that permit validation of production cost component modeling for the SCUC optimization
  - Need to ensure outcomes are reported properly back to the user. Additional data that need to be written to '.out' file are: RTM LMPs, RTM GenCo commitment data, DAM/RTM power flow data, LMP true costs, and generator profit/propensity data.
  - Detailed verification of PSST code for validating SCUC optimization formulation, including both objective function and constraints.
- **[IN PROGRESS] Further Cleaning Up of AMES V5.0 Code**
  - Current code includes unused functions that need to be removed.

# **Report on AMES V5.0 Verification Test Cases**



# Notes on AMES V5.0 Test-Case Data Files

- Input data files for verification test cases are located in the following GitHub website directory: AMES-V5.0\DATA\VerificationTestCases\
  - Intermediary output files:
    - Data files written by AMES V5.0
      - ✓ ReferenceModel.dat : This is an input file for PSST that contains input data required to solve SCUC.
      - ✓ RTReferenceModel.dat : This is an input file for PSST that contains input data required to solve SCUC.
      - ✓ rt-unitcommitments.dat: : This is an input file for PSST that contains the unit commitment status of each generator for each M-minute period.
    - SCUC output data files generated by PSST for Day-Ahead Market (DAM)
      - ✓ xfertoames.dat : Contains DAM unit commitment status and dispatch schedule for each generator along with generator ID.
      - ✓ DAMLMP.dat : Contains DAM LMP at each bus for each hour of a 24-hour period
    - SCED output data files generated by PSST for the Real-Time Market (RTM)
      - ✓ RTSCED.dat : Contains RTM LMP at each bus for each M-minute period, power dispatch scheduled for each generator for the next M-minute period, and start-up and shut-down cost details for each minute of each M-minute period.

# AMES – PSST : Sequence of Events

**Step 0:** Initialize  $D = 0$ ,  $H = 0$ ,  $I = 0$ ;

**Step 1:** AMES starts DAM operation on day 'D' for day 'D+1'.

**Step 2:** AMES writes 'ReferenceModel.dat' file and makes an external call to PSST to solve SCUC.

**Step 3:** PSST reads the input file 'ReferenceModel.dat' and performs SCUC.

**Step 4:** PSST writes SCUC outcomes into 'DAMLMP.dat' and 'xfertoames.dat' files.

**Step 5:** AMES reads 'DAMLMP.dat' and 'xfertoames.dat' and updates its DAM outcomes.

**Step 6:** AMES starts RTM operations for interval 'I' (duration of each interval = 'M' min).

**Step 7:** AMES writes 'rt-unitcommitments.dat' (contains generator unit commitments of day 'D' and 'RTReferenceModel.dat' and makes an external call to PSST to solve SCED.

**Step 8:** PSST reads the input files 'rt-unitcommitments.dat', 'RTReferenceModel.dat' and performs SCED.

# AMES – PSST : Sequence of Events ... Continued

**Step 9:** PSST writes SCED outcomes into 'RTSCED.dat'.

**Step 10:** AMES reads 'RTSCED.dat' and updates RTM outcomes.

**Step 11:** Increment I;

```
    If (I*M % 60 == 0) {
```

```
        H++;
```

```
    }
```

```
    If (H% 24 == 0) {
```

```
        increment D;
```

```
        goto Step 0;
```

```
    }
```

```
Else goto Step 6.
```

# Summary of Previous AMES V5.0 Verification Test Cases

## ❑ VerTestCaseBaseCase

- This test case produces SCUC/SCED outcomes under the following conditions:
  - ✓ Transmission congestion is absent
  - ✓ Minimum power generation limits are taken to be zero
  - ✓ Start up, shut down and no-load costs are taken to be zero
  - ✓ Minimum up-time and down-time values are taken to be 0 (hr)
  - ✓ No ramping limits
  - ✓ Day-ahead and real-time load forecasts are set equal
- This test case provides a base case for later comparison purposes.

## ❑ VerTestCaseGenMinPowerLevel

- This test case verifies a generator's minimum power level is maintained when it is committed, given the above-stated conditions (i) and (iii)-(vi).

## ❑ VerTestCaseUpTimeDownTime

- This test case verifies a generator's minimum up time and down time are maintained when it is committed, given the above-stated conditions (i) and (iii)-(vi).

## ❑ VerTestCaseMultiDayRun

- This test case verifies DAM/RTM initial conditions are refreshed appropriately when AMES V5.0 is run for multiple successive days.

Note: Files for the above test cases are uploaded at <https://github.com/ITDProject/ERCOTTestSystem/tree/dev-source-code/AMES-V5.0/DATA/VerificationTestCases>

# Summary of Previous and Ongoing AMES V5.0 Verification Test Cases

## ■ VerTestCaseCostComponents

The purpose of this test case is to verify cost component aspects of the SCUC formulation under the above-stated conditions (i)-(ii) and (iv)-(vi) – i.e., to verify that the SCUC formulation correctly includes no load, start-up, dispatch, and shut-down cost components.

### ✓ Completed

#### ■ VerTestCaseCostComponentsNoLoad

This test case verifies that no load cost is appropriately taken into account in SCUC/SCED formulation given the above-stated conditions (i), (ii) and (iv)-(vi).

### ✓ To be completed

#### ■ VerTestCaseCostComponentsStartUP

#### ■ VerTestCaseCostComponentsShutDown

# Total Production Cost Modeling in AMES V5.0 for SCUC/SCED Operations

1. For any given generator  $j$ , the user specifies a convex total production cost function

$$\text{TPC}(p) = a + bp + cp^2, \\ p \in [\underline{P}, \bar{P}], \text{ applicable for each operating period } k \text{ (e.g., hourly)}$$

2. User then sets the number  $NL$  of power blocks, and either
  - i. specifies the length of each of the  $NL$  power blocks, starting at  $\underline{P}$  and ending at  $\bar{P}$ , OR
  - ii. chooses "Automated Approximation Option" in which the power output range  $[\underline{P}, \bar{P}]$  is simply divided into  $NL$  equal-length blocks.

3. A piecewise-linear approximation for  $\text{TPC}(p)$  is then constructed, as shown in Fig. 1.




Fig 1. Linearized approximation for the total production cost function  $\text{TPC}(p)$  of a generator  $j$ , used for each operating period  $k$  (e.g., each hour).

**NOTE:** For a detailed explanation of construction 1.-3., please refer to Section 5 of “Analytical Formulation and Python Implementation for an Extended Carrion/Arroyo SCUC/SCED Optimization Formulation” at <http://www2.econ.iastate.edu/tesfatsi/ECAModelAndPyomoCodeDoc.LTesfatsion.pdf>

# Brief Summary of Planned Future AMES V5.0 Verification Test Cases

---

- **VerTestCaseRampUpRampDown**

The purpose of this test case is to verify that ramping constraints are correctly modeled in the SCUC/SCED formulation.

- **VerTestCaseNonDispatchableGeneration**

The purpose of this test case is to verify if non-dispatchable generation is correctly taken into account in the SCUC/SCED formulation.