

46770 Integrated energy grids

Marta Victoria

Lecture 3 – Networks



Recap from previous lectures



Balancing renewable generation

We ended last lecture, stating that we need optimization to decide how to combine different flexibility options.

- 1. Back-up generation and curtailment
- 2. Storage
- 3. Regional integration of renewables
- 4. Demand-side management
- 5. Sector-coupling

Temporal and spatial balancing (together with demand-side management and sector-coupling) must be simultaneously considered -> **This requires optimization!**



General formulation of optimization problems (I)

$$\min_{x} f(x)$$

Objective function

subject to

$$h_i(x) = c_i \leftrightarrow \lambda_i$$


$$g_i(x) \ge d_i \leftrightarrow \mu_i$$


 $h_i(x) = c_i \leftrightarrow \lambda_i$ Equality and $g_i(x) \ge d_i \leftrightarrow \mu_i$ inequality constraints

 λ_i and μ_i are the Lagrange or Karush-Kuhn-Tucker (KKT) multipliers

x, y, z are called primary variables and λ_i , μ_i are called dual variables

A constraint can be binding (affecting the optimal solution x^*) or not-binding







Economic dispatch or one-node dispatch optimization (I)

Assume we have a set of generators *s* (e.g., onshore wind, solar PV, gas power plant...) each of them has an installed capacity G_s and a linear variable cost O_s . The economic dispatch consists in calculating the optimal dispatch (how much energy is being produced by each generator g_s) to supply the demand d in a certain hour while minimizing the total system cost.

subject to:

$$\sum_{S} g_{S} - d = 0 \iff \lambda$$

$$g_{S} \ge 0 \iff \underline{\mu_{S}}$$

$$-g_{S} + G_{S} \ge 0 \iff \overline{\mu_{S}}$$

$$g_{s} \ge 0 \leftrightarrow \underline{\mu_{s}}$$

$$-g_{s} + G_{s} \ge 0 \leftrightarrow \overline{\mu_{s}}$$

For renewable generators, the installed capacity is multiplied by the capacity factor: $-g_s + CF_sG_s \leq 0 \leftrightarrow \overline{\mu_s}$



Types of optimization problems and course structure

	One node	Network				
One time	Economic dispatch or One-node dispatch optimization (Lecture 2)	Power		Coo flow	Lloot flow	
step		Linearized AC power flow (Lecture 4)	AC power flow (Lecture 5)	Gas flow (Lecture 6)	Heat flow (Lecture 7)	
Multiple time steps	Multi-period optimization Join capacity and dispatch optimization in one node (Lecture 8)	Join capacity and dispatch optimization in a network (Lecture 10)				






Learning goals for this lecture

- Describe the Degree, Adjacency, and Laplacian (or bus susceptance) matrix.
- Describe the Incidence and Cycle matrix.
- Obtain the Laplacian (or bus susceptance) matrix describing the topology of a network.
- Calculate the current flows in a DC network by calculating the voltages using the inverse of the weighted Laplacian matrix
- Calculate the current flows in a DC network by using the Power Transfer Distribution Factors (PTDF) matrix





A network is a catalogue of a system's components often called nodes (**N**) or vertices and the direct interactions between them, called links (**L**) or edges.





In power systems, nodes (**N**) are called buses and links (**L**) are called lines.







Ref: ENTSOE map




Undirected Network: A network whose links do not have a defined direction. E.g. actor network, power grid ...




Directed Network: A network whose links have selected directions. E.g. WWW, citation network...



Weighted Network: A network whose links have a defined weight, strength or flow parameter, E.g. power grid, gas networks ...



Radial Network: A network that was no cycles



Ref: Network Science, Albert-Lazslo Barabási



The degree k indicates the number of links that a node has to other nodes.

The average degree $\langle k \rangle$ gives an indication of how meshed is a network.

NETWORK	NODES	LINKS	DIRECTED UNDIRECTED	N	L	<k></k>
Internet	Routers	Internet connections	Undirected	192,244	609,066	6.34
WWW	Webpages	Links	Directed	325,729	1,497,134	4.60
Power Grid	Power plants, transformers	Cables	Undirected	4,941	6,594	2.67
Mobile Phone Calls	Subscribers	Calls	Directed	36,595	91,826	2.51
Email	Email addresses	Emails	Directed	57,194	103,731	1.81
Science Collaboration	Scientists	Co-authorship	Undirected	23,133	93,439	8.08
Actor Network	Actors	Co-acting	Undirected	702,388	29,397,908	83.71
Citation Network	Paper	Citations	Directed	449,673	4,689,479	10.43
E. Coli Metabolism	Metabolites	Chemical reactions	Directed	1,039	5,802	5.58
Protein Interactions	Proteins	Binding interactions	Undirected	2,018	2,930	2.90

Ref: Network Science, Albert-Lazslo Barabási



Overview of relevant equations to model energy networks

Regardless of the type of network (power, gas, heat) we need:

- Equations that represent the balance of energy (or mass) in every node -> Nodal balance equations
- Equations that represent the transport of energy in every link -> Link equations
 (these will depend on the physical applicable laws when transporting power, gas, heat)
- Information on how the nodes are connected by links -> Matrices to capture the network topology
 (we need a "map" of the network)



Notation in this course

- Nodes: *i*, *j*, *k*
- Links, Lines: $l, i \rightarrow j$ (line transporting power from node i to node j)
- Matrix X_{ij} with i rows and j columns
- Complex number \bar{S}
- To simplify notation, index are not always declared

For example, when we write $-g_{n,s,t} + G_{s,n} \ge 0$


We implicitly mean $-g_{n,s,t} + G_{s,n} \ge 0$ $\forall n,s,t$ where n,s,t are technologies, nodes and timesteps



Degree matrix

We are going to define five matrices which are very useful in energy networks: **Degree**, Adjacency, Laplacian, Incidence and Cycles matrix.

Degree matrix
$$D_{ij} = \begin{cases} k_i = \sum_{j=1}^n A_{ij} & if \ i = j \\ 0 & if \ i \neq j \end{cases}$$
 number of links attached to node i






Adjacency matrix

We are going to define five matrices which are very useful in energy networks: Degree, Adjacency, Laplacian, Incidence and Cycles matrix.

Adjacency matrix
$$A_{ij} = \begin{cases} 1 & \text{if link between node } i \text{ and } j \text{ exists} \\ 0 & \text{if link between node } i \text{ and } j \text{ does not exist} \end{cases}$$






Laplacian matrix

We are going to define 5 matrices which are very useful in energy networks: Degree, Adjacency, Laplacian, Incidence and Cycles matrix.

Laplacian matrix $L_{ij} = D_{ij} - A_{ij}$



$$L_{ij} = \begin{pmatrix} 2 & -1 & -1 \\ -1 & 2 & -1 \\ -1 & -1 & 2 \end{pmatrix} = \begin{bmatrix} \begin{pmatrix} 2 & 0 & 0 \\ 0 & 2 & 0 \\ 0 & 0 & 2 \end{pmatrix} - \begin{pmatrix} 0 & 1 & 1 \\ 1 & 0 & 1 \\ 1 & 1 & 0 \end{pmatrix} \end{bmatrix}$$

The columns (and rows) of the Laplacian matrix sum to zero $\sum_{i} L_{ij} = 0$

The Laplacian matrix is a "map" of the network, it contains information on how the nodes are connected.

If the links have different strength, we can add this information in the off-diagonal elements and we get the weighted Laplacian matrix.

In AC power flows, the weighted Laplacian matrix is also called Bus Susceptance matrix.



Laplacian matrix (II)

Why we call it Laplacian matrix?

In mathematics, the Laplacian operator indicates the divergence of the gradient, it is given by the sum of second partial derivatives of the function with respect to each independent variable

$$\Delta f = \nabla^2 f = \varphi \qquad \left(\frac{\partial^2}{\partial x^2} + \frac{\partial^2}{\partial y^2} + \frac{\partial^2}{\partial x^2}\right) f(x, y, z) = \varphi(x, y, z)$$

If we approach the first and second partial derivatives

$$\frac{\partial}{\partial x} \sim \frac{f_i - f_{i-1}}{\Delta x}$$

$$\frac{\partial^{2}}{\partial x^{2}} \sim \frac{\frac{\partial}{\partial x}\Big|_{i+1/2} - \frac{\partial}{\partial x}\Big|_{i-1/2}}{\Delta x} = \frac{f_{i+1} - f_{i}}{\Delta x} - \frac{f_{i} - f_{i-1}}{\Delta x}}{\Delta x} = \frac{f_{i+1} - 2f_{i} + f_{i-1}}{\Delta x^{2}}$$

$$L_{ij} = \begin{pmatrix} 2 & -1 & -1 \\ -1 & 2 & -1 \\ -1 & -1 & 2 \end{pmatrix}$$

The rows in the Laplacian matrix resembles the Laplacian operator




Incidence matrix

We are going to define 5 matrices which are very useful in energy networks: Degree, Adjacency, Laplacian, Incidence and Cycles matrix.

Incidence matrix
$$K_{il} = \begin{cases} 1 & \text{if link } l \text{ starts at node } i \\ -1 & \text{if link } l \text{ ends at node } i \end{cases}$$

$$0 & \text{otherwise}$$



links: 1 2 3 nodes
$$K_{il} = \begin{pmatrix} 1 & 1 & 0 \\ -1 & 0 & 1 \\ 0 & -1 & -1 \end{pmatrix} \begin{array}{cccc} 1 & 2 & 3 & 1 \\ 2 & 3 & 1 & 2 \\ 3 & 3 & 3 & 3 \end{array}$$

The Laplacian and the Incidence matrix are related by: $L = KK^T$

The Incidence matrix contains information on the links connected to each node and allows us to impose energy conservation or nodal energy balances $I_i = \sum_l K_{il} I_l$


The transpose of the Incidence matrix allows us to express the current flowing through a link as a function of the voltage difference between the nodes $I_l = \sum_j K_{lj} V_j$



Example: Current flows in a 3-node DC network



Energy Networks. Stating the problem (I)



In every node i, mismatch (i.e., renewable generation g_i^R minus demand d_i), is equal to local balance b_i plus injection p_i :

$$\Delta_i = g_i^R - d_i = b_i + p_i$$

The total sum of energy injection is zero (energy conservation):


$$\sum_{i} p_i = p_1 + p_2 + p_3 = 0$$

The goal of power flow analysis is to find the power flows through the links of a network given the injection pattern for the nodes.

More generally, in energy networks, we want to calculate the flows of energy (electricity, gas, heat) given the injection patterns in the nodes



Energy Networks. Stating the problem (I)



In this lecture, we focus on a simplified version using DC circuits.

How can we find the current flows in the links of a network given the current injection pattern?

Data: I_1, I_2, I_3

Unknown: $I_{1\rightarrow 2}$, $I_{1\rightarrow 3}$, $I_{2\rightarrow 3}$

We follow the convention that positive current is leaving a node.

The total sum of current injection is zero (energy conservation):

$$\sum_{i} I_i = I_1 + I_2 + I_3 = 0$$

We can use the incidence matrix to impose nodal energy balances $I_i = \sum_l K_{il} I_l$

However, to calculate the current flows, we need additional equations otherwise there are many possible solutions (e.g. consider $I_1 = 1$, $I_2 = -1$, $I_3 = 0$)


How do current flow in DC circuits?


23



DC circuits and Ohm's law

The electric current through a conductor between two points is directly proportional to the voltage difference between the two points





$$I_{1\to 2} = \frac{V_1 - V_2}{R_{12}}$$


Notice here that the current flowing trough a link depends on the voltage difference, so we can always find an equivalent solution adding a constant to every voltage. We will have to choose a slack or reference node for which V = 0.

For simplicity, in the following example, we assume $R_{12}=1$ and hence $I_{1\rightarrow 2}=V_1-V_2$



Example: Current flows in a 3-node network

Problem: Calculate the current flows $I_{i\to j}$ in the links of a network given the current injection pattern for the nodes I_i



$$I_{1} = I_{1 \to 2} + I_{1 \to 3} = (V_{1} - V_{2}) + (V_{1} - V_{3}) = 2V_{1} - V_{2} - V_{3}$$

$$I_{2} = I_{2 \to 1} + I_{2 \to 3} = (V_{2} - V_{1}) + (V_{2} - V_{3}) = -V_{1} + 2V_{2} - V_{3}$$

$$I_{3} = I_{3 \to 1} + I_{3 \to 2} = (V_{3} - V_{1}) + (V_{3} - V_{2}) = -V_{1} - V_{2} + 2V_{3}$$

$$\binom{I_{1}}{I_{2}} = \binom{2}{I_{1}} - \binom{1}{I_{2}} - \binom{1}{I_{1}} - \binom{1}{I_{2}} - \binom{1}{I_{2$$

The Laplacian matrix relates the current injection I_i and voltages V_j in every node $I_i = \sum_j L_{ij} V_j$


To obtain the currents $I_{i\rightarrow j}$ flowing through the links :

- 1°. Calculate the voltages V_i
- 2°. Calculate the flows $I_{i\rightarrow j}$ using the voltages V_j



Example: Current flows in a 3-node network

Problem: Calculate the current flows $I_{i\rightarrow j}$ in the links of a network given the current injection pattern for the nodes I_i



$$I_1 = I_{1\to 2} + I_{1\to 3} = (V_1 - V_2) + (V_1 - V_3) = 2V_1 - V_2 - V_3$$

$$I_2 = I_{2\to 1} + I_{2\to 3} = (V_2 - V_1) + (V_2 - V_3) = -V_1 + 2V_2 - V_3$$

$$I_3 = I_{3\to 1} + I_{3\to 2} = (V_3 - V_1) + (V_3 - V_2) = -V_1 - V_2 + 2V_3$$

There are only two independent variables because $I_1 + I_2 + I_3 = 0$

We select $V_3 = 0$

1°. Calculate the voltages

$$I_{1} = 2V_{1} - V_{2}$$

$$I_{2} = -V_{1} + 2V_{2}$$

$$V_{1} = \frac{2}{3}I_{1} + \frac{1}{3}I_{2}$$

$$V_{2} = \frac{1}{3}I_{1} + \frac{2}{3}I_{2}$$

$$V_{3} = 0$$

$$I_{1 \to 2} = (V_{1} - V_{2})$$

$$I_{1 \to 3} = (V_{1} - V_{3})$$

$$I_{2 \to 3} = (V_{2} - V_{3})$$

We can also express the result as a matrix that relates the current flows to the current injection

2º. Calculate the current flows using the voltages

$$I_{1\to 2} = (V_1 - V_2)$$

$$I_{1\to 3} = (V_1 - V_3)$$

$$I_{2\to 3} = (V_2 - V_3)$$

$$\begin{pmatrix} I_{1\to 2} \\ I_{1\to 3} \\ I_{2\to 3} \end{pmatrix} = \begin{pmatrix} 1/3 & -1/3 & 0 \\ 2/3 & 1/3 & 0 \\ 1/3 & 2/3 & 0 \end{pmatrix} \begin{pmatrix} I_1 \\ I_2 \\ I_3 \end{pmatrix}$$




General formulation: Calculating currents flows knowing current injections



Calculating the current flows in a network

The Laplacian matrix relates the injected currents I_i and voltages V_j in every node $I_i = \sum_j L_{ij} V_j$



To obtain the currents $I_{i\rightarrow j}$ flowing through the links, we follow two steps:

- 1°. Calculate the voltages V_j using the inverse of the Laplacian matrix $V_j = \sum_i (L^{-1})_{ji} I_i$
- 2°. Calculate the current flows $I_l = I_{i \to j}$ using the voltages and the transpose incidence matrix $I_l = \sum_j K_{lj} V_j$



Inverting the Laplacian matrix

There is a small caveat: the **Laplacian matrix is not invertible**.

because it is singular (its determinant is zero).

This is related to the fact that the currents flows depend on the voltage differences, so we can always find an equivalent solution adding a constant to every voltage.


To invert it, we delete the row and column corresponding to the slack bus (in the previous example $V_3 = 0$), so that we obtain a matrix with dimension $(i - 1) \cdot (j - 1)$ that can be inverted

Alternatively, we can use the Moore-Penrose pseudo-inverse



Weighted Laplacian matrix

If we assume now that the resistance is different for every link.



The current flowing through every link $I_{i\rightarrow j}=I_l$ depends on the voltage difference across the nodes connected by the link

$$I_{i \to j} = I_l = \frac{V_l}{R_l} = \frac{1}{R_l} \sum_{j} K_{lj} V_j$$

And the current injected in every node I_i is equal to the sum of the current exported through the links

$$I_{l} = \sum_{l} K_{il} I_{l} = \sum_{l} K_{il} \frac{1}{R_{l}} \sum_{j} K_{lj} V_{j}$$


$$L = KBK^{T} \qquad B_{ll} = \frac{1}{R_{l}} \quad \text{is the diagonal matrix of inverse of every link resistance}$$

The weighted Laplacian matrix relates the injected currents I_i and voltages V_j in every node. In AC power flows, the weighted Laplacian matrix is also called Bus Susceptance matrix.



Calculating the current flows in a weighted network

The weighted Laplacian matrix relates the injected currents I_i and voltages V_j in every node $I_i = \sum_j L_{ij} V_j$



To obtain the currents $I_{i\rightarrow j}$ flowing through the links, we follow two steps:


1°. Calculate the voltages V_j using the inverse of the weighted Laplacian matrix $V_j = \sum_i (L^{-1})_{ji} I_i$

2°. Calculate the current flows $I_l = I_{l \to j}$ using the voltages and the transposed incidence matrix $I_l = \frac{1}{R_l} \sum_j K_{lj} V_j$



Power Transfer Distribution Factors (PTDF) matrix

An alternative method consists in using the Power Transfer Distribution Factors (PTDF) matrix



$$I_{l} = \frac{1}{R_{l}} \sum_{j} K_{lj} V_{j} = \frac{1}{R_{l}} \sum_{ji} K_{lj} (L^{-1})_{ji} I_{i} = \sum_{i} PTDF_{li} I_{i}$$

The PTDF is calculated as the transpose incidence matrix times the inverse Laplacian matrix


The PTDF matrix measures the sensitivity of current flows in each link relative to incremental changes in nodal current injections throughout the network.

We calculated the PTDF matrix at the end of the 3-node example (slide 26)



Power Transfer Distribution Factors (PTDF) matrix

The PTDF matrix measures the sensitivity of current flows in each link relative to incremental changes in nodal current injections throughout the network.



For a unitary current being transferred from node i to the slack node (3), each element column i indicates the resulting current flows in the links



Alternative formulation using the cycles matrix



Cycle matrix

The cycle matrix contains the closed cycles.


$$C_{Ic} = \frac{1}{2}$$

- if link *l* belongs de cycle *c*
- $C_{lc} = \begin{cases} -1 & \text{if reverse link } l \text{ belongs to cycle } c \end{cases}$

The combination of links representing a closed cycle multiplied by incidence matrix is zero: KC = 0

$$\begin{pmatrix} 1 & 0 & 0 & 0 & -1 \\ -1 & 1 & 1 & 0 & 0 \\ 0 & -1 & 0 & 1 & 1 \\ 0 & 0 & -1 & -1 & 0 \end{pmatrix} \begin{pmatrix} 1 \\ 1 \\ 0 \\ 0 \\ 1 \end{pmatrix} = 0$$

$$\begin{pmatrix} 1 & 0 & 0 & 0 & -1 \\ -1 & 1 & 1 & 0 & 0 \\ 0 & -1 & 0 & 1 & 1 \\ 0 & 0 & -1 & -1 & 0 \end{pmatrix} \begin{pmatrix} 0 \\ 1 \\ -1 \\ 1 \\ 0 \end{pmatrix} = 0$$



cycles:
$$a$$
 b links $C_{lc} = \begin{pmatrix} 1 & 0 \\ 1 & 1 \\ 0 & -1 \\ 0 & 1 \\ 1 & 0 \end{pmatrix} = \begin{pmatrix} 1 & 2 & 3 \\ 4 & 5 & 5 \end{pmatrix}$



Physical laws of current and voltage in DC circuits

Currents flowing through a circuit depends on the circuit configuration


We use Kirchhoff's laws to determine currents in a circuit:


Kirchhoff's Currents Law

The algebraic sum of currents in a network of conductors meeting at a point is zero.

Kirchhoff's Voltage Law

The directed sum of the voltages around any closed loop is zero.







Kirchhoff's laws

Alternatively, we can solve the problem of calculating the current flows (given the current injection patterns), by imposing both Kirchhoff's laws

Kirchhoff's Currents Law can be imposed using the incidence matrix


$$I_i = \sum_{l} K_{il} I_l \qquad \forall i$$

Here, I_i is the current that node i wants to inject, while I_1 is the current flowing throughout link *l*

Kirchhoff's Voltage Law can be imposed using the cycle matrix

$$\sum_{l} C_{lc} V_{l} = 0$$

 $\forall c$



This method is computationally very efficient for large networks*.

Kirchhoff's voltage law is equivalent to the equations imposing Ohm's law that we have used before.

$$I_{1\to 2} = \frac{V_1 - V_2}{R_{12}} \qquad I_l = \frac{1}{R_l} \sum_j K_{lj} V_j$$

*See Hörsch et al, 2018. Linear optimal power flow using cycle flows



Problems for this lecture

Problems 3.1, 3.2 (**Group 6**)

Review tutorial on networkx

https://martavp.github.io/integrated-energy-grids/intro-networkx.html

Problems 3.3, 3.4 (**Group 7**)

#