AI SITE HISTORY REPORT

AI Scan v1.1

502 Church Road, Taigum QLD

Generated 09 Apr 2026 | Lot size: 11,925 m² | Confidence: High

Preliminary AI Screening Notice

This report is generated using automated interpretation of available aerial imagery and is intended for preliminary site screening purposes only.

While reasonable effort has been made to identify visible indicators such as ponds, historical water features, and site disturbance, not all features may be detected or accurately interpreted.

Users are strongly encouraged to independently review historical imagery (e.g. Google Earth) and obtain a detailed geotechnical investigation in accordance with AS2870 prior to design, construction, or purchase decisions.

Executive Summary

No current on-site water bodies are clearly visible; however, historical imagery indicates former ponds or infilled wet depressions on-site. Site disturbance or possible fill-related ground modification is also visible.

Assessment Boundary

Current north-up image showing the drawn lot assessment boundary used for this screening.

Key Site Risks

Former Water Features	**High**
Historical imagery indicates former pond or altered wet depression signatures on-site.	
Fill / Disturbance	**Elevated**
Recent on-site disturbance and possible fill-related ground modification are visible.	

Recommendation

Historical imagery indicates former or possible former pond / wet depression signatures on-site. Detailed geotechnical investigation is strongly recommended.

Current Site Image

North-up current imagery. Polygon shown for site reference. Any visible disturbance is highlighted only if clear.

Source: mapbox_bbox_site

Geotechnical Risk Summary

The following preliminary risk commentary is based on the interpreted site history features identified from available aerial imagery.

Disturbance / Fill Risk — ELEVATED

Visible disturbance within the site suggests that ground modification or placement of fill materials may have occurred. The origin and composition of such materials are typically unknown at this stage and may include uncontrolled fill. This can result in variable strength, moisture conditions, and overall soil behaviour, which may impact foundation performance and footing type, and contribute to differential settlement if not properly assessed in accordance with AS2870.

Historical Pond / Fill Risk — HIGH

Historical imagery indicates the presence of former water features or wet depressions within the site. These areas may have been infilled over time, potentially with uncontrolled or undocumented materials. Infilled pond zones can present significant geotechnical risks, including compressible soils, variable founding conditions, and potential for differential movement. The nature and extent of any fill materials should be confirmed through detailed geotechnical investigation in accordance with AS2870 requirements.

Historical Evidence

Best historical image showing the clearest former water feature evidence.

Source: qld_public_imagery | Queensland Digital Orthophoto Image Data - Brisbane_1995_60cm_9543 | 1995-06-18

Later Comparison Image

Later imagery used to check whether the historical water feature remains visible or appears altered.

Source: qld_public_imagery | Queensland Digital Orthophoto Image Data - Brisbane_Urban_2021_10cm_SISP | 2021-07-17

Limitations & Disclaimer

• Imagery interpretation remains preliminary and should be manually reviewed where uncertainty persists.

This AI site history scan is a preliminary screening tool only. It is intended to identify possible visual indicators for further professional review. It must not be relied on as a substitute for geotechnical investigation, engineering assessment, or design advice.