

BIS AI ASSISTANT – TEST DOCUMENT

Sample compliance document for testing PDF text extraction, requirement extraction, compliance scoring, violations and recommendations.

Product	LED Street Light
Reference Standard	IS 10322 – Luminaires / LED Lighting (test reference)
Document Type	Product Compliance Specification
Manufacturer	ABC Lighting Technologies Pvt. Ltd.
Model	ALT-LED-120

1. Product Requirements

ID	Requirement
REQ-01	The luminaire shall be suitable for outdoor road and street lighting applications.
REQ-02	The product shall provide protection against electric shock during normal operation.
REQ-03	All accessible conductive metal parts shall be properly connected to protective earthing where applicable.
REQ-04	Internal wiring shall be suitably insulated, secured and protected against mechanical damage.
REQ-05	The enclosure shall provide adequate protection for the intended outdoor operating environment.
REQ-06	The luminaire shall have durable and legible product identification and marking.
REQ-07	Terminals and electrical connections shall be secure and suitable for the rated electrical load.
REQ-08	Adequate creepage and clearance distances shall be maintained between relevant conductive parts.
REQ-09	The product shall undergo applicable electrical safety and functional tests before release.
REQ-10	Installation and maintenance instructions shall be supplied with the product.

2. Product Specifications

Parameter	Declared Value
Rated Voltage	220–240 V AC
Rated Frequency	50 Hz
Rated Power	120 W
Protection Class	Class I
Ingress Protection	IP65
Operating Temperature	-10 °C to +45 °C
Housing Material	Aluminium alloy
Light Source	LED module
Power Factor	≥ 0.90

3. Marking and Identification Requirements

- The product marking should identify the manufacturer or responsible supplier.
- Rated voltage, frequency and power information shall be clearly indicated.
- Model or product identification shall be traceable to the relevant technical documentation.
- Safety-related symbols and warnings shall be provided where applicable.
- Markings shall remain legible under the intended operating and environmental conditions.

4. Testing Requirements

Test ID	Test / Verification	Expected Result
TEST-01	Visual inspection	No unsafe construction or exposed hazardous parts
TEST-02	Protective earthing verification	Earth connection secure and continuous
TEST-03	Insulation verification	Insulation suitable for rated voltage
TEST-04	Electrical connection inspection	Connections secure and correctly terminated
TEST-05	Marking verification	Required identification and ratings are legible
TEST-06	Mechanical inspection	Housing and mounting arrangement are secure
TEST-07	Functional operation	Luminaire operates normally at rated supply

5. Sample Compliance Evidence

Requirement	Evidence Provided	Status
REQ-01	Product datasheet states outdoor street-light application.	PASS
REQ-03	Earthing terminal shown in product drawing.	PASS
REQ-04	Wiring specification is available.	PASS
REQ-06	Rating label photograph provided.	PASS
REQ-08	Clearance/creepage measurement report missing.	FAIL
REQ-09	Complete electrical safety test report missing.	FAIL
REQ-10	Installation manual attached.	PASS

6. Known Gaps / Potential Violations

- Missing documented evidence for creepage and clearance measurements.
- Missing complete electrical safety test report.
- The compliance system should verify whether all mandatory marking fields are present.
- The compliance system should verify whether the supplied evidence corresponds to the declared product model.

7. Expected AI Analysis Output

The AI system should extract the requirements, compare them with the supplied evidence, calculate a compliance score, identify failed or missing requirements, and generate actionable recommendations. For this test document, REQ-08 and REQ-09 are intentionally marked as FAIL so that the violation and recommendation stages can be tested.

IMPORTANT: This is a synthetic test document created for software testing. It is not an official BIS standard and must not be used as a legal or certification reference.