

Unit Consumption Details

Sr.no.	Item Description	Location Name										Unit	Losses in %	
		Hospital LT	Bungalow 1 LT Panel	Office Set LT Panel	Police Station	8000 Sqft	Restaurant	Parsi	Bungalow 2 LT	Villa	ODU			
1	Units Billed to Parties	2163	4921	1665	584	961	1646	1524	5142	9434	355	28395		DONE
2	Unit Use for Shooting Purpose	600	866	2657	0	0	150	0	600	0	9	4882		DONE
3	Unit use by Ellora Team for Operational Purpose including Vendor Work with Makeup Rooms											923		DONE
4	Unit Use for Makeup Rooms (Un billed Unit)											3072		DONE
5	Unit Use for Ellora Gate Office											396		DONE
6	Unit Use for Electric Motor											871		DONE
7	Unit Use for Road Light											1735		DONE
	Non Identified Unit											5086	11.21%	DONE
	Unit Losses Details													
1	Monthly Transformer Unit Losses											3350	7.39%	Formula Req'd
2	Unit Consumed by Capacitor Bank											64	0.14%	Formula Req'd
3	Main LT Panels Energy Meter loss and Cable losses											599	1.32%	Formula Req'd
4	Location LT Panels Energy Meter loss and Cable losses											663	1.46%	Formula Req'd
	Grand Total of Unit Losses											4676		