

Title	Register type	Register	Division factor	Unit	Size of variable			Min value		Max value		Default value
Current outdoor temperature (BT1)		MODBUS_INPUT_REGISTER			1	10	°C	2	0	0	0	
Supply line (EP23-BT2)	MODBUS_INPUT_REGISTER		2	10	°C	2	0	0	0			
Supply line (EP22-BT2)	MODBUS_INPUT_REGISTER		3	10	°C	2	0	0	0			
Supply line (EP21-BT2)	MODBUS_INPUT_REGISTER		4	10	°C	2	0	0	0			
Supply line (BT2)	MODBUS_INPUT_REGISTER		5	10	°C	2	0	0	0			
Return line (BT3)	MODBUS_INPUT_REGISTER		7	10	°C	2	0	0	0			
Hot water top (BT7)	MODBUS_INPUT_REGISTER		8	10	°C	2	0	0	0			
Hot water charging (BT6)	MODBUS_INPUT_REGISTER		9	10	°C	2	0	0		0		
Exh. air (AZ30-BT20)	MODBUS_INPUT_REGISTER		19	10	°C	2	0	0	0			
Extr. air (AZ30-BT21)	MODBUS_INPUT_REGISTER		20	10	°C	2	0	0	0			
Roomsensor 1-1	MODBUS_INPUT_REGISTER		26	10	°C	2	0	0				
Temperature limiter (EB100-FD1)	MODBUS_INPUT_REGISTER		36	1		2	0	0		0		
Average temperature (BT1)	MODBUS_INPUT_REGISTER		37	10	°C	2	0	0	0			
Boiler temperature (BT52)	MODBUS_INPUT_REGISTER		38	10	°C	2	0	0	0			
Flow sensor (BF1)	MODBUS_INPUT_REGISTER		40	10	l/m	2	0	0	0			
Electrical anode (EB100-FR1)	MODBUS_INPUT_REGISTER		41	1		2	0	0		0		
Supp. air (AZ30-BT22)	MODBUS_INPUT_REGISTER		42	10	°C	2	0	0	0			
Current (BE3)	MODBUS_INPUT_REGISTER		46	10	A	6	0	0	0			
Current (BE2)	MODBUS_INPUT_REGISTER		48	10	A	6	0	0	0			
Current (BE1)	MODBUS_INPUT_REGISTER		50	10	A	6	0	0	0			
Exh. air (AZ33-BT20)	MODBUS_INPUT_REGISTER		60	10	°C	2	0	0	0			
Exh. air (AZ32-BT20)	MODBUS_INPUT_REGISTER		61	10	°C	2	0	0	0			
Exh. air (AZ31-BT20)	MODBUS_INPUT_REGISTER		62	10	°C	2	0	0	0			
Extract air (AZ33-BT21)	MODBUS_INPUT_REGISTER		63	10	°C	2	0	0	0			
Extract air (AZ32-BT21)	MODBUS_INPUT_REGISTER		64	10	°C	2	0	0	0			
Extract air (AZ31-BT21)	MODBUS_INPUT_REGISTER		65	10	°C	2	0	0	0			
Additional heat (BT63)	MODBUS_INPUT_REGISTER		72	10	°C	2	0	0	0			
Return line (EP23-BT3)	MODBUS_INPUT_REGISTER		75	10	°C	2	0	0	0			
Return line (EP22-BT3)	MODBUS_INPUT_REGISTER		76	10	°C	2	0	0	0			
Return line (EP21-BT3)	MODBUS_INPUT_REGISTER		77	10	°C	2	0	0	0			
Return line (EP15-BT3)	MODBUS_INPUT_REGISTER		78	10	°C	2	0	0	0			
Outgoing hot water (BT70)	MODBUS_INPUT_REGISTER		87	10	°C	2	0	0		0		
Supply line (EP47-BT2)	MODBUS_INPUT_REGISTER		94	10	°C	2	0	0	0			
Supply line (EP46-BT2)	MODBUS_INPUT_REGISTER		95	10	°C	2	0	0	0			
Supply line (EP45-BT2)	MODBUS_INPUT_REGISTER		96	10	°C	2	0	0	0			
Supply line (EP44-BT2)	MODBUS_INPUT_REGISTER		97	10	°C	2	0	0	0			
Return line (EP47-BT3)	MODBUS_INPUT_REGISTER		98	10	°C	2	0	0	0			
Return line (EP46-BT3)	MODBUS_INPUT_REGISTER		99	10	°C	2	0	0	0			
Return line (EP45-BT3)	MODBUS_INPUT_REGISTER		100	10	°C	2	0	0	0			
Return line (EP44-BT3)	MODBUS_INPUT_REGISTER		101	10	°C	2	0	0	0			
Outd temperature (AZ30-BT23)	MODBUS_INPUT_REGISTER		107	10	°C	2	0	0		0		
id:149	MODBUS_INPUT_REGISTER		108	10	°C	2	0	0	0			
Room average temp. clim. system 8 (BT50)	MODBUS_INPUT_REGISTER		109	10	°C	2	0	0	0		0	
Room average temp. clim. system 7 (BT50)	MODBUS_INPUT_REGISTER		110	10	°C	2	0	0	0		0	
Room average temp. clim. system 6 (BT50)	MODBUS_INPUT_REGISTER		111	10	°C	2	0	0	0		0	
Room average temp. clim. system 5 (BT50)	MODBUS_INPUT_REGISTER		112	10	°C	2	0	0	0		0	

Room average temp. clim. system 4 (BT50)	MODBUS_INPUT_REGISTER	113	10	°C	2	0	0	0
Room average temp. clim. system 3 (BT50)	MODBUS_INPUT_REGISTER	114	10	°C	2	0	0	0
Room average temp. clim. system 2 (BT50)	MODBUS_INPUT_REGISTER	115	10	°C	2	0	0	0
Room average temp. clim. system 1 (BT50)	MODBUS_INPUT_REGISTER	116	10	°C	2	0	0	0
External cooling supply temperature (BT25)	MODBUS_INPUT_REGISTER	119	10	°C	2	0	0	0
id:193 MODBUS_INPUT_REGISTER	128	1	4	0	0	0		
Oper. mode shunt climate system 8	MODBUS_INPUT_REGISTER	129	1		4	0	0	0
Oper. mode shunt climate system 7	MODBUS_INPUT_REGISTER	130	1		4	0	0	0
Oper. mode shunt climate system 6	MODBUS_INPUT_REGISTER	131	1		4	0	0	0
Oper. mode shunt climate system 5	MODBUS_INPUT_REGISTER	132	1		4	0	0	0
id:246 MODBUS_INPUT_REGISTER	133	1	4	0	0	0		
Relay status (ERS 1)	MODBUS_INPUT_REGISTER	134	1		4	0	0	0
Fan speed (AZ30-GQ2)	MODBUS_INPUT_REGISTER	135	1	%	4	0	0	0
Fan speed (AZ30-GQ3)	MODBUS_INPUT_REGISTER	136	1	%	4	0	0	0
Current hot water mode controlled by	MODBUS_INPUT_REGISTER	137	1		1	0	0	0
Max. compressor frequency, heating	MODBUS_INPUT_REGISTER	141	100	Hz	5	0	0	0
Inverter alarm code	MODBUS_INPUT_REGISTER	142	1		5	0	0	0
Inverter alarm code	MODBUS_INPUT_REGISTER	143	1		5	0	0	0
External adjustment climate system 8	MODBUS_INPUT_REGISTER	151	1		4	0	0	0
External adjustment climate system 7	MODBUS_INPUT_REGISTER	152	1		4	0	0	0
External adjustment climate system 6	MODBUS_INPUT_REGISTER	153	1		4	0	0	0
External adjustment climate system 5	MODBUS_INPUT_REGISTER	154	1		4	0	0	0
Climate system 8	MODBUS_INPUT_REGISTER	156	1		4	0	0	0
Climate system 7	MODBUS_INPUT_REGISTER	157	1		4	0	0	0
Climate system 6	MODBUS_INPUT_REGISTER	158	1		4	0	0	0
Climate system 5	MODBUS_INPUT_REGISTER	159	1		4	0	0	0
Hot water comfort return (BT82)	MODBUS_INPUT_REGISTER	174	10	°C	2	0	0	0
Hot water comfort heater (BT83)	MODBUS_INPUT_REGISTER	175	10	°C	2	0	0	0
id:599 MODBUS_INPUT_REGISTER	267	1	h	6	-2147483648	2147483647	0	
id:600 MODBUS_INPUT_REGISTER	269	1	h	6	-2147483648	2147483647	0	
id:601 MODBUS_INPUT_REGISTER	271	1	h	6	-2147483648	2147483647	0	
Compressor, total time cooling, main unit (EP14)	MODBUS_INPUT_REGISTER	279	1	h	6	-2147483648	2147483647	0
Compressor, total time pool, main unit (EP14)	MODBUS_INPUT_REGISTER	281	1	h	6	-2147483648	2147483647	0
Compressor, total time pool 2, main unit (EP14)	MODBUS_INPUT_REGISTER	283	1	h	6	-2147483648	2147483647	0
Heat pump 1 requested compressor frequency	MODBUS_INPUT_REGISTER	301	1	Hz	4	0	0	0
Main unit, requested compressor freq	MODBUS_INPUT_REGISTER	302	1	Hz	4	0	0	0
Frost protection heat exchanger, main unit	MODBUS_INPUT_REGISTER	310	1		4	0	0	0
Status (OPT)	MODBUS_INPUT_REGISTER	311	1		4	0	0	0
Version (OPT)	MODBUS_INPUT_REGISTER	312	1		5	0	0	0
OPT relay, modulation level	MODBUS_INPUT_REGISTER	313	10	%	2	0	0	0
OPT operating time	MODBUS_INPUT_REGISTER	315	1	h	5	0	0	0
Available compressors heating	MODBUS_INPUT_REGISTER	317	1		4	0	0	0
Available compressors hot water	MODBUS_INPUT_REGISTER	318	1		4	0	0	0
Available compressors pool 1	MODBUS_INPUT_REGISTER	319	1		4	0	0	0
Available compressors cooling	MODBUS_INPUT_REGISTER	321	1		4	0	0	0
+Adjust, port	MODBUS_INPUT_REGISTER	327	1		4	0	0	0

+Adjust, operating mode	MODBUS_INPUT_REGISTER	328	1		4	0	0	0		
+Adjust, comfort	MODBUS_INPUT_REGISTER	329	1		4	0	0	0		
+Adjust, parallel adjustment	MODBUS_INPUT_REGISTER	330	1			1	0	0	0	
+Adjust, humidity	MODBUS_INPUT_REGISTER	331	10	%RH	2	0	0	0		
+Adjust, indoor temperature	MODBUS_INPUT_REGISTER	332	10	°C	2	0	0	0	0	
+Adjust, outdoor temperature	MODBUS_INPUT_REGISTER	333	10	°C	2	0	0	0	0	
+Adjust, version	MODBUS_INPUT_REGISTER	334	1		5	0	0	0		
+Adjust, active	MODBUS_INPUT_REGISTER	335	1		4	0	0	0		
+Adjust, demand	MODBUS_INPUT_REGISTER	336	1		4	0	0	0		
+Adjust, parallel factor	MODBUS_HOLDING_REGISTER	1	1			1	1	10	5	
+Adjust, Parallel (min-max)	MODBUS_HOLDING_REGISTER	2	1			1	1	100	100	
Supply temperature (BT64)	MODBUS_INPUT_REGISTER	337	10	°C	2	0	0	0		
Heat pump functionality 2	MODBUS_INPUT_REGISTER	338	1			6	0	0	0	
Status (S135)	MODBUS_INPUT_REGISTER	344	1		4	0	0	0		
Status, demand, pump speed (S135)	MODBUS_INPUT_REGISTER	345	1				4	0	0	0
Status, demand, fan speed (S135)	MODBUS_INPUT_REGISTER	346	1				4	0	0	0
Status, solenoid (S135)	MODBUS_INPUT_REGISTER	347	1		4	0	0	0		
Status, compressor, heater(S135)	MODBUS_INPUT_REGISTER	348	1				4	0	0	0
Status, compressor, demand (S135)	MODBUS_INPUT_REGISTER	350	1				4	0	0	0
No. of starts (S135)	MODBUS_INPUT_REGISTER	351	1		6	0	9999999	0		
Operating time (S135)	MODBUS_INPUT_REGISTER	353	1	h	6	0	9999999	0		
Degree minutes	MODBUS_HOLDING_REGISTER	11	10	DM	3	-30000	30000	0		
Blocking (ERS 1)	MODBUS_INPUT_REGISTER	358	1		4	0	0	0		
AZ30-EB17	MODBUS_INPUT_REGISTER	359	1		4	0	0	0		
Supply line (S135-BT12)	MODBUS_INPUT_REGISTER	360	10	°C	2	0	0	0		
Return line (S135-BT13)	MODBUS_INPUT_REGISTER	361	10	°C	2	0	0	0		
Evaporator (S135-BT16)	MODBUS_INPUT_REGISTER	362	10	°C	2	0	0	0		
Defrosting sensor (S135-BT76)	MODBUS_INPUT_REGISTER	363	10	°C	2	0	0	0	0	
Incoming air (S135-BT77)	MODBUS_INPUT_REGISTER	364	10	°C	2	0	0	0	0	
Alarm number (S135)	MODBUS_INPUT_REGISTER	365	1		5	0	0	0		
Defrosting (S135)	MODBUS_INPUT_REGISTER	366	1		4	0	0	0		
Status, relay 5 (S135)	MODBUS_INPUT_REGISTER	367	1		4	0	0	0		
Status, relay 4 (S135)	MODBUS_INPUT_REGISTER	368	1		4	0	0	0		
Status, relay 3 (S135)	MODBUS_INPUT_REGISTER	369	1		4	0	0	0		
Status, relay 2 (S135)	MODBUS_INPUT_REGISTER	370	1		4	0	0	0		
Status, relay 1 (S135)	MODBUS_INPUT_REGISTER	371	1		4	0	0	0		
Status, relay 0 (S135)	MODBUS_INPUT_REGISTER	372	1		4	0	0	0		
Pump speed (S135)	MODBUS_INPUT_REGISTER	373	1	%	4	0	0	0		
Selected fan speed	MODBUS_INPUT_REGISTER	374	1	%	4	0	0	0		
Version (S135)	MODBUS_INPUT_REGISTER	376	1		5	0	0	0		
id:803	MODBUS_INPUT_REGISTER	377	1		6	0	2147483647	0		
id:804	MODBUS_INPUT_REGISTER	379	1		6	0	0	0		
id:805	MODBUS_INPUT_REGISTER	381	1		6	0	2147483647	0		
id:806	MODBUS_INPUT_REGISTER	383	1		6	0	0	0		
Seconds of blank time left, charge pump 1	MODBUS_INPUT_REGISTER	392	1				4	0	0	0
Seconds of blank time left, charge pump 0	MODBUS_INPUT_REGISTER	393	1				4	0	0	0
Alarm number from outdoor air heat pump (EB101)	MODBUS_INPUT_REGISTER	400	1				4	0	0	0

Fan speed (EB101)	MODBUS_INPUT_REGISTER	401	1	rpm	5	0	0	0		
Max fan speed (EB101)	MODBUS_INPUT_REGISTER	402	1	rpm	5	0	0	0		
Min fan speed (EB101)	MODBUS_INPUT_REGISTER	403	1	rpm	5	0	0	0		
Max compressor speed (EB101)	MODBUS_INPUT_REGISTER	404	10	Hz	5	0	0	0	0	
Min compressor speed (EB101)	MODBUS_INPUT_REGISTER	405	10	Hz	5	0	0	0	0	
Power (EB101)	MODBUS_INPUT_REGISTER	406	10	kW	5	0	0	0		
Time to defrosting (EB101)	MODBUS_INPUT_REGISTER	407	1	min	5	0	0	0	0	
Defrosting index (EB101)	MODBUS_INPUT_REGISTER	408	1		5	0	0	0	0	
Superheat reference EEV (EB101)	MODBUS_INPUT_REGISTER	409	10	°C	2	0	0	0	0	
Superheat EEV (EB101)	MODBUS_INPUT_REGISTER	410	10	°C	2	0	0	0	0	
EEV-ssh-error (EB101)	MODBUS_INPUT_REGISTER	411	10	°C	2	0	0	0	0	
Superheat temp. reference EEV (EB101)	MODBUS_INPUT_REGISTER	412	10	°C	2	0	0	0	0	0
Set point value EEV (EB101)	MODBUS_INPUT_REGISTER	413	10	°C	2	0	0	0	0	
EEV PV (EB101)	MODBUS_INPUT_REGISTER	414	10	°C	2	0	0	0	0	
EEV-te-error average open (EB101)	MODBUS_INPUT_REGISTER	415	10	°C	2	0	0	0	0	0
Degree of opening EEV (EB101)	MODBUS_INPUT_REGISTER	416	1		5	0	0	0	0	
Superheat reference EVI (EB101)	MODBUS_INPUT_REGISTER	417	10	°C	2	0	0	0	0	
Superheat EVI (EB101)	MODBUS_INPUT_REGISTER	418	10	°C	2	0	0	0	0	
EEV-ssh-error (EVI)(EB101)	MODBUS_INPUT_REGISTER	419	10	°C	2	0	0	0	0	
Superheat temp. reference EVI (EB101)	MODBUS_INPUT_REGISTER	420	10	°C	2	0	0	0	0	0
Set point value EVI (EB101)	MODBUS_INPUT_REGISTER	421	10	°C	2	0	0	0	0	
EVI PV (EB101)	MODBUS_INPUT_REGISTER	422	10	°C	2	0	0	0	0	
EEV-te-error average open in (EVI)(EB101)	MODBUS_INPUT_REGISTER	423	10	°C	2	0	0	0	0	0
Degree of opening EVI (EB101)	MODBUS_INPUT_REGISTER	424	1		5	0	0	0	0	
id:859	MODBUS_INPUT_REGISTER	426	10	%RH	2	0	0	0	0	
id:861	MODBUS_INPUT_REGISTER	427	1		6	0	0	0	0	
id:862	MODBUS_INPUT_REGISTER	429	1		5	0	0	0	0	
Low press (EB101 BP8 dew)	MODBUS_INPUT_REGISTER	550	10	°C	2	0	0	0	0	
Hi press (EB101 BP9 dew)	MODBUS_INPUT_REGISTER	551	10	°C	2	0	0	0	0	
Injection (EB101-BT81)	MODBUS_INPUT_REGISTER	552	10	°C	2	0	0	0	0	
Pressure sensor, injection (EB101-BP11)	MODBUS_INPUT_REGISTER	553	10		2	0	0	0	0	0
EVI pressure (EB101-EP14-BP11 dew)	MODBUS_INPUT_REGISTER	554	10	°C	2	0	0	0	0	0
Evaporator (EB101-BT84)	MODBUS_INPUT_REGISTER	555	10	°C	2	0	0	0	0	
Fan status (EB101-EP14)	MODBUS_INPUT_REGISTER	556	1		4	0	0	0	0	
Fan rpm (EB101-EP14)	MODBUS_INPUT_REGISTER	557	1	rpm	5	0	0	0	0	
High condenser out alarm (S135)	MODBUS_INPUT_REGISTER	575	1		5	0	0	0	0	
High condenser in alarm (S135)	MODBUS_INPUT_REGISTER	576	1		5	0	0	0	0	
Average current (EME 10)	MODBUS_INPUT_REGISTER	578	10	A	2	0	0	0	0	
Operating mode PV panels	MODBUS_INPUT_REGISTER	579	1		4	0	0	0	0	
EME lux mode without EME	MODBUS_INPUT_REGISTER	581	1		4	0	0	0	0	
Timer (EME)	MODBUS_INPUT_REGISTER	582	60	min	5	0	0	0	0	
Fan mode 4	MODBUS_INPUT_REGISTER	590	1	%	4	0	0	0	0	
Fan mode 3	MODBUS_INPUT_REGISTER	591	1	%	4	0	0	0	0	
Fan mode 2	MODBUS_INPUT_REGISTER	592	1	%	4	0	0	0	0	
Is the compressor accessible	MODBUS_INPUT_REGISTER	593	1		4	0	0	0	0	
Prio, hot water (OPT)	MODBUS_INPUT_REGISTER	604	1		4	0	0	0	0	
Permit (undefined)	MODBUS_INPUT_REGISTER	683	1		4	0	0	0	0	

Permit (undefined)	MODBUS_INPUT_REGISTER	684	1	4	0	0	0		
Permit (undefined)	MODBUS_INPUT_REGISTER	685	1	4	0	0	0		
Permit (OPT 10) additional heat	MODBUS_INPUT_REGISTER	686	1	4	4	0	0	0	
Permit ext. imm. heater step	MODBUS_INPUT_REGISTER	687	1	4	4	0	0	0	
Permit int. imm. heater step	MODBUS_INPUT_REGISTER	688	1	4	4	0	0	0	
Permit shunted additional heat	MODBUS_INPUT_REGISTER	689	1	4	4	0	0	0	
Permit prioritised additional heat	MODBUS_INPUT_REGISTER	690	1	4	4	0	0	0	0
Permit (EB108-EP15)	MODBUS_INPUT_REGISTER	691	1	4	0	0	0		
Permit (EB107-EP15)	MODBUS_INPUT_REGISTER	692	1	4	0	0	0		
Permit (EB106-EP15)	MODBUS_INPUT_REGISTER	693	1	4	0	0	0		
Permit (EB105-EP15)	MODBUS_INPUT_REGISTER	694	1	4	0	0	0		
Permit (EB104-EP15)	MODBUS_INPUT_REGISTER	695	1	4	0	0	0		
Permit (EB103-EP15)	MODBUS_INPUT_REGISTER	696	1	4	0	0	0		
Permit (EB102-EP15)	MODBUS_INPUT_REGISTER	697	1	4	0	0	0		
Permit (EB101-EP15)	MODBUS_INPUT_REGISTER	698	1	4	0	0	0		
Permit (EB100-EP15)	MODBUS_INPUT_REGISTER	699	1	4	0	0	0		
Permit (EB108-EP14)	MODBUS_INPUT_REGISTER	700	1	4	0	0	0		
Permit (EB107-EP14)	MODBUS_INPUT_REGISTER	701	1	4	0	0	0		
Permit (EB106-EP14)	MODBUS_INPUT_REGISTER	702	1	4	0	0	0		
Permit (EB105-EP14)	MODBUS_INPUT_REGISTER	703	1	4	0	0	0		
Permit (EB104-EP14)	MODBUS_INPUT_REGISTER	704	1	4	0	0	0		
Permit (EB103-EP14)	MODBUS_INPUT_REGISTER	705	1	4	0	0	0		
Permit (EB102-EP14)	MODBUS_INPUT_REGISTER	706	1	4	0	0	0		
Permit (EB101-EP14)	MODBUS_INPUT_REGISTER	707	1	4	0	0	0		
Permit (EB100-EP14)	MODBUS_INPUT_REGISTER	708	1	4	0	0	0		
Smart energy source, priority 7, start DM	MODBUS_INPUT_REGISTER	709	1	3	0	0	0		
Smart energy source, priority 6, start DM	MODBUS_INPUT_REGISTER	711	1	3	0	0	0		
Smart energy source, priority 5, start DM	MODBUS_INPUT_REGISTER	713	1	3	0	0	0		
Smart energy source, priority 4, start DM	MODBUS_INPUT_REGISTER	715	1	3	0	0	0		
Smart energy source, priority 3, start DM	MODBUS_INPUT_REGISTER	717	1	3	0	0	0		
Smart energy source, priority 2, start DM	MODBUS_INPUT_REGISTER	719	1	3	0	0	0		
Smart energy source, priority 1, start DM	MODBUS_INPUT_REGISTER	721	1	3	0	0	0		
Smart energy source, priority 7, stop DM	MODBUS_INPUT_REGISTER	723	1	3	0	0	0		
Smart energy source, priority 6, stop DM	MODBUS_INPUT_REGISTER	725	1	3	0	0	0		
Smart energy source, priority 5, stop DM	MODBUS_INPUT_REGISTER	727	1	3	0	0	0		
Smart energy source, priority 4, stop DM	MODBUS_INPUT_REGISTER	729	1	3	0	0	0		
Smart energy source, priority 3, stop DM	MODBUS_INPUT_REGISTER	731	1	3	0	0	0		
Smart energy source, priority 2, stop DM	MODBUS_INPUT_REGISTER	733	1	3	0	0	0		
Smart energy source, priority 1, stop DM	MODBUS_INPUT_REGISTER	735	1	3	0	0	0		
Smart energy source, DM minimum value	MODBUS_INPUT_REGISTER	737	1	3	0	0	0		
External guide status	MODBUS_INPUT_REGISTER	745	1	4	0	0	0		
Test guide value	MODBUS_INPUT_REGISTER	746	1	5	0	0	0		
Temp. lux forces start of hot water demand	MODBUS_INPUT_REGISTER	747	1	4	0	0	0		
Smart energy source, prio OPT10 for hot water	MODBUS_INPUT_REGISTER	757	1	4	0	0	0		
Smart energy source, Permit OPT to produce hot water	MODBUS_INPUT_REGISTER	758	1	4	0	0	0	0	
Wood boiler activated	MODBUS_INPUT_REGISTER	759	1	4	0	0	0		
Time to defrosting (EB108)	MODBUS_INPUT_REGISTER	767	1	min	5	0	0	0	

Time to defrosting (EB107)	MODBUS_INPUT_REGISTER	792	1	min	5	0	0	0			
Time to defrosting (EB106)	MODBUS_INPUT_REGISTER	817	1	min	5	0	0	0			
Time to defrosting (EB105)	MODBUS_INPUT_REGISTER	842	1	min	5	0	0	0			
Time to defrosting (EB104)	MODBUS_INPUT_REGISTER	867	1	min	5	0	0	0			
Time to defrosting (EB103)	MODBUS_INPUT_REGISTER	892	1	min	5	0	0	0			
Time to defrosting (EB102)	MODBUS_INPUT_REGISTER	917	1	min	5	0	0	0			
Alarm number (EB100)	MODBUS_INPUT_REGISTER	935	1		4	0	0	0			
Fan speed (EB100)	MODBUS_INPUT_REGISTER	936	1	rpm	5	0	0	0			
Max fan speed (EB100)	MODBUS_INPUT_REGISTER	937	1	rpm	5	0	0	0			
Min fan speed (EB100)	MODBUS_INPUT_REGISTER	938	1	rpm	5	0	0	0			
Max compressor speed (EB100)	MODBUS_INPUT_REGISTER	939	10	Hz	5	0	0	0			
Min compressor speed (EB100)	MODBUS_INPUT_REGISTER	940	10	Hz	5	0	0	0			
Power (EB100)	MODBUS_INPUT_REGISTER	941	10	kW	5	0	0	0			
Time to defrosting (EB100)	MODBUS_INPUT_REGISTER	942	1	min	5	0	0	0			
Defrosting index (EB100)	MODBUS_INPUT_REGISTER	943	1		5	0	0	0			
Superheat reference (EEV)(EB100)	MODBUS_INPUT_REGISTER	944	10	°C	2	0	0	0	0		
Superheat EEV (EB100)	MODBUS_INPUT_REGISTER	945	10	°C	2	0	0	0	0		
EEV-ssh-error (EB100)	MODBUS_INPUT_REGISTER	946	10	°C	2	0	0	0	0		
Superheat temp. reference (EEV)(EB100)	MODBUS_INPUT_REGISTER	947	10	°C	2	0	0	0	0		
Set point value EEV (EB100)	MODBUS_INPUT_REGISTER	948	10	°C	2	0	0	0	0		
EEV PV (EB100)	MODBUS_INPUT_REGISTER	949	10	°C	2	0	0	0	0		
EEV-te-error average open (EB100)	MODBUS_INPUT_REGISTER	950	10	°C	2	0	0	0	0		
Opening degree EEV (EB100)	MODBUS_INPUT_REGISTER	951	1		5	0	0	0	0		
Superheat reference EVI (EB100)	MODBUS_INPUT_REGISTER	952	10	°C	2	0	0	0	0		
Superheat EVI (EB100)	MODBUS_INPUT_REGISTER	953	10	°C	2	0	0	0	0		
EEV-ssh-error (EVI)(EB100)	MODBUS_INPUT_REGISTER	954	10	°C	2	0	0	0	0		
Superheat temp. reference (EVI)(EB100)	MODBUS_INPUT_REGISTER	955	10	°C	2	0	0	0	0		
Set point value EVI (EB100)	MODBUS_INPUT_REGISTER	956	10	°C	2	0	0	0	0		
EVI PV (EB100)	MODBUS_INPUT_REGISTER	957	10	°C	2	0	0	0	0		
EEV-te-error average open (EVI)(EB100)	MODBUS_INPUT_REGISTER	958	10	°C	2	0	0	0	0		
Opening degree EVI (EB100)	MODBUS_INPUT_REGISTER	959	1		5	0	0	0	0		
Wind speed, weather forecast	MODBUS_INPUT_REGISTER	960	10		5	0	0	0	0		
Humidity, weather forecast	MODBUS_INPUT_REGISTER	961	10	%	5	0	0	0	0		
Temperature, weather forecast	MODBUS_INPUT_REGISTER	962	10	°C	2	0	0	0	0		
Temperature, weather data (forecast)	MODBUS_INPUT_REGISTER	963	10	°C	2	0	0	0	0		
Smart energy source, priority select. in hot water	MODBUS_INPUT_REGISTER	991	1		4	0	0	0	0	0	0
Outd. air heat pump, inverter, limits	MODBUS_INPUT_REGISTER	992	1		4	0	0	0	0	0	0
Outd. air heat pump, inverter, speed reducing	MODBUS_INPUT_REGISTER	993	1		4	0	0	0	0	0	0
Has one phase (EB101)	MODBUS_INPUT_REGISTER	1008	1		4	0	0	0	0		
Serial index (EB101)	MODBUS_INPUT_REGISTER	1009	1		4	0	0	0	0		
Serial index (EB100)	MODBUS_INPUT_REGISTER	1011	1		4	0	0	0	0		
Alarm incompatible (heat pump)	MODBUS_INPUT_REGISTER	1012	1		5	0	0	0	0		
Limit DM	MODBUS_HOLDING_REGISTER	18	10	DM	2	-30000	30000	0			
Calculated supply climate system 1	MODBUS_INPUT_REGISTER	1017	10	°C	2	0	0	0	0		
Class 1 alarm	MODBUS_INPUT_REGISTER	2195	1		4	0	0	0	0		
Frost protection status	MODBUS_INPUT_REGISTER	1018	1		5	0	0	0	0		
Cooling status	MODBUS_INPUT_REGISTER	1019	1		4	0	0	0	0		

id:1726 MODBUS_HOLDING_REGISTER	2757	1	2	0	30000	0				
Total run time additional heat	MODBUS_INPUT_REGISTER	1025	10	h	3	0	1000000	0		
Power internal additional heat	MODBUS_INPUT_REGISTER	1027	100	kW	2	0	0	0		
id:1757 MODBUS_HOLDING_REGISTER	2758	1	4	0	1	0				
Priority	MODBUS_INPUT_REGISTER	1028	1	4	0	0				
Operating mode internal add. heat	MODBUS_INPUT_REGISTER	1029	1		4	0	0	0		
Oper. mode shunt climate system 4	MODBUS_INPUT_REGISTER	1030	1		4	0	0	0		
Oper. mode shunt climate system 3	MODBUS_INPUT_REGISTER	1031	1		4	0	0	0		
Oper. mode shunt climate system 2	MODBUS_INPUT_REGISTER	1032	1		4	0	0	0		
Oper. mode shunt climate system 1	MODBUS_INPUT_REGISTER	1033	1		4	0	0	0		
Operating. mode shunt controlled additional heat	MODBUS_INPUT_REGISTER	1034	1		4	0	0	0		
Fan mode 1	MODBUS_INPUT_REGISTER	1037	1	%	4	0	0	0		
Current hot water mode	MODBUS_INPUT_REGISTER	1038	1		1	0	0	0		
Blocking cooling	MODBUS_INPUT_REGISTER	1053	1		4	0	0	0		
External adjustment climate system 4	MODBUS_INPUT_REGISTER	1054	1		4	0	0	0		
External adjustment climate system 3	MODBUS_INPUT_REGISTER	1055	1		4	0	0	0		
External adjustment climate system 2	MODBUS_INPUT_REGISTER	1056	1		4	0	0	0		
External adjustment climate system 1	MODBUS_INPUT_REGISTER	1057	1		4	0	0	0		
External blocking	MODBUS_INPUT_REGISTER	1058	1		4	0	0	0		
Step controlled add. heat blocking	MODBUS_INPUT_REGISTER	1062	1		4	0	0	0		
Energy meter	MODBUS_INPUT_REGISTER	1067	10	kWh	6	0	9999999	0		
Hot water circulation (GP11)	MODBUS_INPUT_REGISTER	1063	1		4	0	0	0		
Total HW run time additional heat	MODBUS_INPUT_REGISTER	1069	10	h	3	0	9999999	0		
More hot water status	MODBUS_INPUT_REGISTER	1078	1		4	0	0	0		
Holiday function status	MODBUS_HOLDING_REGISTER	19	1		1	0	0	0		
Heating medium pump speed (GP1)	MODBUS_INPUT_REGISTER	1102	1	%	4	0	0	0		
Docked compressors heating	MODBUS_INPUT_REGISTER	1108	1		4	0	0	0		
Docked compressors hot water	MODBUS_INPUT_REGISTER	1109	1		4	0	0	0		
Docked compressors pool 1	MODBUS_INPUT_REGISTER	1110	1		4	0	0	0		
Reversing valve hot water (QN10)	MODBUS_INPUT_REGISTER	2196	1		4	0	0	0		
Operating mode step controlled additional heat	MODBUS_INPUT_REGISTER	1115	1		4	0	0	0		
Relay status, base board (EB100-EP14)	MODBUS_INPUT_REGISTER	1117	1		4	0	0	0		
Relay status, imm. heat. board (EB100-EP14)	MODBUS_INPUT_REGISTER	1119	1		4	0	0	0		
Current status	MODBUS_INPUT_REGISTER	1120	1		6	0	0	0		
Functionality, heat pump (EP14)	MODBUS_INPUT_REGISTER	1122	1		6	0	0	0		
Active heat pumps	MODBUS_INPUT_REGISTER	1124	1		5	0	0	0		
Functionality, heat pump (EP15)	MODBUS_INPUT_REGISTER	1125	1		6	0	0	0		
Operating mode HW comfort	MODBUS_INPUT_REGISTER	1129	1		4	0	0	0		
Operating mode HW comfort additional heat	MODBUS_INPUT_REGISTER	1130	1		4	0	0	0		
Blocked	MODBUS_INPUT_REGISTER	1132	1		4	0	0	0		
Pool 1 (QN19)	MODBUS_INPUT_REGISTER	1134	1		4	0	0	0		
Version (EB101)	MODBUS_INPUT_REGISTER	1451	1		5	0	0	0		
Heat pump type (EB101)	MODBUS_INPUT_REGISTER	1452	1		4	0	0	0		
Compressor size (EB101)	MODBUS_INPUT_REGISTER	1453	1		4	0	0	0		
Return line (EB101-BT3)	MODBUS_INPUT_REGISTER	1475	10	°C	2	0	0	0		
Supply line (EB101-BT12)	MODBUS_INPUT_REGISTER	1478	10	°C	2	0	0	0		
Discharge (EB101-BT14)	MODBUS_INPUT_REGISTER	1479	10	°C	2	0	0	0		

Liquid line (EB101-BT15)	MODBUS_INPUT_REGISTER	1480	10	°C	2	0	0	0			
Suction gas (EB101-BT17)	MODBUS_INPUT_REGISTER	1481	10	°C	2	0	0	0			
Compressor, time to start (EB101-EP14)	MODBUS_INPUT_REGISTER	1485	1	min	4	0	0	0	0		
Compressor, number of starts (EB101-EP14)	MODBUS_INPUT_REGISTER	1489	1			6	-2147483648	2147483647	0		
Compressor, oper. time, total (EB101-EP14)	MODBUS_INPUT_REGISTER	1491	1	h	6	-2147483648	2147483647	0			
Compressor, oper. time, hot water (EB101-EP14)	MODBUS_INPUT_REGISTER	1493	1	h	6	-2147483648	2147483647	0			
Alarm number (EB101-EP14)	MODBUS_INPUT_REGISTER	1495	1	5	0	0	0				
Heat pump type (EB100)	MODBUS_INPUT_REGISTER	1497	1	4	0	0	0				
Compressor size (EB100)	MODBUS_INPUT_REGISTER	1498	1	4	0	0	0				
Compressor, requested (EB101-EP14)	MODBUS_INPUT_REGISTER	1556	1	4	0	0	0	0			
Cooling blocking	MODBUS_INPUT_REGISTER	1559	1	4	0	0	0				
Date, periodic hot water	MODBUS_INPUT_REGISTER	1561	1	-	-	-	-				
Blocked compressors	MODBUS_INPUT_REGISTER	2174	1	6	0	0	0				
Cooling degree minutes	MODBUS_HOLDING_REGISTER	20	10	DM	2	-30000	30000	0			
Calculated cooling supply climate system 1	MODBUS_INPUT_REGISTER	1567	10	°C	2	0	0	0	0		
Hot water, including int. add. heat	MODBUS_INPUT_REGISTER	1575	10	kWh	6	0	9999999	0			
Heating, including int. add. heat	MODBUS_INPUT_REGISTER	1577	10	kWh	6	0	9999999	0			
Cooling, compressor only	MODBUS_INPUT_REGISTER	1579	10	kWh	6	0	9999999	0			
Hot water, compressor only	MODBUS_INPUT_REGISTER	1583	10	kWh	6	0	9999999	0			
Heating, compressor only	MODBUS_INPUT_REGISTER	1585	10	kWh	6	0	9999999	0			
id:2728	MODBUS_HOLDING_REGISTER	3099	1	3	0	9999999	0				
Speed (GP12)	MODBUS_INPUT_REGISTER	1589	1	%	4	0	0				
Cooling pump manual speed	MODBUS_HOLDING_REGISTER	21	1	%	1	1	100	70			
Outdoor temperature (EB101-BT28)	MODBUS_INPUT_REGISTER	1621	10	°C	2	0	0	0	0		
Evaporator (EB101-BT16)	MODBUS_INPUT_REGISTER	1622	10	°C	2	0	0	0			
Heating medium pump speed (GP1)	MODBUS_INPUT_REGISTER	1636	1	%	4	0	0	0			
id:2793	MODBUS_INPUT_REGISTER	1637	1	%	4	0	0				
Frost protection heat exchanger heat pump 1	MODBUS_INPUT_REGISTER	1638	1			4	0	0	0		
Operating mode extra additional heat	MODBUS_INPUT_REGISTER	1693	1			4	0	0	0		
Docked compressors cooling	MODBUS_INPUT_REGISTER	1694	1	4	0	0	0				
BP4, unprocessed (EB101-EP14)	MODBUS_INPUT_REGISTER	1800	1	2	0	0	0				
Pressure sensor, condenser (EB101-BP4)	MODBUS_INPUT_REGISTER	1801	10	bar	2	0	0	0	0		
Low pressure (EB101-BP8)	MODBUS_INPUT_REGISTER	1802	10	bar	2	0	0	0			
Current compressor frequency (EB101)	MODBUS_INPUT_REGISTER	1803	10	Hz	2	0	0	0	0		
Protection mode (EB101)	MODBUS_INPUT_REGISTER	1804	1	5	0	0	0				
Defrosting (EB101)	MODBUS_INPUT_REGISTER	1805	1	4	0	0	0				
Power (EB101-EP14)	MODBUS_INPUT_REGISTER	1806	1	kW	4	0	0	0			
Internal charge pump (GP12)	MODBUS_INPUT_REGISTER	1822	1	4	0	0	0	0			
Climate system 4	MODBUS_INPUT_REGISTER	1823	1	4	0	0	0				
Climate system 3	MODBUS_INPUT_REGISTER	1824	1	4	0	0	0				
Climate system 2	MODBUS_INPUT_REGISTER	1825	1	4	0	0	0				
Climate system 1 (HMP)	MODBUS_INPUT_REGISTER	1826	1	4	0	0	0				
Pool 1 pump status	MODBUS_INPUT_REGISTER	1828	1	4	0	0	0				
Requested compressor frequency (EB101)	MODBUS_INPUT_REGISTER	1854	1	Hz	4	0	0	0	0		
Low press. sensor, unprocessed (EB101-EP14)	MODBUS_INPUT_REGISTER	1902	1			2	0	0	0		
Current sensor (EB101-EP14)	MODBUS_INPUT_REGISTER	1903	10	A	2	0	0	0			
Operating mode (SG Ready)	MODBUS_INPUT_REGISTER	1911	1	4	0	0	0				

SG ready, input A	MODBUS_INPUT_REGISTER	1912	1	4	0	0	0			
SG ready, input B	MODBUS_INPUT_REGISTER	1913	1	4	0	0	0			
Heating offset (SPA)	MODBUS_INPUT_REGISTER	1914	10	1	0	0	0			
Hot water comfort mode (SPA)	MODBUS_INPUT_REGISTER	1915	1		1	0	0	0		
Pool offset (SPA)	MODBUS_INPUT_REGISTER	1916	1	1	0	0	0			
Cooling offset (SPA)	MODBUS_INPUT_REGISTER	1917	1	1	0	0	0			
Operating mode (Smart Price Adaption)	MODBUS_INPUT_REGISTER	1918	1		4	0	0	0		
Evaporator 2 (EB101-EP14-BT16)	MODBUS_INPUT_REGISTER	1966	10	°C	2	0	0	0		
Temperature, inverter (EB101-EP14)	MODBUS_INPUT_REGISTER	1967	10	°C	2	0	0	0		
fan speed (EB101-EP14)	MODBUS_INPUT_REGISTER	1968	1	4	0	0	0			
Evaporator 2 (EB100-EP15-BT16)	MODBUS_INPUT_REGISTER	1969	10	°C	2	0	0	0		
Temperature, inverter (EB100-EP15)	MODBUS_INPUT_REGISTER	1970	10	°C	2	0	0	0		
fan speed (EB100-EP15)	MODBUS_INPUT_REGISTER	1971	1	4	0	0	0			
Evaporator 2 (EB100-EP14-BT16)	MODBUS_INPUT_REGISTER	1972	10	°C	2	0	0	0		
Temperature, inverter (EB100-EP14)	MODBUS_INPUT_REGISTER	1973	10	°C	2	0	0	0		
fan speed (EB100-EP14)	MODBUS_INPUT_REGISTER	1974	1	4	0	0	0			
Alarm number	MODBUS_INPUT_REGISTER	1975	1	2	0	0	0			
Reset alarm	MODBUS_HOLDING_REGISTER	22	1	4	0	0	0			
Non module-specific alarm numbers	MODBUS_INPUT_REGISTER	1976	1		2	0	0	0		
Heating curve climate system 1	MODBUS_HOLDING_REGISTER	26	1		1	0	15	9		
Heating offset climate system 1	MODBUS_HOLDING_REGISTER	30	1		1	-10	10	0		
Min supply climate system 1	MODBUS_HOLDING_REGISTER	34	10	°C	2	50	800	200		
Max supply climate system 1	MODBUS_HOLDING_REGISTER	38	10	°C	2	50	800	600		
Own curve, heating P7	MODBUS_HOLDING_REGISTER	39	1	°C	1	5	80	15		
Own curve, heating P6	MODBUS_HOLDING_REGISTER	40	1	°C	1	5	80	15		
Own curve, heating P5	MODBUS_HOLDING_REGISTER	41	1	°C	1	5	80	26		
Own curve, heating P4	MODBUS_HOLDING_REGISTER	42	1	°C	1	5	80	32		
Own curve, heating P3	MODBUS_HOLDING_REGISTER	43	1	°C	1	5	80	35		
Own curve, heating P2	MODBUS_HOLDING_REGISTER	44	1	°C	1	5	80	40		
Own curve, heating P1	MODBUS_HOLDING_REGISTER	45	1	°C	1	5	80	45		
Point offset outdoor temperature	MODBUS_HOLDING_REGISTER	46	1	°C	1	-40	30	0		
Point offset	MODBUS_HOLDING_REGISTER	47	1	°C	1	-10	10	0		
External adjustment climate system 1	MODBUS_HOLDING_REGISTER	51	1		1	-10	10	0		
External adjustment with room sensor climate system 1	MODBUS_HOLDING_REGISTER	55	10	°C	2	50	300	200		
Hot water demand mode	MODBUS_HOLDING_REGISTER	56	1		1	0	1			
Start temperature HW high temperature	MODBUS_HOLDING_REGISTER	58	10	°C	2	50	700	440		
Start temperature HW normal temperature	MODBUS_HOLDING_REGISTER	59	10	°C	2	50	700	410		
Start temperature HW low temperature	MODBUS_HOLDING_REGISTER	60	10	°C	2	50	700	380		
Stop temperature HW periodic increase	MODBUS_HOLDING_REGISTER	61	10	°C	2	550	700	550		
Stop temperature HW high temperature	MODBUS_HOLDING_REGISTER	62	10	°C	2	50	700	480		
Stop temperature HW normal temperature	MODBUS_HOLDING_REGISTER	63	10	°C	2	50	700	450		
Stop temperature HW low temperature	MODBUS_HOLDING_REGISTER	64	10	°C	2	50	700	420		
Periodic hot water	MODBUS_HOLDING_REGISTER	65	1		1	0	1			
Periodic hot water interval	MODBUS_HOLDING_REGISTER	66	1	days	1	1	90	7		
Start time periodic hot water	MODBUS_HOLDING_REGISTER	67	1		-	-	-	-		
Language	MODBUS_HOLDING_REGISTER	91	1		0	22	0			
Period time hot water	MODBUS_HOLDING_REGISTER	92	1	min	4	0	180	30		

Period time heating	MODBUS_HOLDING_REGISTER	93	1	min	4	0	180	30				
Operating mode	MODBUS_HOLDING_REGISTER	2743	1		4	0	2	0				
Operating mode heating medium pump	MODBUS_HOLDING_REGISTER	95			1			4	10	40	40	
Activate forced control	MODBUS_HOLDING_REGISTER	5000	1		4	0		0	0			
Max. internal additional heat	MODBUS_HOLDING_REGISTER	102	100	kW	2	0		4500	900			
Fuse	MODBUS_HOLDING_REGISTER	103	1	A	5	1	400	16				
id:3826	MODBUS_HOLDING_REGISTER	2747	1		4	1	128	4				
id:3827	MODBUS_HOLDING_REGISTER	2746	1		4	1	128	2				
id:3828	MODBUS_HOLDING_REGISTER	2745	1		4	1	128	1				
Ventilation mode	MODBUS_HOLDING_REGISTER	104	1		4	0		4	0			
Return time fan 4	MODBUS_HOLDING_REGISTER	115	1	h	4	1		24	4			
Return time fan 3	MODBUS_HOLDING_REGISTER	116	1	h	4	1		24	4			
Return time fan 2	MODBUS_HOLDING_REGISTER	117	1	h	4	1		24	4			
Return time fan 1	MODBUS_HOLDING_REGISTER	118	1	h	4	1		24	4			
Time between filter replacement	MODBUS_HOLDING_REGISTER	119	1		4			1	24	3		
Floor drying	MODBUS_HOLDING_REGISTER	120	1		4	0	1	0				
Floor drying period 7	MODBUS_HOLDING_REGISTER	121	1	days	4	0		30	2			
Floor drying period 6	MODBUS_HOLDING_REGISTER	122	1	days	4	0		30	2			
Floor drying period 5	MODBUS_HOLDING_REGISTER	123	1	days	4	0		30	2			
Floor drying period 4	MODBUS_HOLDING_REGISTER	124	1	days	4	0		30	3			
Floor drying period 3	MODBUS_HOLDING_REGISTER	125	1	days	4	0		30	2			
Floor drying period 2	MODBUS_HOLDING_REGISTER	126	1	days	4	0		30	2			
Floor drying period 1	MODBUS_HOLDING_REGISTER	127	1	days	4	0		30	2			
Floor drying temp. 7	MODBUS_HOLDING_REGISTER	128	1	°C	4	15		70	20			
Floor drying temp. 6	MODBUS_HOLDING_REGISTER	129	1	°C	4	15		70	30			
Floor drying temp. 5	MODBUS_HOLDING_REGISTER	130	1	°C	4	15		70	40			
Floor drying temp. 4	MODBUS_HOLDING_REGISTER	131	1	°C	4	15		70	45			
Floor drying temp. 3	MODBUS_HOLDING_REGISTER	132	1	°C	4	15		70	40			
Floor drying temp. 2	MODBUS_HOLDING_REGISTER	133	1	°C	4	15		70	30			
Floor drying temp. 1	MODBUS_HOLDING_REGISTER	134	1	°C	4	15		70	20			
Floor drying ongoing time.	MODBUS_INPUT_REGISTER	1977	1		5	0		10000	0			
Dimensioned outdoor temperature	MODBUS_HOLDING_REGISTER	140	10	°C	2	-400		200	-180			
Delta T for DOT	MODBUS_HOLDING_REGISTER	141	10	°C	2	10	250	100				
Climate system 2	MODBUS_HOLDING_REGISTER	142	1		4	0		1	0			
Climate system 3	MODBUS_HOLDING_REGISTER	143	1		4	0		1	0			
Climate system 4	MODBUS_HOLDING_REGISTER	144	1		4	0		1	0			
Shunt controlled additional heat	MODBUS_HOLDING_REGISTER	153	1			4		0	1	0		
Wait time shunt, shunt controlled additional heat	MODBUS_HOLDING_REGISTER	157	1			1		s	2	10	300	30
Step controlled additional heat accessory	MODBUS_HOLDING_REGISTER	158	1			4		0	1	0		
DM start step controlled additional heat	MODBUS_HOLDING_REGISTER	159	1	DM		2		-2000	-30	-400		
Waiting time cooling/heating	MODBUS_HOLDING_REGISTER	165	1	h	1	0		48	2			
Heating start at under temp.	MODBUS_HOLDING_REGISTER	166	10	°C	1	5		100	10			
Cooling start at over temp.	MODBUS_HOLDING_REGISTER	167	10	°C	1	5		100	30			
Cooling with room sensors	MODBUS_HOLDING_REGISTER	170	10		4	0		41	0			
Start active cooling DM	MODBUS_HOLDING_REGISTER	173	1	DM	2	10	300	30				
Permit additional heat, heating	MODBUS_HOLDING_REGISTER	180	1		4	0		1	1			
Permit heating	MODBUS_HOLDING_REGISTER	181	1		4	0	1	1				

Permit cooling	MODBUS_HOLDING_REGISTER	182	1	4	0	1	1						
Auto mode, start temperature for cooling	MODBUS_HOLDING_REGISTER	183				10	°C	2	150	400	250		
Auto mode, stop temperature for heating	MODBUS_HOLDING_REGISTER	184			10	°C	2	-200	400	170			
Auto mode, additional heat stop temperature	MODBUS_HOLDING_REGISTER	185			10	°C	2	-250	400	50			
Auto mode filter time	MODBUS_HOLDING_REGISTER	186	1	h	4	0	48	24					
Max difference supply, compressor	MODBUS_HOLDING_REGISTER	187			10	°C	2	10	250	100			
Max difference supply, additional heat	MODBUS_HOLDING_REGISTER	188			10	°C	2	10	240	70			
Time format	MODBUS_HOLDING_REGISTER	194	1	4	0	1	1						
Alarm action, lower room temperature	MODBUS_HOLDING_REGISTER	196			1		4	0	1	0			
Alarm action lower HW temperature	MODBUS_HOLDING_REGISTER	197			1		4	0	1	1			
Auxiliary operation on alarm	MODBUS_HOLDING_REGISTER	198			1		4	0	0	0			
Use room sensor climate system 4	MODBUS_HOLDING_REGISTER	199			1		4	0	1	0			
Use room sensor climate system 3	MODBUS_HOLDING_REGISTER	200			1		4	0	1	0			
Use room sensor climate system 2	MODBUS_HOLDING_REGISTER	201			1		4	0	1	0			
Use room sensor climate system 1	MODBUS_HOLDING_REGISTER	202			1		4	0	1	0			
Room sensor set point value climate system 4	MODBUS_HOLDING_REGISTER	203				10	°C	2	50	300	200		
Room sensor set point value climate system 3	MODBUS_HOLDING_REGISTER	204				10	°C	2	50	300	200		
Room sensor set point value climate system 2	MODBUS_HOLDING_REGISTER	205				10	°C	2	50	300	200		
Room sensor set point value climate system 1	MODBUS_HOLDING_REGISTER	206				10	°C	2	50	300	200		
Room sensor factor climate system 4	MODBUS_HOLDING_REGISTER	207			10		4	0	60	20			
Room sensor factor climate system 3	MODBUS_HOLDING_REGISTER	208			10		4	0	60	20			
Room sensor factor climate system 2	MODBUS_HOLDING_REGISTER	209			10		4	0	60	20			
Room sensor factor climate system 1	MODBUS_HOLDING_REGISTER	210			10		4	0	60	20			
Input AUX5	MODBUS_HOLDING_REGISTER	211	1	4	0	65	0						
Input AUX4	MODBUS_HOLDING_REGISTER	212	1	4	0	65	0						
Input AUX3	MODBUS_HOLDING_REGISTER	213	1	4	0	65	0						
Input AUX2	MODBUS_HOLDING_REGISTER	214	1	4	0	65	0						
Input AUX1	MODBUS_HOLDING_REGISTER	215	1	4	0	65	0						
Output AUX1	MODBUS_HOLDING_REGISTER	216	1	4	0	28	0						
id:3968	MODBUS_HOLDING_REGISTER	2752	1	5	1	3600	5						
Preset flow setting for climate system	MODBUS_HOLDING_REGISTER	223			1		4	0	3	1			
id:3977	MODBUS_HOLDING_REGISTER	2753	1	4	21	22	22						
More hot water	MODBUS_HOLDING_REGISTER	225	10	-	-	-	-						
Night cooling 1	MODBUS_HOLDING_REGISTER	227	1	4	0	1	0						
id:4045	MODBUS_HOLDING_REGISTER	4041	1	°C	1	1	40	8					
id:4046	MODBUS_HOLDING_REGISTER	4043	1	°C	1	0	40	4					
id:4049	MODBUS_HOLDING_REGISTER	4045	1		4	0	1	0					
id:4050	MODBUS_HOLDING_REGISTER	4046	1		4	0	1	0					
id:4051	MODBUS_HOLDING_REGISTER	4047	1		4	0	1	0					
Oper. mode	MODBUS_HOLDING_REGISTER	237	1	4	0	0	0						
Cooling heat sensor set point value	MODBUS_HOLDING_REGISTER	681			10		2	50	400	210			
Pool 1 accessory	MODBUS_HOLDING_REGISTER	685	1		4	0	1	0					
Hot water comfort	MODBUS_HOLDING_REGISTER	694	1		4	0	1	0					
More hot water	MODBUS_HOLDING_REGISTER	697	1	1	0	0	0						
Start diff. DM, step-controlled add. heat	MODBUS_HOLDING_REGISTER	703			1	DM	2	0	2000	400			
HW comfort shunt on/off	MODBUS_HOLDING_REGISTER	705	1		4	0	1	0					
External cooling accessory	MODBUS_HOLDING_REGISTER	709		1		4	0	1	0				

https://raw.githubusercontent.com/yozik04/nibe/master/nibe/data/s320_s325.csv

Climate system 6	MODBUS_HOLDING_REGISTER 906	1	4	0	1	0			
Climate system 7	MODBUS_HOLDING_REGISTER 907	1	4	0	1	0			
Climate system 8	MODBUS_HOLDING_REGISTER 908	1	4	0	1	0			
Heating connected, climate system 1	MODBUS_HOLDING_REGISTER 932	1			4	0	1	1	
ERS 1	MODBUS_HOLDING_REGISTER 933	1	4	0	1	0			
id:4961	MODBUS_HOLDING_REGISTER 4090	1	4	0	3	0			
id:4969	MODBUS_HOLDING_REGISTER 4091	1	4	0	1	0			
id:4970	MODBUS_HOLDING_REGISTER 4092	1	4	0	1	0			
id:4971	MODBUS_HOLDING_REGISTER 4093	1	Hz	4	20	117	20		
id:4972	MODBUS_HOLDING_REGISTER 4094	1	Hz	4	20	117	20		
id:4973	MODBUS_HOLDING_REGISTER 4095	1	Hz	4	23	120	23		
id:4974	MODBUS_HOLDING_REGISTER 4096	1	Hz	4	23	120	23		
id:4992	MODBUS_HOLDING_REGISTER 4097	1		4	-999	999	70		
id:4993	MODBUS_HOLDING_REGISTER 4098	1		4	-999	999	70		
id:4994	MODBUS_HOLDING_REGISTER 4099	1		4	-999	999	70		
id:4995	MODBUS_HOLDING_REGISTER 4100	1		4	-999	999	70		
id:4996	MODBUS_HOLDING_REGISTER 4101	1		4	-999	999	70		
id:4997	MODBUS_HOLDING_REGISTER 4102	1		4	-999	999	75		
Use room sensor climate system 8	MODBUS_HOLDING_REGISTER 948	1			4	0	1	0	
Use room sensor climate system 7	MODBUS_HOLDING_REGISTER 949	1			4	0	1	0	
Use room sensor climate system 6	MODBUS_HOLDING_REGISTER 950	1			4	0	1	0	
Use room sensor climate system 5	MODBUS_HOLDING_REGISTER 951	1			4	0	1	0	
Room sensor set point value climate system 8	MODBUS_HOLDING_REGISTER 952	10	°C	2	50	300	200		
Room sensor set point value climate system 7	MODBUS_HOLDING_REGISTER 953	10	°C	2	50	300	200		
Room sensor set point value climate system 6	MODBUS_HOLDING_REGISTER 954	10	°C	2	50	300	200		
Room sensor set point value climate system 5	MODBUS_HOLDING_REGISTER 955	10	°C	2	50	300	200		
Room sensor factor climate system 8	MODBUS_HOLDING_REGISTER 956	10		4	0	60	20		
Room sensor factor climate system 7	MODBUS_HOLDING_REGISTER 957	10		4	0	60	20		
Room sensor factor climate system 6	MODBUS_HOLDING_REGISTER 958	10		4	0	60	20		
Room sensor factor climate system 5	MODBUS_HOLDING_REGISTER 959	10		4	0	60	20		
Cooling curve climate system 1	MODBUS_HOLDING_REGISTER 967	1		1	0	9	0		
Cooling offset climate system 1	MODBUS_HOLDING_REGISTER 975	1		1	-10	10	0		
Own curve, cooling P4	MODBUS_HOLDING_REGISTER 976	1	°C	1	7	40	20		
Own curve, cooling P2	MODBUS_HOLDING_REGISTER 977	1	°C	1	7	40	20		
Own curve, cooling P1	MODBUS_HOLDING_REGISTER 978	1	°C	1	7	40	20		
Current transformer ratio	MODBUS_HOLDING_REGISTER 980	1		5	300	3000	300		
Room sensor set point value climate system 8, cooling	MODBUS_HOLDING_REGISTER 981	10	°C	2	50	350	250		
Room sensor set point value climate system 7, cooling	MODBUS_HOLDING_REGISTER 982	10	°C	2	50	350	250		
Room sensor set point value climate system 6, cooling	MODBUS_HOLDING_REGISTER 983	10	°C	2	50	350	250		
Room sensor set point value climate system 5, cooling	MODBUS_HOLDING_REGISTER 984	10	°C	2	50	350	250		
Room sensor set point value climate system 4, cooling	MODBUS_HOLDING_REGISTER 985	10	°C	2	50	350	250		
Room sensor set point value climate system 3, cooling	MODBUS_HOLDING_REGISTER 986	10	°C	2	50	350	250		
Room sensor set point value climate system 2, cooling	MODBUS_HOLDING_REGISTER 987	10	°C	2	50	350	250		
Room sensor set point value climate system 1, cooling	MODBUS_HOLDING_REGISTER 988	10	°C	2	50	350	250		
Room sensor factor climate system 8, cooling	MODBUS_HOLDING_REGISTER 989	10		4	0	60	10		
Room sensor factor climate system 7, cooling	MODBUS_HOLDING_REGISTER 990	10		4	0	60	10		
Room sensor factor climate system 6, cooling	MODBUS_HOLDING_REGISTER 991	10		4	0	60	10		

Room sensor factor climate system 5, cooling	MODBUS_HOLDING_REGISTER	992	10		4	0	60	10
Room sensor factor climate system 4, cooling	MODBUS_HOLDING_REGISTER	993	10		4	0	60	10
Room sensor factor climate system 3, cooling	MODBUS_HOLDING_REGISTER	994	10		4	0	60	10
Room sensor factor climate system 2, cooling	MODBUS_HOLDING_REGISTER	995	10		4	0	60	10
Room sensor factor climate system 1, cooling	MODBUS_HOLDING_REGISTER	996	10		4	0	60	10
Set point value (RH)	MODBUS_HOLDING_REGISTER	997	1	%	1	30	90	60
HTS 1	MODBUS_HOLDING_REGISTER	998	1	4	0	1	0	
OPT	MODBUS_HOLDING_REGISTER	1015	1	4	0	1	0	
DM start difference (OPT)	MODBUS_HOLDING_REGISTER	1016	1	DM	2	10	2000	700
Exhaust air fan speed 4 (ERS 1)	MODBUS_HOLDING_REGISTER	1021	1	%	4	0	100	100
Exhaust air fan speed 3 (ERS 1)	MODBUS_HOLDING_REGISTER	1022	1	%	4	0	100	80
Exhaust air fan speed 2 (ERS 1)	MODBUS_HOLDING_REGISTER	1023	1	%	4	0	100	30
Exhaust air fan speed 1 (ERS 1)	MODBUS_HOLDING_REGISTER	1024	1	%	4	0	100	0
Exhaust air fan speed normal (ERS 1)	MODBUS_HOLDING_REGISTER	1025	1	%	4	1	100	75
S135	MODBUS_HOLDING_REGISTER	1035	1	4	0	1	0	
Pump speed (S135)	MODBUS_HOLDING_REGISTER	1036	1	%	4	1	100	70
Supply air fan speed 4 (ERS 1)	MODBUS_HOLDING_REGISTER	1038	1	%	4	0	100	100
Supply air fan speed 3 (ERS 1)	MODBUS_HOLDING_REGISTER	1039	1	%	4	0	100	80
Supply air fan speed 2 (ERS 1)	MODBUS_HOLDING_REGISTER	1040	1	%	4	0	100	30
Supply air fan speed 1 (ERS 1)	MODBUS_HOLDING_REGISTER	1041	1	%	4	0	100	0
Supply air fan speed normal (ERS 1)	MODBUS_HOLDING_REGISTER	1042	1	%	4	1	100	60
Min. vent temp. (ERS 1)	MODBUS_HOLDING_REGISTER	1043	1	°C	4	0	10	3
Bypass temp. (ERS 1)	MODBUS_HOLDING_REGISTER	1044	1	°C	4	2	10	4
Pool pump type	MODBUS_HOLDING_REGISTER	1045	1	4	0	1	1	
External cooling accessory pump type	MODBUS_HOLDING_REGISTER	1046	1		4	0	1	1
Flow sensor activated X21	MODBUS_HOLDING_REGISTER	1031	1		4	0	1	0
Flow sensor activated X22	MODBUS_HOLDING_REGISTER	1049	1		4	0	1	0
Max. internal additional heat SG Ready	MODBUS_HOLDING_REGISTER	1052	100	kW	2	0	900	900
Hysteresis (OPT)	MODBUS_HOLDING_REGISTER	1066	1	2	10	2000	100	
Activated (EME10)	MODBUS_HOLDING_REGISTER	1068	1	4	0	1	0	
PV panel affects heating (EME)	MODBUS_HOLDING_REGISTER	1069	1	4	0	1	0	
PV panel affects hot water (EME)	MODBUS_HOLDING_REGISTER	1070	1		4	0	1	0
Delay timer EME	MODBUS_HOLDING_REGISTER	1071	1	5	0	0	0	
AUX blocking (OPT)	MODBUS_HOLDING_REGISTER	1095	1	4	0	0	0	
Outdoor air mixing	MODBUS_HOLDING_REGISTER	1096	1	4	0	1	0	
Smart home room control	MODBUS_HOLDING_REGISTER	1102	1	4	0	1	0	
Smart Energy Source	MODBUS_HOLDING_REGISTER	1105	1	4	0	1	0	
Control method, smart energy source	MODBUS_HOLDING_REGISTER	1106	1		4	0	1	0
El. price, special, smart energy source	MODBUS_HOLDING_REGISTER	1107	1		4	0	2	0
El. price, fixed, smart energy source	MODBUS_HOLDING_REGISTER	1108	1		5	0	10000	100
El. price, smart energy source	MODBUS_HOLDING_REGISTER	1109	1	4	0	1	0	
El. price, fixed, smart energy source	MODBUS_HOLDING_REGISTER	1110	1		5	0	10000	100
El. price, smart energy source	MODBUS_HOLDING_REGISTER	1111	1	4	0	1	0	
El. price, fixed, smart energy source	MODBUS_HOLDING_REGISTER	1112	1		5	0	10000	100
El. price, smart energy source	MODBUS_HOLDING_REGISTER	1113	1	4	0	1	0	
El. price, fixed, smart energy source	MODBUS_HOLDING_REGISTER	1114	1		5	0	10000	100
El. price, smart energy source	MODBUS_HOLDING_REGISTER	1115	1	4	0	1	0	

El. price, fixed, smart energy source	MODBUS_HOLDING_REGISTER	1116	1	5	0	10000	100		
Prim. factor, smart energy source	MODBUS_HOLDING_REGISTER	1117	10	4	0	50	25		
Prim. factor, shunt add. heat smart energy source	MODBUS_HOLDING_REGISTER	1118	10	10		4	0	50	10
Prim. factor, ext. step add. heat smart energy source	MODBUS_HOLDING_REGISTER	1119	10	10		4	0	50	10
Prim. factor, OPT10 smart energy source	MODBUS_HOLDING_REGISTER	1120	10	4	0	50	10		
OPT10, high tariff price smart energy source	MODBUS_HOLDING_REGISTER	1121	1		5	1	10000	100	
OPT10, low tariff price smart energy source	MODBUS_HOLDING_REGISTER	1122	1		5	1	10000	100	
ext. step add. heat, high tariff price smart energy source	MODBUS_HOLDING_REGISTER	1123		1		5	1	10000	100
ext. step add. heat, low tariff price smart energy source	MODBUS_HOLDING_REGISTER	1124		1		5	1	10000	100
Shunt add. heat, high tariff price smart energy source	MODBUS_HOLDING_REGISTER	1125		1		5	1	10000	100
Shunt add. heat, low tariff price smart energy source	MODBUS_HOLDING_REGISTER	1126		1		5	1	10000	100
El. price, fixed, high tariff smart energy source	MODBUS_HOLDING_REGISTER	1127		1		5	1	10000	100
El. price, fixed, low tariff smart energy source	MODBUS_HOLDING_REGISTER	1128		1		5	1	10000	100
El. price, variable, high tariff smart energy source	MODBUS_HOLDING_REGISTER	1129		1		5	1	10000	100
El. price, variable, low tariff smart energy source	MODBUS_HOLDING_REGISTER	1130		1		5	1	10000	100
DM start source, priority 5 smart energy source	MODBUS_HOLDING_REGISTER	1131	1		2	100	2000	400	
DM start source, priority 4 smart energy source	MODBUS_HOLDING_REGISTER	1132	1		2	100	2000	400	
DM start source, priority 3 smart energy source	MODBUS_HOLDING_REGISTER	1133	1		2	100	2000	400	
DM start source, priority 2 smart energy source	MODBUS_HOLDING_REGISTER	1134	1		2	100	2000	400	
DM start source, priority 1 smart energy source	MODBUS_HOLDING_REGISTER	1135	1		2	-2000	-10	-60	
Start day, tariff smart energy source	MODBUS_HOLDING_REGISTER	1136	1	4	1	31	1		
End day, tariff smart energy source	MODBUS_HOLDING_REGISTER	1137	1	4	1	31	31		
Start month, tariff smart energy source	MODBUS_HOLDING_REGISTER	1138	1	4	1	12	1		
End month, tariff smart energy source	MODBUS_HOLDING_REGISTER	1139	1	4	1	12	12		
Start day, fixed tariff smart energy source	MODBUS_HOLDING_REGISTER	1172	1		4	1	31	1	
End day, fixed tariff smart energy source	MODBUS_HOLDING_REGISTER	1173	1		4	1	31	31	
Start month, fixed tariff smart energy source	MODBUS_HOLDING_REGISTER	1174	1		4	1	12	1	
End month, fixed tariff smart energy source	MODBUS_HOLDING_REGISTER	1175	1		4	1	12	12	
Start day, tariff OPT10 smart energy source	MODBUS_HOLDING_REGISTER	1208	1		4	1	31	1	
End day, tariff OPT10 smart energy source	MODBUS_HOLDING_REGISTER	1209	1		4	1	31	31	
Start month, tariff OPT10 smart energy source	MODBUS_HOLDING_REGISTER	1210	1		4	1	12	1	
End month, tariff OPT10 smart energy source	MODBUS_HOLDING_REGISTER	1211	1		4	1	12	12	
Start day tariff, shunt additional heat smart energy source	MODBUS_HOLDING_REGISTER	1244		1		4	1	31	1
End day tariff, shunt additional heat smart energy source	MODBUS_HOLDING_REGISTER	1245		1		4	1	31	31
Start month tariff, shunt additional heat smart energy source	MODBUS_HOLDING_REGISTER	1246		1		4	1	12	1
End month tariff, shunt additional heat smart energy source	MODBUS_HOLDING_REGISTER	1247		1		4	1	12	12
Start day tariff, ext. step add. heat smart energy source	MODBUS_HOLDING_REGISTER	1280		1		4	1	31	1
End day tariff, ext. step add. heat smart energy source	MODBUS_HOLDING_REGISTER	1281		1		4	1	31	31
Start month tariff, ext. step add. heat smart energy source	MODBUS_HOLDING_REGISTER	1282		1		4	1	12	1
End month tariff, ext. step add. heat smart energy source	MODBUS_HOLDING_REGISTER	1283		1		4	1	12	12
Prioritise additional heat (AXC40)	MODBUS_HOLDING_REGISTER	1320	1	4	0	1	0		
Max difference, SES priority 1 energy source	MODBUS_HOLDING_REGISTER	1326	10	°C	2	10	250	100	
Max difference, SES lower priority energy source	MODBUS_HOLDING_REGISTER	1327	10	°C	2	10	250	70	
Forced control (AZ30-GQ2)	MODBUS_HOLDING_REGISTER	5029	1	%	4	0	100	50	
Forced control (AZ30-GQ3)	MODBUS_HOLDING_REGISTER	5030	1	%	4	0	100	50	
Installed (EB101)	MODBUS_HOLDING_REGISTER	1550	1	4	0	1	1		
EME20	MODBUS_HOLDING_REGISTER	4000	1	4	0	1	0		

https://raw.githubusercontent.com/yozik04/nibe/master/nibe/data/s320_s325.csv

blockFreq 1 (EB108)	MODBUS_HOLDING_REGISTER	4170	1		4	0	1	0			
id:6977	MODBUS_HOLDING_REGISTER	4201	1	4	0	100	0				
Power at DOT, manual value	MODBUS_HOLDING_REGISTER	4200	1			4	0	1	0		
ERS 1	MODBUS_HOLDING_REGISTER	4094	1	4	0	1	1				
Blocking actions (ERS 3)	MODBUS_HOLDING_REGISTER	4100	1			4	0	2	2		
Blocking actions (ERS 4)	MODBUS_HOLDING_REGISTER	4101	1			4	0	2	2		
id:7048	MODBUS_HOLDING_REGISTER	3987	1	4	0	1	0				
id:7138	MODBUS_HOLDING_REGISTER	4009	1	%	4	0	100	70			
id:7139	MODBUS_HOLDING_REGISTER	4010	1		4	0	1	0			
id:7140	MODBUS_HOLDING_REGISTER	4011	1		4	0	1	0			
id:7141	MODBUS_HOLDING_REGISTER	4012	1	%	4	0	100	70			
id:7142	MODBUS_HOLDING_REGISTER	4013	1		4	0	1	0			
id:7143	MODBUS_HOLDING_REGISTER	4014	1		4	0	1	0			
id:7144	MODBUS_HOLDING_REGISTER	4015	1	%	4	0	100	70			
id:7145	MODBUS_HOLDING_REGISTER	4016	1		4	0	1	0			
id:7146	MODBUS_HOLDING_REGISTER	4017	1		4	0	1	0			
id:7147	MODBUS_HOLDING_REGISTER	4018	1	%	4	0	100	70			
id:7148	MODBUS_HOLDING_REGISTER	4019	1		4	0	1	0			
id:7149	MODBUS_HOLDING_REGISTER	4020	1		4	0	1	0			
id:7150	MODBUS_HOLDING_REGISTER	4021	1	%	4	0	100	70			
id:7176	MODBUS_HOLDING_REGISTER	4023	1		4	0	1	0			
Night cooling 1	MODBUS_HOLDING_REGISTER	2955	1	4	0	1	0				
Start temperature night cooling 1	MODBUS_HOLDING_REGISTER	2942	1	°C	4	3	10	6	20	30	25
Night cooling diff	MODBUS_HOLDING_REGISTER	2943	1	°C	4	3	10	6			
id:8002	MODBUS_HOLDING_REGISTER	1996	1	%	4	-15	10	-3			
id:8003	MODBUS_HOLDING_REGISTER	1997	1	%	4	1	254	65			
Minimum permitted speed (EB101 GP12)	MODBUS_HOLDING_REGISTER	3243	1	%	4	1	0	1	50	1	
Start fan de-icing (EB101)	MODBUS_HOLDING_REGISTER	3251	1		1	0	1	0			
id:8060	MODBUS_HOLDING_REGISTER	3259	1	1	0	1	0				
id:8061	MODBUS_HOLDING_REGISTER	3260	1	1	0	1	0				
id:8062	MODBUS_HOLDING_REGISTER	3261	1	1	0	1	0				
id:8063	MODBUS_HOLDING_REGISTER	3262	1	1	0	1	0				
id:8064	MODBUS_HOLDING_REGISTER	3263	1	1	0	1	0				
id:8065	MODBUS_HOLDING_REGISTER	3264	1	1	0	1	0				
id:8066	MODBUS_HOLDING_REGISTER	3265	1	1	0	1	0				
id:8067	MODBUS_HOLDING_REGISTER	3266	1	1	0	1	0				
Increased ventilation 1	MODBUS_HOLDING_REGISTER	3627	1		4	0	0	0			
System 1 (RMU)	MODBUS_HOLDING_REGISTER	176	1	4	0	1	0				
System 2 (RMU)	MODBUS_HOLDING_REGISTER	177	1	4	0	1	0				
System 3 (RMU)	MODBUS_HOLDING_REGISTER	178	1	4	0	1	0				
System 4 (RMU)	MODBUS_HOLDING_REGISTER	179	1	4	0	1	0				
System 4 (RMU)	MODBUS_HOLDING_REGISTER	1998	1	4	0	1	0				
System 4 (RMU)	MODBUS_HOLDING_REGISTER	1999	1	4	0	1	0				
System 4 (RMU)	MODBUS_HOLDING_REGISTER	2000	1	4	0	1	0				
System 4 (RMU)	MODBUS_HOLDING_REGISTER	2001	1	4	0	1	0				
id:8982	MODBUS_HOLDING_REGISTER	3346	1	4	0	0	0				
The start guide has been run	MODBUS_HOLDING_REGISTER	2742	1		4	0	1	1			

Audio signal on alarm	MODBUS_HOLDING_REGISTER	3232	1		4	0	1	1	
Sound when pressing button	MODBUS_HOLDING_REGISTER	3233	1			4	0	1	1
BT12 offset, heat pump 1	MODBUS_HOLDING_REGISTER	3234	10	°C		1	-50	50	0
Heating, auto	MODBUS_HOLDING_REGISTER	3059	1		4	0	1	1	
Cooling, auto	MODBUS_HOLDING_REGISTER	3060	1		4	0	1	1	
Factor	MODBUS_HOLDING_REGISTER	3033	1	4	1	10	5		
Fan speed ERS1 (GQ2)	MODBUS_INPUT_REGISTER	2251	1	%	4	0	0	0	
Fan speed ERS1 (GQ3)	MODBUS_INPUT_REGISTER	2252	1	%	4	0	0	0	
id:10881	MODBUS_HOLDING_REGISTER	3062	1		4	0	1	0	
id:10890	MODBUS_HOLDING_REGISTER	3063	1		4	0	1	0	
Hot water start (BT5)	MODBUS_INPUT_REGISTER	2014	10	°C		2	0	0	0
Pump: Heating medium (GP6)	MODBUS_INPUT_REGISTER	2128	1			4	0	0	0
id:12332	MODBUS_HOLDING_REGISTER	2767	1	2	-600	600	-32768		
id:12333	MODBUS_HOLDING_REGISTER	2768	1	2	-600	600	-32768		
id:12334	MODBUS_HOLDING_REGISTER	2769	1	2	-600	600	-32768		
id:12335	MODBUS_HOLDING_REGISTER	2770	1	2	-600	600	-32768		
id:12336	MODBUS_HOLDING_REGISTER	2771	1	2	-600	600	-32768		
id:12337	MODBUS_HOLDING_REGISTER	2772	1	2	-600	600	-32768		
id:12338	MODBUS_HOLDING_REGISTER	2773	1	2	-600	600	-32768		
id:12339	MODBUS_HOLDING_REGISTER	2774	1	2	-600	600	-32768		
id:12340	MODBUS_HOLDING_REGISTER	2775	1	2	-600	600	-32768		
id:12341	MODBUS_HOLDING_REGISTER	2776	1	2	-600	600	-32768		
id:12342	MODBUS_HOLDING_REGISTER	2777	1	2	-600	600	-32768		
id:12343	MODBUS_HOLDING_REGISTER	2778	1	2	-600	600	-32768		
id:12344	MODBUS_HOLDING_REGISTER	2779	1	2	-600	600	-32768		
id:12345	MODBUS_HOLDING_REGISTER	2780	1	2	-600	600	-32768		
id:12346	MODBUS_HOLDING_REGISTER	2781	1	2	-600	600	-32768		
id:12347	MODBUS_HOLDING_REGISTER	2782	1	2	-600	600	-32768		
id:12348	MODBUS_HOLDING_REGISTER	2783	1	2	-600	600	-32768		
id:12349	MODBUS_HOLDING_REGISTER	2784	1	2	-600	600	-32768		
id:12350	MODBUS_HOLDING_REGISTER	2785	1	2	-600	600	-32768		
id:12351	MODBUS_HOLDING_REGISTER	2786	1	2	-600	600	-32768		
id:12352	MODBUS_HOLDING_REGISTER	2787	1	2	-600	600	-32768		
id:12353	MODBUS_HOLDING_REGISTER	2788	1	2	-600	600	-32768		
id:12354	MODBUS_HOLDING_REGISTER	2789	1	2	-600	600	-32768		
id:12355	MODBUS_HOLDING_REGISTER	2790	1	2	-600	600	-32768		
id:12356	MODBUS_HOLDING_REGISTER	2791	1	2	-600	600	-32768		
id:12357	MODBUS_HOLDING_REGISTER	2792	1	2	-600	600	-32768		
id:12358	MODBUS_HOLDING_REGISTER	2793	1	2	-600	600	-32768		
id:12359	MODBUS_HOLDING_REGISTER	2794	1	2	-600	600	-32768		
id:12360	MODBUS_HOLDING_REGISTER	2795	1	2	-600	600	-32768		
id:12361	MODBUS_HOLDING_REGISTER	2796	1	2	-600	600	-32768		
id:12362	MODBUS_HOLDING_REGISTER	2797	1	2	-600	600	-32768		
id:12363	MODBUS_HOLDING_REGISTER	2798	1	2	-600	600	-32768		
id:12364	MODBUS_HOLDING_REGISTER	2799	1	2	-600	600	-32768		
id:12365	MODBUS_HOLDING_REGISTER	2800	1	2	-600	600	-32768		
id:12366	MODBUS_HOLDING_REGISTER	2801	1	2	-600	600	-32768		

id:12367	MODBUS_HOLDING_REGISTER	2802	1		2	-600	600	-32768		
id:12368	MODBUS_HOLDING_REGISTER	2803	1		2	-600	600	-32768		
id:12369	MODBUS_HOLDING_REGISTER	2804	1		2	-600	600	-32768		
id:12370	MODBUS_HOLDING_REGISTER	2805	1		2	-600	600	-32768		
id:12371	MODBUS_HOLDING_REGISTER	2806	1		2	-600	600	-32768		
id:12372	MODBUS_HOLDING_REGISTER	2807	1		2	-600	600	-32768		
id:12373	MODBUS_HOLDING_REGISTER	2808	1		2	-600	600	-32768		
id:12374	MODBUS_HOLDING_REGISTER	2809	1		2	-600	600	-32768		
id:12375	MODBUS_HOLDING_REGISTER	2810	1		2	-600	600	-32768		
id:12376	MODBUS_HOLDING_REGISTER	2811	1		2	-600	600	-32768		
id:12377	MODBUS_HOLDING_REGISTER	2812	1		2	-600	600	-32768		
id:12378	MODBUS_HOLDING_REGISTER	2813	1		2	-600	600	-32768		
id:12379	MODBUS_HOLDING_REGISTER	2814	1		2	-600	600	-32768		
id:12380	MODBUS_HOLDING_REGISTER	2815	1		2	-600	600	-32768		
id:12381	MODBUS_HOLDING_REGISTER	2816	1		2	-600	600	-32768		
id:12382	MODBUS_HOLDING_REGISTER	2817	1		2	-600	600	-32768		
id:12383	MODBUS_HOLDING_REGISTER	2818	1		2	-600	600	-32768		
id:12384	MODBUS_HOLDING_REGISTER	2819	1		2	-600	600	-32768		
Period	MODBUS_HOLDING_REGISTER	3088	1	4	0	1	0			
Number of years	MODBUS_HOLDING_REGISTER	3089	1		4	1	10	1		
Months	MODBUS_HOLDING_REGISTER	3090	1	6	0	4095	4095			
id:12388	MODBUS_HOLDING_REGISTER	3092	1		4	0	0	0		
id:12391	MODBUS_HOLDING_REGISTER	3095	1		4	0	0	0		
Show outdoor temperature	MODBUS_HOLDING_REGISTER	3096	1		4	0	0	0	0	
Show indoor temperature	MODBUS_HOLDING_REGISTER	3097	1		4	0	0	0	0	
Active days	MODBUS_HOLDING_REGISTER	3066	1		4	0	127	0		
Active days	MODBUS_HOLDING_REGISTER	3067	1		4	0	127	0		
Active days	MODBUS_HOLDING_REGISTER	3068	1		4	0	127	0		
Active days	MODBUS_HOLDING_REGISTER	3069	1		4	0	127	0		
Active days	MODBUS_HOLDING_REGISTER	3070	1		4	0	127	0		
Start time	MODBUS_HOLDING_REGISTER	3071	1		-	-	-	-		
Start time	MODBUS_HOLDING_REGISTER	3073	1		-	-	-	-		
Stop time	MODBUS_HOLDING_REGISTER	3075	1		-	-	-	-		
id:12650	MODBUS_HOLDING_REGISTER	3104	1		-	-	-	-		
id:12651	MODBUS_HOLDING_REGISTER	3144	1		-	-	-	-		
id:12652	MODBUS_HOLDING_REGISTER	3184	1		-	-	-	-		
id:12653	MODBUS_HOLDING_REGISTER	3224	1		-	-	-	-		
id:12654	MODBUS_HOLDING_REGISTER	3264	1		-	-	-	-		
id:12655	MODBUS_HOLDING_REGISTER	3304	1		-	-	-	-		
id:12656	MODBUS_HOLDING_REGISTER	3344	1		-	-	-	-		
id:12657	MODBUS_HOLDING_REGISTER	3384	1		-	-	-	-		
id:12658	MODBUS_HOLDING_REGISTER	3424	1		-	-	-	-		
id:12659	MODBUS_HOLDING_REGISTER	3464	1		-	-	-	-		
id:12660	MODBUS_HOLDING_REGISTER	3504	1		-	-	-	-		
id:12661	MODBUS_HOLDING_REGISTER	3544	1		-	-	-	-		
id:12662	MODBUS_HOLDING_REGISTER	3584	1		-	-	-	-		
id:12663	MODBUS_HOLDING_REGISTER	3624	1		-	-	-	-		

id:12664	MODBUS_HOLDING_REGISTER	3664	1	-	-	-	-
id:12665	MODBUS_HOLDING_REGISTER	3704	1	-	-	-	-
id:12666	MODBUS_HOLDING_REGISTER	3744	1	-	-	-	-
id:12667	MODBUS_HOLDING_REGISTER	3784	1	-	-	-	-
id:12668	MODBUS_HOLDING_REGISTER	3824	1	-	-	-	-
id:12669	MODBUS_HOLDING_REGISTER	3864	1	-	-	-	-
id:12670	MODBUS_HOLDING_REGISTER	3904	1	-	-	-	-
id:12671	MODBUS_HOLDING_REGISTER	2978	1	4	0	3	0
id:12672	MODBUS_HOLDING_REGISTER	2979	1	4	0	3	0
id:12673	MODBUS_HOLDING_REGISTER	2980	1	4	0	3	0
id:12674	MODBUS_HOLDING_REGISTER	2981	1	4	0	3	0
id:12675	MODBUS_HOLDING_REGISTER	2982	1	4	0	3	0
id:12676	MODBUS_HOLDING_REGISTER	2983	1	4	0	3	0
id:12677	MODBUS_HOLDING_REGISTER	2984	1	4	0	3	0
id:12678	MODBUS_HOLDING_REGISTER	2985	1	4	0	3	0
id:12679	MODBUS_HOLDING_REGISTER	2986	1	4	0	15	0
id:12680	MODBUS_HOLDING_REGISTER	2987	1	4	0	15	0
id:12681	MODBUS_HOLDING_REGISTER	2988	1	4	0	15	0
id:12682	MODBUS_HOLDING_REGISTER	2989	1	4	0	15	0
id:12683	MODBUS_HOLDING_REGISTER	2990	1	4	0	15	0
id:12684	MODBUS_HOLDING_REGISTER	2991	1	4	0	15	0
id:12685	MODBUS_HOLDING_REGISTER	2992	1	4	0	15	0
id:12686	MODBUS_HOLDING_REGISTER	2993	1	4	0	15	0
id:12687	MODBUS_HOLDING_REGISTER	2994	1	4	0	15	0
id:12688	MODBUS_HOLDING_REGISTER	2995	1	4	0	15	0
id:12689	MODBUS_HOLDING_REGISTER	2996	1	4	0	15	0
id:12690	MODBUS_HOLDING_REGISTER	2997	1	4	0	15	0
id:12691	MODBUS_HOLDING_REGISTER	2998	1	4	0	3	0
id:12692	MODBUS_HOLDING_REGISTER	3944	1	6	0	0	0
id:12693	MODBUS_HOLDING_REGISTER	3946	1	6	0	0	0
id:12694	MODBUS_HOLDING_REGISTER	3948	1	6	0	0	0
id:12695	MODBUS_HOLDING_REGISTER	3950	1	6	0	0	0
id:12696	MODBUS_HOLDING_REGISTER	3952	1	6	0	0	0
id:12697	MODBUS_HOLDING_REGISTER	3954	1	6	0	0	0
id:12698	MODBUS_HOLDING_REGISTER	3956	1	6	0	0	0
id:12699	MODBUS_HOLDING_REGISTER	3958	1	6	0	0	0
id:12700	MODBUS_HOLDING_REGISTER	3960	1	6	0	0	0
id:12701	MODBUS_HOLDING_REGISTER	3962	1	6	0	0	0
id:12702	MODBUS_HOLDING_REGISTER	3964	1	6	0	0	0
id:12703	MODBUS_HOLDING_REGISTER	3966	1	6	0	0	0
id:12704	MODBUS_HOLDING_REGISTER	3968	1	6	0	0	0
id:12705	MODBUS_HOLDING_REGISTER	3970	1	6	0	0	0
id:12706	MODBUS_HOLDING_REGISTER	3972	1	6	0	0	0
id:12707	MODBUS_HOLDING_REGISTER	3974	1	6	0	0	0
id:12708	MODBUS_HOLDING_REGISTER	3976	1	6	0	0	0
id:12709	MODBUS_HOLDING_REGISTER	3978	1	6	0	0	0
id:12710	MODBUS_HOLDING_REGISTER	3980	1	6	0	0	0

id:12711	MODBUS_HOLDING_REGISTER	3982	1		6	0	0	0
id:12712	MODBUS_HOLDING_REGISTER	3984	1		6	0	0	0
id:12801	MODBUS_HOLDING_REGISTER	2505	10	°C	3	50	300	200
id:12802	MODBUS_HOLDING_REGISTER	2507	10	°C	3	50	300	200
id:12803	MODBUS_HOLDING_REGISTER	2509	10	°C	3	50	300	200
id:12804	MODBUS_HOLDING_REGISTER	2511	10	°C	3	50	300	200
id:12805	MODBUS_HOLDING_REGISTER	2513	10	°C	3	50	300	200
id:12806	MODBUS_HOLDING_REGISTER	2515	10	°C	3	50	300	200
id:12807	MODBUS_HOLDING_REGISTER	2517	10	°C	3	50	300	200
id:12808	MODBUS_HOLDING_REGISTER	2519	10	°C	3	50	300	200
id:12809	MODBUS_HOLDING_REGISTER	2521	10	°C	3	50	300	200
id:12810	MODBUS_HOLDING_REGISTER	2523	10	°C	3	50	300	200
id:12811	MODBUS_HOLDING_REGISTER	2525	10	°C	3	50	300	200
id:12812	MODBUS_HOLDING_REGISTER	2527	10	°C	3	50	300	200
id:12813	MODBUS_HOLDING_REGISTER	2529	10	°C	3	50	300	200
id:12814	MODBUS_HOLDING_REGISTER	2531	10	°C	3	50	300	200
id:12815	MODBUS_HOLDING_REGISTER	2533	10	°C	3	50	300	200
id:12816	MODBUS_HOLDING_REGISTER	2535	10	°C	3	50	300	200
id:12817	MODBUS_HOLDING_REGISTER	2537	10	°C	3	50	300	200
id:12818	MODBUS_HOLDING_REGISTER	2539	10	°C	3	50	300	200
id:12819	MODBUS_HOLDING_REGISTER	2541	10	°C	3	50	300	200
id:12820	MODBUS_HOLDING_REGISTER	2543	10	°C	3	50	300	200
id:12821	MODBUS_HOLDING_REGISTER	2545	10	°C	3	50	300	200
id:12822	MODBUS_HOLDING_REGISTER	2547	10	°C	3	50	300	200
id:12823	MODBUS_HOLDING_REGISTER	2549	10	°C	3	50	300	200
id:12824	MODBUS_HOLDING_REGISTER	2551	10	°C	3	50	300	200
id:12825	MODBUS_HOLDING_REGISTER	2553	10	°C	3	50	300	200
id:12826	MODBUS_HOLDING_REGISTER	2555	10	°C	3	50	300	200
id:12827	MODBUS_HOLDING_REGISTER	2557	10	°C	3	50	300	200
id:12828	MODBUS_HOLDING_REGISTER	2559	10	°C	3	50	300	200
id:12829	MODBUS_HOLDING_REGISTER	2561	10	°C	3	50	300	200
id:12830	MODBUS_HOLDING_REGISTER	2563	10	°C	3	50	300	200
id:12831	MODBUS_HOLDING_REGISTER	2565	10	°C	3	50	300	200
id:12832	MODBUS_HOLDING_REGISTER	2567	10	°C	3	50	300	200
id:12833	MODBUS_HOLDING_REGISTER	2569	10	°C	3	50	300	200
id:12834	MODBUS_HOLDING_REGISTER	2571	10	°C	3	50	300	200
id:12835	MODBUS_HOLDING_REGISTER	2573	10	°C	3	50	300	200
id:12836	MODBUS_HOLDING_REGISTER	2575	10	°C	3	50	300	200
id:12837	MODBUS_HOLDING_REGISTER	2577	10	°C	3	50	300	200
id:12838	MODBUS_HOLDING_REGISTER	2579	10	°C	3	50	300	200
id:12839	MODBUS_HOLDING_REGISTER	2581	10	°C	3	50	300	200
id:12840	MODBUS_HOLDING_REGISTER	2583	10	°C	3	50	300	200
id:12841	MODBUS_HOLDING_REGISTER	2585	10	°C	3	50	300	250
id:12842	MODBUS_HOLDING_REGISTER	2587	10	°C	3	50	300	250
id:12843	MODBUS_HOLDING_REGISTER	2589	10	°C	3	50	300	250
id:12844	MODBUS_HOLDING_REGISTER	2591	10	°C	3	50	300	250
id:12845	MODBUS_HOLDING_REGISTER	2593	10	°C	3	50	300	250

id:12846	MODBUS_HOLDING_REGISTER	2595	10	°C	3	50	300	250	
id:12847	MODBUS_HOLDING_REGISTER	2597	10	°C	3	50	300	250	
id:12848	MODBUS_HOLDING_REGISTER	2599	10	°C	3	50	300	250	
id:12849	MODBUS_HOLDING_REGISTER	2601	10	°C	3	50	300	250	
id:12850	MODBUS_HOLDING_REGISTER	2603	10	°C	3	50	300	250	
id:12851	MODBUS_HOLDING_REGISTER	2605	10	°C	3	50	300	250	
id:12852	MODBUS_HOLDING_REGISTER	2607	10	°C	3	50	300	250	
id:12853	MODBUS_HOLDING_REGISTER	2609	10	°C	3	50	300	250	
id:12854	MODBUS_HOLDING_REGISTER	2611	10	°C	3	50	300	250	
id:12855	MODBUS_HOLDING_REGISTER	2613	10	°C	3	50	300	250	
id:12856	MODBUS_HOLDING_REGISTER	2615	10	°C	3	50	300	250	
id:12857	MODBUS_HOLDING_REGISTER	2617	10	°C	3	50	300	250	
id:12858	MODBUS_HOLDING_REGISTER	2619	10	°C	3	50	300	250	
id:12859	MODBUS_HOLDING_REGISTER	2621	10	°C	3	50	300	250	
id:12860	MODBUS_HOLDING_REGISTER	2623	10	°C	3	50	300	250	
id:12861	MODBUS_HOLDING_REGISTER	2625	10	°C	3	50	300	250	
id:12862	MODBUS_HOLDING_REGISTER	2627	10	°C	3	50	300	250	
id:12863	MODBUS_HOLDING_REGISTER	2629	10	°C	3	50	300	250	
id:12864	MODBUS_HOLDING_REGISTER	2631	10	°C	3	50	300	250	
id:12865	MODBUS_HOLDING_REGISTER	2633	10	°C	3	50	300	250	
id:12866	MODBUS_HOLDING_REGISTER	2635	10	°C	3	50	300	250	
id:12867	MODBUS_HOLDING_REGISTER	2637	10	°C	3	50	300	250	
id:12868	MODBUS_HOLDING_REGISTER	2639	10	°C	3	50	300	250	
id:12869	MODBUS_HOLDING_REGISTER	2641	10	°C	3	50	300	250	
id:12870	MODBUS_HOLDING_REGISTER	2643	10	°C	3	50	300	250	
id:12871	MODBUS_HOLDING_REGISTER	2645	10	°C	3	50	300	250	
id:12872	MODBUS_HOLDING_REGISTER	2647	10	°C	3	50	300	250	
id:12873	MODBUS_HOLDING_REGISTER	2649	10	°C	3	50	300	250	
id:12874	MODBUS_HOLDING_REGISTER	2651	10	°C	3	50	300	250	
id:12875	MODBUS_HOLDING_REGISTER	2653	10	°C	3	50	300	250	
id:12876	MODBUS_HOLDING_REGISTER	2655	10	°C	3	50	300	250	
id:12877	MODBUS_HOLDING_REGISTER	2657	10	°C	3	50	300	250	
id:12878	MODBUS_HOLDING_REGISTER	2659	10	°C	3	50	300	250	
id:12879	MODBUS_HOLDING_REGISTER	2661	10	°C	3	50	300	250	
id:12880	MODBUS_HOLDING_REGISTER	2663	10	°C	3	50	300	250	
id:13796	MODBUS_INPUT_REGISTER	2243	1		4	0	0	0	
id:13797	MODBUS_INPUT_REGISTER	2244	1		4	0	0	0	
id:13798	MODBUS_INPUT_REGISTER	2245	1		4	0	0	0	
id:13799	MODBUS_INPUT_REGISTER	2246	1		4	0	0	0	
id:13800	MODBUS_INPUT_REGISTER	2247	1		4	0	0	0	
id:13801	MODBUS_INPUT_REGISTER	2248	1		4	0	0	0	
id:13802	MODBUS_INPUT_REGISTER	2249	1		4	0	0	0	
id:13803	MODBUS_INPUT_REGISTER	2250	1		4	0	0	0	
Offset cooling (EME20)	MODBUS_HOLDING_REGISTER	2667	1			1	-10	0	-1
Offset heating (EME20)	MODBUS_HOLDING_REGISTER	2668	1			4	0	10	1
Offset pool (EME20)	MODBUS_HOLDING_REGISTER	2669	1	°C		4	0	10	10
Cooling (EME20)	MODBUS_HOLDING_REGISTER	2666	1		4	0	1	0	

AUX (EME20)	MODBUS_HOLDING_REGISTER	2675	1	4	0	1	0			
id:14052	MODBUS_HOLDING_REGISTER	2670	1	kw	6	1	999	1		
id:14061	MODBUS_HOLDING_REGISTER	2672	1	4	0	1	0			
Temperature, Overload, pool	MODBUS_HOLDING_REGISTER	0	1	°C	4	1	50	1		
EME20 API	MODBUS_HOLDING_REGISTER	2107	1	4	0	1	0			
EME20 API Include own consumption	MODBUS_HOLDING_REGISTER	2108	1			4	0	1	0	
EME20 API Available power	MODBUS_HOLDING_REGISTER	2109	1			5	0	65535	0	
External adjustment input, main unit (ECS1)	MODBUS_HOLDING_REGISTER	2111	1			4	0	1	0	
External adjustment input (ECS2)	MODBUS_HOLDING_REGISTER	2112	1			4	0	1	0	
External adjustment input (ECS3)	MODBUS_HOLDING_REGISTER	2113	1			4	0	1	0	
External adjustment input (ECS4)	MODBUS_HOLDING_REGISTER	2114	1			4	0	1	0	
External adjustment input (ECS5)	MODBUS_HOLDING_REGISTER	2115	1			4	0	1	0	
External adjustment input (ECS6)	MODBUS_HOLDING_REGISTER	2116	1			4	0	1	0	
External adjustment input (ECS7)	MODBUS_HOLDING_REGISTER	2117	1			4	0	1	0	
External adjustment input (ECS8)	MODBUS_HOLDING_REGISTER	2118	1			4	0	1	0	
Zone 1 affected by ECS1	MODBUS_HOLDING_REGISTER	2119	1	4	0	1	0			
Zone 2 affected by ECS1	MODBUS_HOLDING_REGISTER	2120	1	4	0	1	0			
Zone 3 affected by ECS1	MODBUS_HOLDING_REGISTER	2121	1	4	0	1	0			
Zone 4 affected by ECS1	MODBUS_HOLDING_REGISTER	2122	1	4	0	1	0			
Zone 5 affected by ECS1	MODBUS_HOLDING_REGISTER	2123	1	4	0	1	0			
Zone 6 affected by ECS1	MODBUS_HOLDING_REGISTER	2124	1	4	0	1	0			
Zone 7 affected by ECS1	MODBUS_HOLDING_REGISTER	2125	1	4	0	1	0			
Zone 8 affected by ECS1	MODBUS_HOLDING_REGISTER	2126	1	4	0	1	0			
Zone 9 affected by ECS1	MODBUS_HOLDING_REGISTER	2127	1	4	0	1	0			
Zone 10 affected by ECS1	MODBUS_HOLDING_REGISTER	2128	1		4	0	1	0		
Zone 11 affected by ECS1	MODBUS_HOLDING_REGISTER	2129	1		4	0	1	0		
Zone 12 affected by ECS1	MODBUS_HOLDING_REGISTER	2130	1		4	0	1	0		
Zone 13 affected by ECS1	MODBUS_HOLDING_REGISTER	2131	1		4	0	1	0		
Zone 14 affected by ECS1	MODBUS_HOLDING_REGISTER	2132	1		4	0	1	0		
Zone 15 affected by ECS1	MODBUS_HOLDING_REGISTER	2133	1		4	0	1	0		
Zone 16 affected by ECS1	MODBUS_HOLDING_REGISTER	2134	1		4	0	1	0		
Zone 17 affected by ECS1	MODBUS_HOLDING_REGISTER	2135	1		4	0	1	0		
Zone 18 affected by ECS1	MODBUS_HOLDING_REGISTER	2136	1		4	0	1	0		
Zone 19 affected by ECS1	MODBUS_HOLDING_REGISTER	2137	1		4	0	1	0		
Zone 20 affected by ECS1	MODBUS_HOLDING_REGISTER	2138	1		4	0	1	0		
Zone 21 affected by ECS1	MODBUS_HOLDING_REGISTER	2139	1		4	0	1	0		
Zone 22 affected by ECS1	MODBUS_HOLDING_REGISTER	2140	1		4	0	1	0		
Zone 23 affected by ECS1	MODBUS_HOLDING_REGISTER	2141	1		4	0	1	0		
Zone 24 affected by ECS1	MODBUS_HOLDING_REGISTER	2142	1		4	0	1	0		
Zone 25 affected by ECS1	MODBUS_HOLDING_REGISTER	2143	1		4	0	1	0		
Zone 26 affected by ECS1	MODBUS_HOLDING_REGISTER	2144	1		4	0	1	0		
Zone 27 affected by ECS1	MODBUS_HOLDING_REGISTER	2145	1		4	0	1	0		
Zone 28 affected by ECS1	MODBUS_HOLDING_REGISTER	2146	1		4	0	1	0		
Zone 29 affected by ECS1	MODBUS_HOLDING_REGISTER	2147	1		4	0	1	0		
Zone 30 affected by ECS1	MODBUS_HOLDING_REGISTER	2148	1		4	0	1	0		
Zone 31 affected by ECS1	MODBUS_HOLDING_REGISTER	2149	1		4	0	1	0		
Zone 32 affected by ECS1	MODBUS_HOLDING_REGISTER	2150	1		4	0	1	0		

Zone 33 affected by ECS1	MODBUS_HOLDING_REGISTER	2151	1		4	0	1	0		
Zone 34 affected by ECS1	MODBUS_HOLDING_REGISTER	2152	1		4	0	1	0		
Zone 35 affected by ECS1	MODBUS_HOLDING_REGISTER	2153	1		4	0	1	0		
Zone 36 affected by ECS1	MODBUS_HOLDING_REGISTER	2154	1		4	0	1	0		
Zone 37 affected by ECS1	MODBUS_HOLDING_REGISTER	2155	1		4	0	1	0		
Zone 38 affected by ECS1	MODBUS_HOLDING_REGISTER	2156	1		4	0	1	0		
Zone 39 affected by ECS1	MODBUS_HOLDING_REGISTER	2157	1		4	0	1	0		
Zone 40 affected by ECS1	MODBUS_HOLDING_REGISTER	2158	1		4	0	1	0		
Input on ECS1 affects ECS1	MODBUS_HOLDING_REGISTER	2439	1		4	0	1	0		
Input on ECS1 affects ECS2	MODBUS_HOLDING_REGISTER	2440	1		4	0	1	0		
Input on ECS1 affects ECS3	MODBUS_HOLDING_REGISTER	2441	1		4	0	1	0		
Input on ECS1 affects ECS4	MODBUS_HOLDING_REGISTER	2442	1		4	0	1	0		
Input on ECS1 affects ECS5	MODBUS_HOLDING_REGISTER	2443	1		4	0	1	0		
Input on ECS1 affects ECS6	MODBUS_HOLDING_REGISTER	2444	1		4	0	1	0		
Input on ECS1 affects ECS7	MODBUS_HOLDING_REGISTER	2445	1		4	0	1	0		
Input on ECS1 affects ECS8	MODBUS_HOLDING_REGISTER	2446	1		4	0	1	0		
External setting for adjustment migrated	MODBUS_HOLDING_REGISTER	2503	1		4	0	4	0	1	0
Version, inverter (EB101)	MODBUS_INPUT_REGISTER	2147	1		4	0	0	0		
Time between filter replacement	MODBUS_HOLDING_REGISTER	2676	1		4	1	24	3		
Time between filter replacement	MODBUS_HOLDING_REGISTER	2677	1		4	1	24	3		
Time between filter replacement	MODBUS_HOLDING_REGISTER	2678	1		4	1	24	3		
Time between filter replacement	MODBUS_HOLDING_REGISTER	2679	1		4	1	24	3		
id:21077	MODBUS_HOLDING_REGISTER	3020	1	4	0	0	0			
id:21078	MODBUS_HOLDING_REGISTER	3021	1	4	0	0	0			
id:21079	MODBUS_HOLDING_REGISTER	3022	1	4	0	0	0			
id:21080	MODBUS_HOLDING_REGISTER	3023	1	4	0	0	0			
id:21081	MODBUS_HOLDING_REGISTER	3024	1	4	0	0	0			
id:21082	MODBUS_HOLDING_REGISTER	3025	1	4	0	0	0			
id:21083	MODBUS_HOLDING_REGISTER	3026	1	4	0	0	0			
id:21084	MODBUS_HOLDING_REGISTER	3027	1	4	0	0	0			
Return time fan 4	MODBUS_HOLDING_REGISTER	2700	1	h	4	1	24	4		
Return time fan 4	MODBUS_HOLDING_REGISTER	2701	1	h	4	1	24	4		
Return time fan 4	MODBUS_HOLDING_REGISTER	2702	1	h	4	1	24	4		
Return time fan 4	MODBUS_HOLDING_REGISTER	2703	1	h	4	1	24	4		
Return time fan 4	MODBUS_HOLDING_REGISTER	2704	1	h	4	1	24	4		
Return time fan 4	MODBUS_HOLDING_REGISTER	2705	1	h	4	1	24	4		
Return time fan 4	MODBUS_HOLDING_REGISTER	2706	1	h	4	1	24	4		
Return time fan 4	MODBUS_HOLDING_REGISTER	2707	1	h	4	1	24	4		
Return time fan 4	MODBUS_HOLDING_REGISTER	2708	1	h	4	1	24	4		
Return time fan 4	MODBUS_HOLDING_REGISTER	2709	1	h	4	1	24	4		
Return time fan 4	MODBUS_HOLDING_REGISTER	2710	1	h	4	1	24	4		
Return time fan 4	MODBUS_HOLDING_REGISTER	2711	1	h	4	1	24	4		
Return time fan 4	MODBUS_HOLDING_REGISTER	2712	1	h	4	1	24	4		
Return time fan 4	MODBUS_HOLDING_REGISTER	2713	1	h	4	1	24	4		
Return time fan 4	MODBUS_HOLDING_REGISTER	2714	1	h	4	1	24	4		
Return time fan 4	MODBUS_HOLDING_REGISTER	2715	1	h	4	1	24	4		
Time between filter replacement	MODBUS_HOLDING_REGISTER	2728	1		4	1	24	3		

Time between filter replacement	MODBUS_HOLDING_REGISTER	2729	1		4	1	24	3		
Time between filter replacement	MODBUS_HOLDING_REGISTER	2730	1		4	1	24	3		
Time between filter replacement	MODBUS_HOLDING_REGISTER	2731	1		4	1	24	3		
AUX from Modbus	MODBUS_HOLDING_REGISTER	2740	1	4	0	65	0			
AUX from Modbus	MODBUS_HOLDING_REGISTER	2741	1	2	0	0	0			
Heat pump test - Silent mode (EB101/EB102)	MODBUS_HOLDING_REGISTER	5101	1				4	0	1	0
Last defrost, heat pump 1	MODBUS_INPUT_REGISTER	2158	1		4	0	255	255		
ERS 2	MODBUS_HOLDING_REGISTER	2820	1	4	0	1	0			
ERS 3	MODBUS_HOLDING_REGISTER	2821	1	4	0	1	0			
ERS 4	MODBUS_HOLDING_REGISTER	2822	1	4	0	1	0			
ERS 4	MODBUS_HOLDING_REGISTER	2823	1	4	0	1	0			
ERS 4	MODBUS_HOLDING_REGISTER	2824	1	4	0	1	1			
ERS 4	MODBUS_HOLDING_REGISTER	2825	1	4	0	1	1			
ERS 4	MODBUS_HOLDING_REGISTER	2826	1	4	0	1	1			
ERS 4	MODBUS_HOLDING_REGISTER	2827	1	4	0	1	1			
Min. vent temp. (ERS 4)	MODBUS_HOLDING_REGISTER	2857	1	°C	4	0	10	3		
Min. vent temp. (ERS 4)	MODBUS_HOLDING_REGISTER	2858	1	°C	4	0	10	3		
Min. vent temp. (ERS 4)	MODBUS_HOLDING_REGISTER	2859	1	°C	4	0	10	3		
Min. vent temp. (ERS 4)	MODBUS_HOLDING_REGISTER	2860	1	°C	4	0	10	3		
Blocking actions (ERS 4)	MODBUS_HOLDING_REGISTER	2828	1		4	0	2	2		
Blocking actions (ERS 4)	MODBUS_HOLDING_REGISTER	2829	1		4	0	2	2		
Blocking actions (ERS 4)	MODBUS_HOLDING_REGISTER	2830	1		4	0	2	2		
Blocking actions (ERS 4)	MODBUS_HOLDING_REGISTER	2831	1		4	0	2	2		
id:23145	MODBUS_HOLDING_REGISTER	2921	1	4	0	1	0			
id:23146	MODBUS_HOLDING_REGISTER	2922	1	4	0	1	0			
id:23147	MODBUS_HOLDING_REGISTER	2923	1	4	0	1	0			
id:23148	MODBUS_HOLDING_REGISTER	2924	1	4	0	1	0			
id:23149	MODBUS_HOLDING_REGISTER	2836	10	°C	2	-200	410	190		
id:23150	MODBUS_HOLDING_REGISTER	2837	10	°C	2	-200	410	190		
id:23151	MODBUS_HOLDING_REGISTER	2838	10	°C	2	-200	410	190		
id:23152	MODBUS_HOLDING_REGISTER	2839	10	°C	2	-200	410	190		
id:23153	MODBUS_HOLDING_REGISTER	2832	10	°C	2	30	100	30		
id:23154	MODBUS_HOLDING_REGISTER	2833	10	°C	2	30	100	30		
id:23155	MODBUS_HOLDING_REGISTER	2834	10	°C	2	30	100	30		
id:23156	MODBUS_HOLDING_REGISTER	2835	10	°C	2	30	100	30		
Fan mode 5	MODBUS_INPUT_REGISTER	2168	1	%	4	0	0	0		
Fan mode 6	MODBUS_INPUT_REGISTER	2169	1	%	4	0	0	0		
Fan mode 7	MODBUS_INPUT_REGISTER	2170	1	%	4	0	0	0		
Fan mode 8	MODBUS_INPUT_REGISTER	2171	1	%	4	0	0	0		
Disable emergency restart GP1	MODBUS_HOLDING_REGISTER	3628	1		4	0	1	0		
Disable emergency restart GP1	MODBUS_HOLDING_REGISTER	4204	1		4	0	1	0		
Disable emergency restart GP1	MODBUS_HOLDING_REGISTER	5025	1		4	0	1	0		
id:24483	MODBUS_HOLDING_REGISTER	5008	1	4	0	1	0			
id:24484	MODBUS_HOLDING_REGISTER	5009	10	°C	2	50	800	450		
id:24485	MODBUS_HOLDING_REGISTER	5010	10	°C	2	50	800	450		
id:24486	MODBUS_HOLDING_REGISTER	5011	10	°C	2	50	800	450		
id:24487	MODBUS_HOLDING_REGISTER	5012	10	°C	2	50	800	450		

id:24488	MODBUS_HOLDING_REGISTER	5013	10	°C	2	50	800	450
id:24489	MODBUS_HOLDING_REGISTER	5014	10	°C	2	50	800	450
id:24490	MODBUS_HOLDING_REGISTER	5015	10	°C	2	50	800	450
id:24491	MODBUS_HOLDING_REGISTER	5016	10	°C	2	50	800	450
id:24492	MODBUS_HOLDING_REGISTER	5017	10	°C	2	-50	300	250
id:24493	MODBUS_HOLDING_REGISTER	5018	10	°C	2	-50	300	250
id:24494	MODBUS_HOLDING_REGISTER	5019	10	°C	2	-50	300	250
id:24495	MODBUS_HOLDING_REGISTER	5020	10	°C	2	-50	300	250
id:24496	MODBUS_HOLDING_REGISTER	5021	10	°C	2	-50	300	250
id:24497	MODBUS_HOLDING_REGISTER	5022	10	°C	2	-50	300	250
id:24498	MODBUS_HOLDING_REGISTER	5023	10	°C	2	-50	300	250
id:24499	MODBUS_HOLDING_REGISTER	5024	10	°C	2	-50	300	250
id:24634	MODBUS_HOLDING_REGISTER	5031	10	°C	2	50	800	200
id:24635	MODBUS_HOLDING_REGISTER	5032	10	°C	2	50	800	200
id:24636	MODBUS_HOLDING_REGISTER	5033	10	°C	2	50	800	200
id:24637	MODBUS_HOLDING_REGISTER	5034	10	°C	2	50	800	200
id:24638	MODBUS_HOLDING_REGISTER	5035	10	°C	2	50	800	200
id:24639	MODBUS_HOLDING_REGISTER	5036	10	°C	2	50	800	200
id:24640	MODBUS_HOLDING_REGISTER	5037	10	°C	2	50	800	200
id:24641	MODBUS_HOLDING_REGISTER	5038	10	°C	2	50	800	200
id:24642	MODBUS_HOLDING_REGISTER	5039	10	°C	2	50	800	600
id:24643	MODBUS_HOLDING_REGISTER	5040	10	°C	2	50	800	600
id:24644	MODBUS_HOLDING_REGISTER	5041	10	°C	2	50	800	600
id:24645	MODBUS_HOLDING_REGISTER	5042	10	°C	2	50	800	600
id:24646	MODBUS_HOLDING_REGISTER	5043	10	°C	2	50	800	600
id:24647	MODBUS_HOLDING_REGISTER	5044	10	°C	2	50	800	600
id:24648	MODBUS_HOLDING_REGISTER	5045	10	°C	2	50	800	600
id:24649	MODBUS_HOLDING_REGISTER	5046	10	°C	2	50	800	600
id:24650	MODBUS_HOLDING_REGISTER	5047	10	°C	2	50	800	180
id:24651	MODBUS_HOLDING_REGISTER	5048	10	°C	2	50	800	180
id:24652	MODBUS_HOLDING_REGISTER	5049	10	°C	2	50	800	180
id:24653	MODBUS_HOLDING_REGISTER	5050	10	°C	2	50	800	180
id:24654	MODBUS_HOLDING_REGISTER	5051	10	°C	2	50	800	180
id:24655	MODBUS_HOLDING_REGISTER	5052	10	°C	2	50	800	180
id:24656	MODBUS_HOLDING_REGISTER	5053	10	°C	2	50	800	180
id:24657	MODBUS_HOLDING_REGISTER	5054	10	°C	2	50	800	180
id:24681	MODBUS_HOLDING_REGISTER	5056	1		4	0	1	0
id:24682	MODBUS_HOLDING_REGISTER	5057	1		4	0	1	0
id:24683	MODBUS_HOLDING_REGISTER	5058	1		4	0	255	0
id:24684	MODBUS_HOLDING_REGISTER	5059	1		4	0	1	0
Relay status	MODBUS_INPUT_REGISTER	0	1		4	0	0	0
id:24969	MODBUS_HOLDING_REGISTER	5060	1		4	0	1	0
id:24970	MODBUS_HOLDING_REGISTER	5061	1		2	-100	10000	0
id:24971	MODBUS_HOLDING_REGISTER	5062	1		4	0	1	0
id:24972	MODBUS_HOLDING_REGISTER	5063	1		5	0	1000	0
id:24973	MODBUS_HOLDING_REGISTER	5064	1		4	0	1	0
id:24974	MODBUS_HOLDING_REGISTER	5065	1		4	0	1	0

id:24975	MODBUS_HOLDING_REGISTER	5066	1	5	0	1000	0												
id:24976	MODBUS_HOLDING_REGISTER	5067	1	4	0	1	0												
id:24977	MODBUS_HOLDING_REGISTER	5068	1	4	0	1	0												
id:24978	MODBUS_HOLDING_REGISTER	5069	1	5	0	1000	0												
id:24979	MODBUS_HOLDING_REGISTER	5070	1	4	0	1	0												
id:24980	MODBUS_HOLDING_REGISTER	5071	1	5	0	1000	0												
Energy log - Energy produced for heat during past hour																			
Energy log - Energy produced for hot water during past hour																			
Energy log - Energy produced for cooling during past hour																			
Energy log - Energy used for heat during past hour																			
Energy log - Energy used for hot water during past hour																			
Energy log - Energy used for cooling during past hour																			
Energy log - Energy used by additional heater for heat during past hour																			
0																			
Energy log - Energy used by additional heater for hot water during past hour																			
0																			
Energy log - Current power consumption																			
Energy log - Current power consumption, components																			
id:25407	MODBUS_HOLDING_REGISTER	0	1	4	0	0	0												
Compressor, total time energy storage, main unit (EP14)																			
0																			
Compressor, total time energy storage, main unit (EP15)																			
0																			
Compressor, total time energy storage, heat pump 1 (EP14)																			
2147483647	0																		
Compressor, total time energy storage, heat pump 1 (EP15)																			
2147483647	0																		
id:55035	MODBUS_HOLDING_REGISTER	1555	1	4	0	40	0												
id:55036	MODBUS_HOLDING_REGISTER	1556	1	4	0	40	0												
id:55037	MODBUS_HOLDING_REGISTER	1557	1	4	0	40	0												
id:55076	MODBUS_HOLDING_REGISTER	2877	1	4	0	1	0												
id:55077	MODBUS_HOLDING_REGISTER	2878	1	4	0	1	0												
id:55078	MODBUS_HOLDING_REGISTER	2879	1	4	0	1	0												
id:55079	MODBUS_HOLDING_REGISTER	2880	1	4	0	1	0												
id:55080	MODBUS_HOLDING_REGISTER	2881	1	4	0	1	0												
id:55081	MODBUS_HOLDING_REGISTER	2882	1	4	0	1	0												
id:55082	MODBUS_HOLDING_REGISTER	2883	1	4	0	1	0												
id:55083	MODBUS_HOLDING_REGISTER	2884	1	4	0	1	0												
Immersion heater power, emergency mode																			
Disable emergency restart GP1																			
Return line (AZ2-BT69)																			
Supply line (AZ2-BT68)																			
id:55100	MODBUS_INPUT_REGISTER	2192	10	°C	2	0	0	0											
id:55101	MODBUS_INPUT_REGISTER	2193	10	°C	2	0	0	0											
id:55102	MODBUS_INPUT_REGISTER	2194	10	°C	2	0	0	0											