EnOcean Equipment Profiles

REVISION HISTORY

Ver.	Editor	Change	Date
2.6.8	NM	Last xml edition of the EEP-Specification	Dec 31, 2017

The EnOcean Alliance "EnOcean Equipment Profiles definitions" are available free of charge to companies, individuals and institutions for all non-commercial purposes (including educational research, technical evaluation and development of non-commercial tools or documentation.)

This specification includes intellectual property („IPR") of the EnOcean Alliance and joint intellectual properties („joint IPR") with contributing member companies. No part of this

specification may be used in development of a product or service for sale without being a participant or promoter member of the EnOcean Alliance and/or joint owner of the appropriate joint IPR.

These errata may not have been subjected to an Intellectual Property review, and as such, may contain undeclared Necessary Claims.

EnOcean Alliance Inc.
2400 Camino Ramon, Suite 375
San Ramon, CA 94583
USA
Graham Martin
Chairman & CEO EnOcean Alliance

D2-32: A.C. Current Clamp

Description
A family of EEP's based on a central unit where up to three a.c. Current Clamps can be connected. Each one capable of energy harvesting sufficiently to enable readings of current values to be taken in amps and transmitted every 30 seconds.

Data exchange
Direction: unidirectional
Addressing: broadcast
Communication trigger: time-triggered
Communication interval: 30 seconds
Trigger event: Threshold Voltage for Power Fail transmission bit
Tx delay: -
Rx timeout: -

Teach-in
Teach-in method: Universal teach-in (UTE)

Security
Encryption supported: no
Security level format: -

EEP Family Table:

Supported function	Type 00	Type 01	Type 02
Channel 1	X	X	X
Channel 2	-	X	X
Channel 3	-	-	X

Each TYPE has to support every parameter that is marked in its column!

The list of parameters could be structured following the features that always include a certain group of parameters.

RORG	D2	VLD Telegram
FUNC	32	A.C. Current Clamp
TYPE	02	Type 0x02

Submitter: Pressac Communications Ltd

Type 02



Notes
1) If Power Fail bit is set, all channel readings will be set to zero when this final telegram is sent.
2) Scale/divisor is set to 0 or 1 for all channels only, not individually.

Offset	Size	Data	ShortCut	Description	Valid Range	Scale	Unit
0	1	Power Fail	PF	See Note 1	Enum: 0: False 1: True		
1	1	Divisor	DIV	Divisor for all channels	Enum: 0: x/1 1: x/10		
2	6	Not Used (= 0)					
8	12	Channel 1	CH1	Current value	0...0xFFF	0...4095 (409,5)	A
20	12	Channel 2	CH2	Current value	0...0xFFF	0...4095 (409,5)	A
32	12	Channel 3	CH3	Current value	0...0xFFF	0...4095 (409,5)	A
44	4	Not Used (= 0)					