

CONDITION REPORT INSPECTION SCHEDULE FOR DOMESTIC AND SIMILAR PREMISES WITH UP TO 100A SUPPLY

NOTE: This form is suitable for many types of smaller installation, not exclusively domestic.

OUTCOMES	Acceptable condition	✓	Unacceptable condition	C1 or C2	Improvement recommended	C3	Further investigation	FI	Not verified	N/V	Limitation
ITEM NO.	DESCRIPTION								OUTCOMES		
									(Use codes above. Provide additional codes for C2, C3, and FI coded items to be recorded in Condition Report)		
1.0	External condition of intake equipment (visual inspection only)										
1.1	Service cable										
1.2	Service head										
1.3	Earthing arrangement										
1.4	Meter tails										
1.5	Metering equipment										
1.6	Isolator (where present)										
2.0	Presence of adequate arrangements for other sources such as microgenerators						(551.6; 551.7)				
3.0	Earthing / bonding arrangements						(411.3; chap. 54)				
3.1	Presence and condition of distributor's earthing arrangement						(542.1.2.1; 542.1.2.2)				
3.2	Presence and condition of earth electrode connection where applicable						(542.1.2.3)				
3.3	Provision of earthing/bonding labels at all appropriate locations						(514.13.1)				
3.4	Confirmation of earthing conductor size						(542.3; 543.1.1)				
3.5	Accessibility and condition of earthing conductor at MET						(543.3.2)				