

# CONDITION REPORT INSPECTION SCHEDULE FOR DOMESTIC AND SIMILAR PREMISES WITH UP TO 100A SUPPLY

**NOTE:** This form is suitable for many types of smaller installation, not exclusively domestic.

OUTCOMES	Acceptable condition	✓	Unacceptable condition	C1 or C2	Improvement recommended	C3	Further investigation	FI	Not verified	N/V	Limitation
ITEM NO.	DESCRIPTION								OUTCOMES		
									(Use codes above. Provide additional codes for C2, C3, and FI coded items to be Condition R		
5.13	Provision of fire barriers, sealing arrangements and protection against thermal effects						(Section 527)				
5.14	Band II cables segregated/separated from Band I cables						(528.1)				
5.15	Cables segregated/separated from communications cabling						(528.2)				
5.16	Cables segregated/separated from non-electrical services						(528.3)				
5.17	• Termination of cables at enclosures - indicate extent of sampling in Section D of the report						(Section 526)				
	• Connections soundly made and under no undue strain						(526.6)				
	• No basic insulation of a conductor visible outside enclosure						(526.8)				
	• Connections of live conductors adequately enclosed						(526.5)				
	• Adequately connected at point of entry to enclosure (glands, bushes etc.)						(522.8.5)				
5.18	Condition of accessories including socket-outlets, switches and joint boxes						(651.2(v))				
5.19	Suitability of accessories for external influences						(512.2)				
5.20	Adequacy of working space/accessibility to equipment						(132.12; 513.1)				
5.21	Single-pole switching or protective devices in line conductors only						(132.14.1, 530.3.3)				