

# CD/11 Oil Firing Service & Commissioning Report

This record is for safety purposes only. This report is valid for the day of assessment only.



Customer Details Test	
Name	John Doe
Address	6th Floor, 4 St. Pauls Square Liverpool, L39AG

Company Details	
Company Name	Test Contractor
Company Address	6th Floor, 4 St. Pauls Square Liverpool, L39AG

Appliance Details			
Location	Kitchen		
Make	Test Make	Model	Test Model
Serial Number	DN:1234382		
Burner Make	Test Oil Burner	Burner Model	Oil Burner Model
Burner Type	Open	Tank Type	Open
Flue Type	CF - Conventional Flue	Fuel Type	Oil

Call Type	Service
-----------	---------

Oil Firing Service and Commissioning Schedule			
Oil Storage	Yes	Air Supply	Yes
Fuse Rating	23 Amp	Fuse Compliant	Yes
Appliance Safety Controls	Yes	Combustion Chamber	Yes
Wallflame Burner	Yes	Chimney/Flue	Yes
Heat Exchanger	Yes	Electrical Safety	Yes
Controls Check	Yes	Jet Burner	Yes
Hot Water System Check	Yes	Warm Air System Check	Yes

Landlord Details	
Landlord Name	Jane Lords
Address	6th Floor, 4 St. Pauls Square Liverpool, L39AG

Engineer Details	
Engineer Name	Test Engineer
Engineer OFTEC Number	12343823

Test Results					
Smoke No.	2	Draught	65	inWG	
Flow Rate (Oil) Low	360	cc/min	Flow Rate (Oil) High	380	cc/min
Flow Rate (DHW) Cold	520	l/min	Flow Rate (DHW) Hot	550	l/min
Nozzle Size	200 mm	Nozzle Angle	20 °	Nozzle Pattern	Flat
CO	0.001 ppm	CO <sub>2</sub>	25.1 %	CO : CO <sub>2</sub> Ratio	1:2500
Flue Gas Temp	45 °C	Pump Pressure	100 psi	Pump Vacuum	202 psi
Efficiency Net	89 %	Efficiency Gross	85 %	Excess Air	15 %

Defects Identified	Remedial Recommendations
1 Appliance Defect 1	this is the recommendation for Appliance Defect 1
2 Appliance Defect 2	this is the recommendation for Appliance Defect 2
3 Appliance Defect 3	this is the recommendation for Appliance Defect 3
4 Appliance Defect 4	this is the recommendation for Appliance Defect 4
5 Appliance Defect 5	this is the recommendation for Appliance Defect 5

Servicing Record Sign Off					
Issued by	Signed		Print Name	Test Engineer	Date 2019-11-26
Received By	Signed		Print Name	John Doe	Date 2019-11-26