

CONDITION REPORT INSPECTION SCHEDULE FOR DOMESTIC AND SIMILAR PREMISES WITH UP TO 100A SUPPLY

NOTE: This form is suitable for many types of smaller installation, not exclusively domestic.

OUTCOMES	Acceptable condition	✓	Unacceptable condition	C1 or C2	Improvement recommended	C3	Further investigation	FI	Not verified	N/V	Limitation
ITEM NO.	DESCRIPTION								OUTCOMES		
									(Use codes above. Provide additional codes for C2, C3, and FI coded items to be recorded in Condition Report)		
4.16	Protection against mechanical damage where cables enter consumer unit/distribution board						(132.14.1; 522.8.1; 522.8.5; 522.8.11)				
4.17	Protection against electromagnetic effects where cables enter consumer unit/distribution board/ enclosures						(521.5.1)				
4.18	RCD(s) provided for fault protection - includes RCBOs						(411.4.204; 411.5.2; 531.2)				
4.19	RCD(s) provided for additional protection/requirements - includes RCBOs						(411.3.3; 415.1)				
4.20	Confirmation of indication that SPD is functional						(651.4)				
4.21	Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure						(526.1)				
4.22	Adequate arrangements where a generating set operates as a switched alternative to the public supply						(551.6)				
4.23	Adequate arrangements where a generating set operates in parallel with the public supply						(551.7)				
5.0	Final circuits										
5.1	Identification of conductors						(514.3.1)				
5.2	Cables correctly supported throughout their run						(521.10.202; 522.8.5)				