

Budget Estimate

Project #:AppleBrookHouse2 July 29, 2018

D !		I £	4!
Pro	lect	intoi	rmation

Project #: AppleBrookHouse2

Name: Location:

Quotation For

Project Summary

Load Calculation Method: Manual J8 Total Heating Load: 12,152 W
Design Location: (User Specified) Chadlington, Oxfordshire

Notes:

Outdoor Temperature:

-3.8 °C

Total RH Circuits:

24

Floorplans / Levels:

2 Total Area:

266.7 m²

Total Zones:

15

Comments

Total Quote Price: \$16,302.55

July 29, 2018

Goods & Services Supplied

Tubing		
Part Number	Description	Price
A1220500	1/2" Wirsbo hePEX plus, 1,000 ft. coil	\$3,719.55
A1250500	1/2" Wirsbo hePEX plus, 300 ft. coil	\$372.00
A1260500	1/2" Wirsbo hePEX, 500 ft. coil	\$619.95
A1140500	1/2" Wirsbo hePEX, 100-ft. coil	\$124.05

Subtotal: \$4,835.55

Fittings				
Part Number	Description	Price		
A2660501	TruFLOW Jr. Assembly with Isolation and Balancing Valves, 5-loop	\$1,324.70		
A2660801	TruFLOW Jr. Assembly with Isolation and Balancing Valves, 8-loop	\$924.85		
A2660601	TruFLOW Jr. Assembly with Isolation and Balancing Valves, 6-loop	\$739.65		
A4020500	1/2" QS-style Compression Fitting Assembly, R20 thread	\$626.40		
A2123210	Threaded Brass Bushing, R32 Male x 1" Female NPT	\$158.40		

Subtotal: \$3,774.00

Controls

Part Number	Description	Price
A3023522	Thermal Actuator, four-wire	\$2,043.45
A3100101	Heat-only Thermostat with Touchscreen	\$2,195.70
A9010599	Slab Sensor, 10k	\$672.10
A3050050	50 VA Transformer	\$166.50
A3031004	Four-zone Control Module for Two-wire Operation	\$160.35
A3031003	Three-zone Control Module for Two and Four-wire Operation	\$580.00
A3010100	Single-zone Pump Relay	\$313.90
A5402112	1" Thermal Mixing Valve with Union	\$373.60

Subtotal: \$6,505.60

Accessories

Part Number	Description	Price
A7012000	2" Blue Foam Staples (300/pkg)	\$397.50
A5500500	3/4" PVC Elbow for 3/8" and 1/2" PEX Bend Support	\$187.20
E6061000	Tube Uncoiler	\$562.70
E6081128	Tube Cutter (plastic) for up to 1" PEX (3/4" MLC Tubing)	\$40.00

Subtotal: \$1,187.40

Total Quote Price: \$16,302.55

Project #: AppleBrookHouse2

Name:

Budget Estimate

July 29, 2018

Disclaimers

The calculated values shown in this report are based on the data input by the user of the software. Inaccurate or erroneous data input will result in inaccurate or erroneous results. You are strongly advised to review all input data carefully, and to have the calculated results reviewed by an experienced heating professional to ensure reasonableness and suitability for your application.

IN NO EVENT WILL AVENIR SOFTWARE INC. ("AVENIR") OR ITS AFFILIATES BE LIABLE UNDER ANY CONTRACT, NEGLIGENCE, STRICT LIABILITY OR OTHER LEGAL OR EQUITABLE THEORY FOR ANY CONSEQUENTIAL, INCIDENTAL, INDIRECT OR SPECIAL OR PUNITIVE DAMAGES WHATSOEVER (INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF BUSINESS PROFITS, BUSINESS INTERRUPTION, LOSS OF BUSINESS INFORMATION OR DATA AND THE LIKE), EVEN IF SUCH PARTY HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. AVENIR'S CUMULATIVE LIABILITY FROM ANY CAUSE RELATED TO OR ARISING FROM THE USE THIS REPORT, AND REGARDLESS OF THE FORM OF THE ACTION, SHALL BE LIMITED TO NO GREATER THAN THE AMOUNT OF FEES PAID TO AVENIR UNDER THE SOFTWARE LICENSE AGREEMENT.