

# **Water Supply Summary**

Project #:AppleBrookHouse2

July 29, 2018

#### **Project Information**

Project #: AppleBrookHouse2 Notes:

Name: Location:

## **Supply Summary**

Name	Temp Total Fluid Vol		Total Flow	Head Loss <sup>1</sup>	Load <sup>2</sup>	# Circuits	# Zones	
Water Temperature	37.5	98.7	11.67	5.3	7,743	19	11	
Water Temperature	54.1	31.9	10.50	22.7	6,648	5	1	

<sup>(1)</sup> Head loss includes manifolds, circuits, and supply/return piping if specified, may also contain control valve losses. (2) Load includes all panel back losses.

### **Manifold Summary**

Manifold Name	Circuits	Flowrate	Required Temp.	Supplied Temp.	Manifold Type	S/R Length <sup>1</sup>	S/R Pipe	Manifold Head Loss	Circuit Head Loss	S/R Head Loss	Total Head Loss <sup>2</sup>
Manifold 1	6	4.70	38	38	TruFLOW Jr Valved w/ Balancing	-	-	0.2	5.1	0.0	5.3
Manifold 2	5	2.79	32	38	TruFLOW Jr Valved w/ Balancing	-	-	0.1	2.0	0.0	2.1
Manifold 3	5	10.50	54	54	TruFLOW Jr Valved w/ Balancing	-	-	1.1	21.5	0.0	22.7
Manifold 4	8	4.18	32	38	TruFLOW Jr Valved w/ Balancing	-	-	0.1	4.1	0.0	4.2
Total	24	22.17	54	-	-	-	-				22.7

<sup>(1)</sup> S/R Length = one way, (2) Total Head loss includes manifold, circuits and supply/return piping if specified.

July 29, 2018

# Water Temperature (38 °C)

### Manifold 1 ( 38 °C, TruFLOW Jr Valved w/ Balancing, 6 Circuits )

Circuit	Rooms Served	Total Length	Tube Spacing	Area Covered	Tubing	Flowrate	Head Loss <sup>1</sup>	Temp Drop <sup>2</sup>	Load³	Actuator	Valve Setting
B-1	Kitchen	44.8	200	9.3	hePEX 1/2"	1.01	1.9	11	777	Yes	0.76
B-2	Kitchen	3.8		0.0	hePEX 1/2"	0.38	0.0	11	1	Yes	0.42
B-3	-	4.3		0.0	hePEX 1/2"	0.00	0.0	11	0	Yes	0.25
B-4	Kitchen	4.1		0.0	hePEX 1/2"	0.38	0.0	11	1	Yes	0.42
B-5	Study	61.4	200	14.0	hePEX 1/2"	1.44	4.7	11	1,109	Yes	2.88
B-6	Kitchen	61.6	200	13.9	hePEX 1/2"	1.50	5.1	11	1,158	Yes	4.2
Total	-	180.1		37.2	-	4.70	5.1	-	3,047	6	

<sup>(1)</sup> Head loss for circuit tubing only. (2) Design Temp Drop (Estimated Actual Drop). (3) Load includes panel back losses.

#### Manifold 2 (38 °C, TruFLOW Jr Valved w/ Balancing, 5 Circuits)

Circuit	Rooms Served	Total Length	Tube Spacing	Area Covered	Tubing	Flowrate	Head Loss <sup>1</sup>	Temp Drop <sup>2</sup>	Load <sup>3</sup>	Actuator	Valve Setting
A-1	Main Bathroom	39.1	200	8.3	hePEX 1/2"	0.38	0.3	11	105	Yes	0.5
A-2	Ensuite	33.0	200	7.1	hePEX 1/2"	0.42	0.3	11	328	Yes	0.56
A-3	Bed 1	68.8	200	12.9	hePEX 1/2"	0.81	2.0	11	598	Yes	4.2
A-4	Bed 1	66.6	200	12.8	hePEX 1/2"	0.80	1.9	11	582	Yes	2.86
A-5	Hall 2	35.5	200	7.7	hePEX 1/2"	0.38	0.3	11	121	Yes	0.5
Total	-	242.9		48.8	-	2.79	2.0	-	1,733	5	

<sup>(1)</sup> Head loss for circuit tubing only. (2) Design Temp Drop (Estimated Actual Drop). (3) Load includes panel back losses.

Project #:AppleBrookHouse2

### Manifold 4 ( 38 °C, TruFLOW Jr Valved w/ Balancing, 8 Circuits )

Circuit	Rooms Served	Total Length	Tube Spacing	Area Covered	Tubing	Flowrate	Head Loss <sup>1</sup>	Temp Drop²	Load <sup>3</sup>	Actuator	Valve Setting
A-6	Bed 4	59.8	200	12.7	hePEX 1/2"	0.43	0.6	11	341	Yes	0.47
A-7	Bed 3	49.2	200	9.2	hePEX 1/2"	0.38	0.4	11	236	Yes	0.45
A-8	Bed 3	50.4	200	10.0	hePEX 1/2"	0.38	0.4	11	251	Yes	0.45
A-9	Bed 2	52.5	200	10.2	hePEX 1/2"	0.52	0.7	11	362	Yes	0.49
A-10	Bed 2	52.5	200	8.7	hePEX 1/2"	0.45	0.6	11	330	Yes	0.48
A-11	Hall 1	44.9	200	10.4	hePEX 1/2"	0.38	0.4	11	187	Yes	0.45
A-12	Basement	87.3	200	17.9	hePEX 1/2"	1.06	4.1	11	813	Yes	4.2
A-13	Basement	43.8	200	9.8	hePEX 1/2"	0.58	0.7	11	441	Yes	0.5
Total	-	440.5		88.7	-	4.18	4.1	-	2,962	8	

<sup>(1)</sup> Head loss for circuit tubing only. (2) Design Temp Drop (Estimated Actual Drop). (3) Load includes panel back losses.

### Water Temperature (54 °C)

#### Manifold 3 (54 °C, TruFLOW Jr Valved w/ Balancing, 5 Circuits )

Circuit	Rooms Served	Total Length	Tube Spacing	Area Covered	Tubing	Flowrate	Head Loss <sup>1</sup>	Temp Drop²	Load <sup>3</sup>	Actuator	Valve Setting
B-8	Main Cottage	43.1	200	9.1	hePEX 1/2"	1.18	2.2	11	913	No	0.46
B-9	Main Cottage,WC	66.0	200	15.9	hePEX 1/2"	3.13	17.6	11	1,798	No	1.61
B-10	Main Cottage,Entrance	65.5	200	16.3	hePEX 1/2"	3.54	21.5	11	1,896	No	4.2
B-11	Main Cottage	36.1	200	7.1	hePEX 1/2"	0.92	1.2	11	708	No	0.42
B-12	Main Cottage	68.1	200	13.3	hePEX 1/2"	1.73	6.6	11	1,334	No	0.57
Total	-	278.8		61.7	-	10.50	21.5	-	6,648	0	

<sup>(1)</sup> Head loss for circuit tubing only. (2) Design Temp Drop (Estimated Actual Drop). (3) Load includes panel back losses.

Name: Water Supply Summary

Project #:AppleBrookHouse2 July 29, 2018

#### **Disclaimers**

With the permission of the Air Conditioning Contractors of America ("ACCA"), material is reproduced from Manual J Residential Load Calculation (8th Edition) which is copyrighted by ACCA. The program and data are provided "as is" without warranty of any kind either expressed or implied. The entire risk as the quality and performance of the program and data is with you. In no event will ACCA be liable to you for any damages, including without limitation any lost profits, lost savings, or other incidental or consequential damages arising out of the use or inability to use this program or the data. © 2015 Air Conditioning Contractors of America. All Rights Reserved. www.acca.org

ACCA, Manual J and Powered by ACCA Manual J are registered trademarks of the Air Conditioning Contractors of America. All rights reserved.

Cold weather humidification, or some lifestyles that produce excessive moisture, may cause condensation to occur if the absolute humidity of the indoor air is too high for the momentary circumstances. Condensation can occur on surfaces or concealed within the structure, and can lead to mold, mildew, frost damage, and moisture damage. The software does not perform calculations for the estimation or detection of possible condensation problems, and it is the designers (i.e. software users) responsibility to do so independently if required. For guidance and additional cautions refer to ACCA Manual J 8th Edition, including Section 1-11 and Section 27.

The calculated values shown in this report are based on the data input by the user of the software. Inaccurate or erroneous data input will result in inaccurate or erroneous results. You are strongly advised to review all input data carefully, and to have the calculated results reviewed by an experienced heating professional to ensure reasonableness and suitability for your application.

IN NO EVENT WILL AVENIR SOFTWARE INC. ("AVENIR") OR ITS AFFILIATES BE LIABLE UNDER ANY CONTRACT, NEGLIGENCE, STRICT LIABILITY OR OTHER LEGAL OR EQUITABLE THEORY FOR ANY CONSEQUENTIAL, INCIDENTAL, INDIRECT OR SPECIAL OR PUNITIVE DAMAGES WHATSOEVER (INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF BUSINESS INTERRUPTION, LOSS OF BUSINESS INFORMATION OR DATA AND THE LIKE), EVEN IF SUCH PARTY HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. AVENIFY CUMULATIVE LIABILITY FROM ANY CAUSE RELATED TO OR ARISING FROM THE USE THIS REPORT, AND REGARDLESS OF THE FORM OF THE ACTION, SHALL BE LIMITED TO NO GREATER THAN THE AMOUNT OF FEES PAID TO AVENIR UNDER THE SOFTWARE LICENSE AGREEMENT.