



Circuit Schedule

Project #:AppleBrookHouse2

July 29, 2018

Project Information

Project #: AppleBrookHouse2

Notes:

Name:

Location:

Circuit Stock Summary

Part Number	Description	Quantity
A1220500	1/2" Wirsbo hePEX plus, 1,000 ft. coil	3
A1250500	1/2" Wirsbo hePEX plus, 300 ft. coil	1
A1260500	1/2" Wirsbo hePEX, 500 ft. coil	1
A1140500	1/2" Wirsbo hePEX, 100-ft. coil	1

Coil Summary

Coil	Part Number	Coil Length (m)	Tube Type	Length Used (m)
Coil 1	A1220500	304.8	hePEX 1/2"	292.6
Coil 2	A1220500	304.8	hePEX 1/2"	303.4
Coil 3	A1250500	91.4	hePEX 1/2"	87.3
Coil 4	A1220500	304.8	hePEX 1/2"	304.1
Coil 5	A1260500	152.4	hePEX 1/2"	142.6
Coil 6	A1140500	30.5	hePEX 1/2"	12.2

Circuits Cut Schedule

Ground Floor

Circuit	Length (m)	Location	Coil	Coil Length (m)
A-1	39.1	Ground Floor;Manifold 2;Main Bathroom	Coil 1	304.8
A-2	33.0	Ground Floor;Manifold 2;Ensuite	Coil 2	304.8
A-3	68.8	Ground Floor;Manifold 2;Bed 1	Coil 2	304.8
A-4	66.6	Ground Floor;Manifold 2;Bed 1	Coil 2	304.8
A-5	35.5	Ground Floor;Manifold 2;Hall 2	Coil 2	304.8
A-6	59.8	Ground Floor;Manifold 4;Bed 4	Coil 1	304.8
A-7	49.2	Ground Floor;Manifold 4;Bed 3	Coil 2	304.8
A-8	50.4	Ground Floor;Manifold 4;Bed 3	Coil 2	304.8
A-9	52.5	Ground Floor;Manifold 4;Bed 2	Coil 1	304.8
A-10	52.5	Ground Floor;Manifold 4;Bed 2	Coil 1	304.8
A-11	44.9	Ground Floor;Manifold 4;Hall 1	Coil 1	304.8
A-12	87.3	Ground Floor;Manifold 4;Basement	Coil 3	91.4
A-13	43.8	Ground Floor;Manifold 4;Basement	Coil 1	304.8

Main Floor

Circuit	Length (m)	Location	Coil	Coil Length (m)
B-1	44.8	Main Floor;Manifold 1;Kitchen	Coil 5	152.4
B-2	3.8	Main Floor;Manifold 1;Kitchen	Coil 6	30.5
B-3	4.3	Main Floor;Manifold 1;	Coil 6	30.5

IN NO EVENT WILL AVENIR SOFTWARE INC. ("AVENIR") OR ITS AFFILIATES BE LIABLE UNDER ANY CONTRACT, NEGLIGENCE, STRICT LIABILITY OR OTHER LEGAL OR EQUITABLE THEORY FOR ANY CONSEQUENTIAL, INCIDENTAL, INDIRECT OR SPECIAL OR PUNITIVE DAMAGES WHATSOEVER (INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF BUSINESS PROFITS, BUSINESS INTERRUPTION, LOSS OF BUSINESS INFORMATION OR DATA AND THE LIKE), EVEN IF SUCH PARTY HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. AVENIR'S CUMULATIVE LIABILITY FROM ANY CAUSE RELATED TO OR ARISING FROM THE USE THIS REPORT, AND REGARDLESS OF THE FORM OF THE ACTION, SHALL BE LIMITED TO NO GREATER THAN THE AMOUNT OF FEES PAID TO AVENIR UNDER THE SOFTWARE LICENSE AGREEMENT.

Created Using LoopCAD 2018 Uponor(US) (7/30/2018)
Version:18.0.0594 R (Trial)

B-4	4.1	Main Floor;Manifold 1;Kitchen	Coil 6	30.5
B-5	61.4	Main Floor;Manifold 1;Study	Coil 4	304.8
B-6	61.6	Main Floor;Manifold 1;Kitchen	Coil 5	152.4
B-8	43.1	Main Floor;Manifold 3;Main Cottage	Coil 4	304.8
B-9	66.0	Main Floor;Manifold 3;Main Cottage,WC	Coil 4	304.8
B-10	65.5	Main Floor;Manifold 3;Main Cottage,Entrance	Coil 4	304.8
B-11	36.1	Main Floor;Manifold 3;Main Cottage	Coil 5	152.4
B-12	68.1	Main Floor;Manifold 3;Main Cottage	Coil 4	304.8

Disclaimers

The calculated values shown in this report are based on the data input by the user of the software. Inaccurate or erroneous data input will result in inaccurate or erroneous results. You are strongly advised to review all input data carefully, and to have the calculated results reviewed by an experienced heating professional to ensure reasonableness and suitability for your application.