

Simulation Project

Thermoelectric Plants Events System

Daniel Machado Pérez daniel.machado.0206@gmail.com

Daniel Toledo Martínez daniel.020126@gmail.com

Oswaldo R. Moreno P. osvaldo020213@gmail.com

Mathematics and Computer Science Faculty, University of Havana

June 2024

Contents

1	Abstract	3
2	Introduction	3
2.1	Brief project description	3
2.2	Objectives and goals	3
2.3	Variables describing the problem	4
2.3.1	Time between breakdowns of a thermoelectric plant . . .	4
2.3.2	Repair time of a thermoelectric plant	5
2.3.3	Daily energy demand of a circuit	5
3	Implementation Details	6
3.1	Implemented classes	6
3.2	Jupyter Notebook	6
3.3	Simulation	7
3.4	Agent strategies	7
4	Results and Experiments	7

1 Abstract

This project focuses on simulating a system of thermoelectric plants that provide power to various circuits. Within this system, events can disrupt the optimal functioning of the thermoelectric plants, reducing their capacity to meet circuit demand. To manage these situations, the system includes a scheduler that can choose to either perform maintenance on the thermoelectric plants or shut down a circuit. The aim of the simulation is to study the system's behavior over a specific period and analyze the results to optimize its operation.

To start, we analyzed the system's behavior over time without scheduler intervention, regardless of any resulting energy deficit. This analysis will help us develop a maintenance strategy. Additionally, we considered the produced deficit to determine the appropriate timing for circuit shutdowns.

2 Introduction

2.1 Brief project description

The system consists of a collection of thermoelectric plants that supply power to various circuits. Each thermoelectric plant has a specific energy generation capacity, which can be impacted by events occurring over time. These events can be categorized into two types: maintenance events and break events.

Break events occur when a thermoelectric plant is in a failure state, causing it to stop generating energy. In such cases, the thermoelectric plant needs repairs, which require a certain duration. Once the repairs are completed, the thermoelectric plant resumes its normal operational state.

A maintenance event occurs when the scheduler decides that a thermoelectric plant needs maintenance based on a specific criterion, such as the potential proximity of a break event. In this case, the thermoelectric plant is taken out of circulation and enters a state of repair, which should be shorter than when a break occurs. Once maintenance is completed, the thermoelectric plant resumes supplying the system with its energy generation capacity.

Each circuit has an energy demand that must be met by the thermoelectric plants. If the energy produced by the thermoelectric plants is insufficient to meet the circuits' demand, the system experiences an energy deficit. In such a scenario, the scheduler must decide under what criteria and in what proportion to shut down a circuit. Shutting down a circuit means the circuit will not receive energy for a certain period, resulting in a certain percentage reduction in its demand.

2.2 Objectives and goals

We want to compare different planning strategies for managing thermoelectric plants. Specifically, we want to determine which of the following heuristics is more effective in certain scenarios:

- Always waiting for breakdowns to occur before carrying out repairs.
- Scheduling systematic maintenance for the thermoelectric plants before a potential breakdown occurs.

We want to analyze this in two different scenarios:

- Electricity generation meets demand from the start because the system is sufficiently robust.
- The system fails to meet demand due to its initial characteristics and dimensions.

2.3 Variables describing the problem

To describe our problem, we need variables that allow us to represent the following phenomena:

- Time between breakdowns of a thermoelectric plant
- Repair time of a thermoelectric plant
- Daily energy demand of a circuit

2.3.1 Time between breakdowns of a thermoelectric plant

According to the literature, $Weibull(\alpha, \lambda)$ is a distribution commonly used to model the distribution of failures (in systems) when the failure rate is proportional to a power of time, where α is the shape parameter and λ is the scale parameter of the distribution.

- A value $\alpha < 1$ indicates that the failure rate decreases over time.
- When $\alpha = 1$, the failure rate is constant over time.
- A value $\alpha > 1$ indicates that the failure rate increases over time.

The parameter λ is a scale factor that stretches or compresses the distribution. It provides an estimate of the "characteristic life" of the product, which is the time at which 63.2% of the equipment will have failed.

Weibull analysis helps predict the future failure behavior of a component or system. This predictive capability assists in planning maintenance activities, reducing unplanned downtime, and increasing overall system efficiency.

Probability Cumulative Function: $F(x) = 1 - e^{(-\lambda x)^\alpha}$, for $x > 0$

To generate values with a Weibull distribution, we use its implementation from the Python **random** library.

2.3.2 Repair time of a thermoelectric plant

A log-normal distribution is a probability distribution of a random variable whose logarithm is normally distributed. In other words, if a variable X follows a log-normal distribution, then $\ln(X)$ follows a normal distribution. The log-normal distribution is useful for modeling positive data that are asymmetric and have a long right tail, meaning that high extreme values are more common.

Due to this characteristic, such a distribution fits well in this part of our problem, as repair times are more likely to be concentrated towards the right (higher) end of the data.

Properties of the Log-normal Distribution:

Mathematical Definition: If X is a log-normally distributed random variable, then:

$$X \sim \text{Lognormal}(\mu, \sigma^2) \Rightarrow \ln(X) \sim N(\mu, \sigma^2)$$

Here, μ and σ are the parameters of the normal distribution of $\ln(X)$, where μ is the mean and σ^2 is the variance.

Probability Density Function (PDF):

The probability density function of a log-normal distribution is defined as:

$$f_X(x) = \frac{1}{x\sigma\sqrt{2\pi}} e^{\left(-\frac{(\ln(x)-\mu)^2}{2\sigma^2}\right)}, \text{ for } x > 0$$

2.3.3 Daily energy demand of a circuit

Similarly, the daily energy consumption of a circuit can be modeled with a log-normal distribution, as it is assumed that the consumption would be concentrated towards higher values.

To obtain values with a log-normal distribution, the generator implementation from Python's **random** library was used.

3 Implementation Details

Our investigation was made using Python. As external sources, we used the following libraries for data processing:

- random (rnd)
- numpy (np)
- matplotlib.pyplot (plt)

3.1 Implemented classes

- Weibull and LogNormal for each thermoelectric to keep track of their distribution parameters, each of these classes uses the corresponding distribution from rnd.
- ThermoElectric and Circuit were created to keep track of our entities' characteristics such as every thermoelectric's generation capacity and its previous and future events. Circuits are a similar case, they have their electric demand value, their history of deficit values, and the total deficit value.
- Event class name is self-representative, this class contains when each thermoelectric breaks and when it's repaired.
- In the Agent class, we store the different planning strategies for all different comparisons and posterior data analysis.
- Finally, RoundRobin enables the rotation of circuits when it is necessary to have power outages because the demand exceeds the generation capacity.

3.2 Jupyter Notebook

Thermoelectric generation

- Weibull class receives as α a random value between 40 and 70 and a λ value between 1 and 3. (Note: The implementation of Weibull in **random** receives the scale parameter as the first parameter (α), and the second one is the shape parameter (λ))
- LogNormal receives a random uniform between 2 and 2.5 as μ and another random value between 0.2 and 0.4 as σ^2 .
- The electric generation has a random value between 200 and 1000.

We have auxiliary methods to obtain the next general event given the current day, to determine the average working time of all thermoelectric plants given their final state over time after running a single simulation. We also have a

method to run a single simulation, in which the output is the state of all thermoelectric plants during the simulation, and a method to run k consecutive simulations with different parameters, the output of which is the average working days after the k -th simulation.

3.3 Simulation

The **simulate** function simulates the operation of a set of thermoelectric devices over a specified number of days.

It takes the following parameters:

- **thermoelectrics**: a list of thermoelectric devices to simulate.
- **days**: the number of days to run the simulation.
- **agent**: an optional agent that can manage the thermoelectrics and circuits.
- **circuits**: an optional list of circuits that the thermoelectrics are connected to.
- **stored_energy**: the initial amount of stored energy.
- **rotation**: the rotation strategy for the circuits.

The function initializes lists to keep track of the working state of the thermoelectrics, the energy deficit per day, and the stored energy per day.

It then enters a loop that runs for the specified number of days. For each day, it calculates the total demand from the circuits, allows the agent to manage the thermoelectrics and circuits, and processes any events that occur on that day.

The function then calculates the total energy offer from the working thermoelectrics and the stored energy, and calculates the energy deficit and stored energy for the day.

Finally, it returns lists representing the working state of the thermoelectrics, the energy deficit per day, the stored energy per day, and the circuits.

3.4 Agent strategies

- **empty_strategy**: does nothing
- **give_maintenance_heuristic**: gives maintenance to a thermoelectric if it has been working for an amount of days equal to the average break time calculated with a k -simulation
- **disconnect_circuit_heuristic**: turn off the next circuit clockwise $1/4$ of the time until generation is above consume

4 Results and Experiments