

Indusoft

terça-feira, 18 de outubro de 2022 19:09

New

Project

File

Create new Project with the specified settings

Project name:
revisao

Location:
C:\Users\danub\Desktop\Supervisorio Revisao\ Browse

Configuration file:
C:\Users\danub\Desktop\Supervisorio Revisao\revisao\revisao.app

Target platform*: (All) v

Product type*:

Windows Advanced Server	Windows Operator Workstation	Windows Lite Interface Plus
Windows Control Room	Embedded Professional	Embedded Lite Plus
Windows Control Room Lite	Windows Local Interface	Windows Lite Interface
Windows Operator Workstation Plus	Embedded Standard	Embedded Lite

< >
Operator Workstation for Windows (4000 tags)

*Select Windows target platform for Windows Server/Desktop projects. Select Embedded target platform for Windows Embedded and IoTView projects (Windows Embedded Compact (Windows CE), Windows Mobile, Linux, VxWorks, etc.).

*You can modify the target platform and product type after creating the project by using the Project tab.

OK Cancel

Home View Insert Project Help

Target System (Operator Workstation) v

Information

Options

Communication

Viewer

Preferences

E-Mail/FTP

Service

Configure

Log On

Access level

Web




Mobile Access

Mobile Access Tabular

Settings

Security System

Web



Communication Drivers

Available drivers:

DLL	Description
MITSU	MITSUBISHI Protocol, FX Series (CE) [v10.8]
MODBU	MODBUS Protocol RTU/ASCII (CE) [v10.12]
MODPL	MODBUS PLUS Protocol [v1.11]
MODSL	Protocol ModBus Slave(ASCII and RTU)(Serial and TCP/IP) (CE)[3.3]
MOLOW	MOLOW Protocol RTU/ASCII [v1.1]
MOTCP	MODBUS Protocol RTU via TCP/IP (CE) [v10.19]
MPI	SIEMENS, MPI Protocol - S7 [v1.30]
MPIAD	SIEMENS, MPI Green Cable Protocol - 3964R (CE) [v1.0]

Help

Select >>

Selected drivers:

DLL	Description
SCHNE	Schneider - Modbus Ethernet for M340 and Premium compatible devices (CE) v1...

>> Remove

OK

Cancel

SCHNE - Tags Drives

Description:

Tags Drives

Disable:

Read Completed:

Read Status:

Min:

Write Completed:

Write Status:

Max:

	Tag Name	Station	I/O Address	Action	Scan	Div	Add
	Filter text	Filter text	Filter text	(All)	(All)	Filter text	Filter text
1	DEV.B0sup	127.0.1.1:502		Read+Write	Always		
2	DEV.B1sup	127.0.1.1:502		Read+Write	Always		
3	DEV.B2sup	127.0.1.1:502		Read+Write	Always		
4	DEV.K1sup	127.0.1.1:502		Read+Write	Always		
5	DEV.K2sup	127.0.1.1:502		Read+Write	Always		
6	DEV.L1sup	127.0.1.1:502		Read+Write	Always		
7	DEV.L2sup	127.0.1.1:502		Read+Write	Always		
8	DEV.L3sup	127.0.1.1:502		Read+Write	Always		
9				Read+Write	Always		
10				Read+Write	Always		
11				Read+Write	Always		
*				Read+Write	Always		
*				Read+Write	Always		

A

Text

Pushbutton

Combo Box

Text Box

Check Box

List Box

Button

Radio Button

Smart Message

Active Objects