

Simulation of ARMAX model for Forecast of Power Output of a Photo-Voltaic Grid

Juan S. Cárdenas R.
Student
Universidad EAFIT
Medellín, Colombia
jscardenar@eafit.edu.co

David Plazas E.
Student
Universidad EAFIT
Medellín, Colombia
dplazas@eafit.edu.co

Abstract—This work is devoted to the simulation of an ARMAX model proposed in the literature for better forecasting of power output of a Photo-Voltaic (PV) grid; the model includes information of environmental inputs (average temperature, precipitation amount, insolation duration, humidity) that classical time series approaches did not include. The simulation is performed using three different noise distributions in order to establish a comparison of the time series.

Index Terms—ARMAX, Photo-Voltaic grid, simulation, random noise, outliers, environmental inputs, time series.

I. INTRODUCTION

Photo-Voltaic (PV) systems, nowadays, are growing relevant due to the increasing obligation to global warming and production of renewable energies. It is often desired to forecast the amount energy that can be obtained through these systems, in order plan its distribution and usage.

II. PROBLEM FORMULATION

As previously mentioned, the output of the PV system is an stochastic process. The standard approach to forecasting the behavior of this system has been modelled using ARIMA models, using only information of the past of the same system, but it does not take into consideration the external environmental factors that may affect the power output [1]; as for the problem of this particular work, the main objective is to simulate the ARMAX model proposed in [1] with different noise distributions, particularly with outlier behavior.

III. THEORETICAL APPROACH

A. General ARMAX model

This work uses an ARMAX model presented in the literature; hereby, let the general ARMAX model be presented:

$$z_{t+1} = \sum_{i=0}^{h_1} a_i z_{t-i} + \sum_{i=0}^{h_2} b_i u_{t-i} + \sum_{i=0}^{h_3} c_i \xi_{t-i} \quad (1)$$

for $t = 0, 1, 2, \dots$, and u_k are external inputs and ξ_k are random noises.

B. Rössler System

The Rössler system is a set of ordinary differential equations given by:

$$\begin{cases} \dot{x} = -y - z \\ \dot{y} = x + ay \\ \dot{z} = b + z(x - c). \end{cases} \quad (2)$$

These equations originally proposed by O. Rössler in [2]; it is well-known that, under certain parameters, the output of the state variable z presents peaks in a aperiodic manner [3]. This model is used to emulate the behavior of one of the inputs for the ARMAX model, since it presents quite an unusual behavior and this method gives a decent representation.

IV. NUMERICAL ASPECTS

In this particular case, the model obtained in [1] is:

$$z_t = 237.565 + 0.426z_{t-1} + \xi_t - 0.153\xi_{t-1} + 8.9087u_{1,t} - 1.557u_{7,t} + 31.919u_{8,t} - 2.045u_{9,t} \quad (3)$$

where z_t is the power output of the PV grid in Watts (W); $u_{1,t}$ is the daily average temperature, $u_{7,t}$ is the precipitation amount, $u_{8,t}$ is the insolation duration and $u_{9,t}$ is the humidity.

V. NUMERICAL RESULTS

In the following figures, the simulations of the model for different distributions can be found.




Figure 1: Results using Normal and Cauchy distribution.




Figure 2: Results using Normal and T-Student distribution.

VI. CONCLUSIONS

REFERENCES

- [1] Y. Li, Y. Su, and L. Shu, "An armax model for forecasting the power output of a grid connected photovoltaic system," *Renewable Energy*, vol. 66, pp. 78–89, 2014.
- [2] O. E. Rössler, "An equation for continuous chaos," *Physics Letters A*, vol. 57, no. 5, pp. 397–398, 1976.
- [3] V. Canals, A. Morro, and J. L. Rosselló, "Random number generation based on the rossler attractor," *IEICE Proceeding Series*, vol. 1, pp. 272–275, 2014.