

Standard Operating Procedure — Pump P-204

Document ID: SOP-P204 Rev 3.1 | Date: 2026-07-01

1. Normal Operating Pressure: 2.1 - 3.4 bar
2. Inspection Interval: 30 days
3. Shutdown Procedure §4.2: If pressure exceeds 4.0 bar, notify supervisor.
4. Do NOT restart pump without maintenance verification if pressure > 4.5 bar.
5. Valve replacement requires sign-off by reliability engineer.

This SOP governs pump P-204 operation in Unit 3.

Pressure thresholds are calibrated quarterly.

Contact: reliability@plant.local