





121°53'30° 121°53'33° 121°53'35° 121°53'38° 121°53'40°

2 SITE DEV. PLAN
SCALE: NTS



REPUBLIC OF THE PHILIPPINES DEPARTMENT OF PUBLIC WORKS, TRANSPORTATION & COMMUNICATION OFFICE OF THE BUILDING OFFICIALS

DISTRICT/CITY/MUNICIPALITY

LAND USE AND ZONING

LINE AND GRADE

ARCHITECTURAL

STRUCTURAL

SANITARY

ELECTRICAL

MECHANICAL

FIRE

PROJECT TITLE:

CHECKED BY:

RECOMMENDING APPROVAL:

APPROVED:

REVISIONS: SHEET CONTENT:

SHEET NO.:

PROPOSED CONSTRUCTION OF SEA CUCUMBER HATCHERY AND NURSERY PRODUCTION

LOCATION: BANUYO, GASAN, MARINDUQUE

DR. ALEXANDER M. PASCUA
AGRICULTURAL & BIOSYSTEUS BYGINEER


ARRAYNARD M. MUHI, MSCM
HEAD, PHYSICAL FACULTIES & PROJECT MANAGEMENT


VP-ADMINISTRATION & FINANCE


SUC PRESIDENT III


DRAWN / CADD BY: ATL


DRAWN / CADD BY: ATL













CKT. NO.	LOAD DESCRIPTION	NO.OF OUTLETS	V/A	٧	Α	CB SIZE	SIZE OF WIRE & CONDUIT
1	MAIN						
2	LIGHTING	9	900	230	3.91	15 A	2 -WIRE NO.2.0mm² THHN -1/2" PVC
3	WATER PUMP(WP)	1	2760	230	12	30 A	2 -WIRE NO.5.5mm² THHN -1/2" PVC
4	C.O	4	720	230	3.13	20 A	2 -WIRE NO.3.5mm² THHN -1/2" PVC

LIGHT OUTLET / CFL POWER LINE LIGHTING LINE SWITCH LINE SINGLE CONVENIENCE OUTLET DUPLEX CONVENIENCE OUTLET WATER PUMP PANEL BOARD CIRCUIT HOMERUN

SERVICE ENTRANCE CONDUCTORS: USE 2- 22 mm² THHN Cu WIRES 4,380 / 230 V = 19.043 AMPS

IT =4,380 X 80%

230

=15.234 AMPS

SERVICE ENTRANCE CONDUCTORS:

SERVICE EQUIPMENT


USE 1-30A, 2 POLE, 240 VAC C.B



## **SCHEDULE OF LOADS & COMPUTATIONS**



MARK/ DESCRIPTIO PROPOSED CONSTRUCTION OF AS SHOWN SEA CUCUMBER HATCHERY E-1 15 AND NURSERY PRODUCTION ATTY. CRISPIN FRANCIS M. JANDUSAY AR. MAYNARD M. MUHI, MsCM DIOSDADO P. ZULUETA, FFCP, DPA OCATION : BANUYO, GASAN, MARINDUQUE HEAD, PHYSICAL FACILITIES & PROJECT MANAGEMENT



2 WIRE, 230V, 60Hz

## **ELECTRICAL NOTES:**

 ALL ELECTRICAL INSTALLATION WORKS HERIN SHALL BE DONE IN
THE ACCORDANCE WITH THE PLANS AND SPECIFICATIONS, THE APPLICABLE
PROVISIONS OF THE LATEST EDITION OF THE PHILIPPINE ELECTRICAL CODE, THE RULES & REGULATIONS OF THE LOCAL ENFORCING AUTHORITY AND THE REQUIREMENTS OF THE LOCAL POWER, TELEPHONE AND COMMUNICATION COMPANIES. THE ELECTRICAL WORKS SHALL BE UNDER THE IMMEDIATE SUPERVISION OF A DULY LICENSED ELECTRICAL ENGINEER.

2. UTILITY VOLTAGE TO THE UNIT SHALL BE 3 - PHASE WIRE 230 V 60HZ.

3. THE ELECTRICAL WIRING INSTALLATION SHALL BE DONE IN INTERMEDIATE METALLIC CONDUIT (IMC JINSTALLED BELOW GRADE / SLABS AND WITHIN SLABS SHALL BE RIGID STEEL OR PVC SCHED. 40. FLEXIBLE CONDUITS SHALL BE 15mm INTERNAL DIAMETER.

4. ALL WIRE SHALL BE COPPER, PVC INSULATED AND NYLON JACKETED TYPE "THHN "UNLESS OTHERWISE INDICATED. THE MINIMUM SIZE FOR POWRE SHALL BE IN 3.5mm, AND FOR LIGHTING 2.0mm, CONTROL WIRES SHALL BE AS INDICATED OR AS SPECIFIED ELSEWHERE IN THE PLAN.

5. THE CONTRACTOR SHALL VERIFY AND ORIENT THE ACTUAL LOCATION. THE SERVICE ENTRANCE FOR CONNECTION TO THE POWER SUPPLY AND ALSO THE ACTUAL LOCATION OF TELEPHONE SYSTEM ENTRANCE FOR CONNECTION TO THE LOCAL TELEPHONE CABLE FACILITIES.

6. THE MOUNTING HEIGHTS OF WIRING DEVICES SHALL BE AS FOLLOWS:
a.) LIGHT SWITCHES
1.30 m ABOVE FLOOR FINISI

ABOVE FLOOR FINISH b.) CONVENIENCE OUTLETS 0.30 m 0.30 m

do / AS REQUIRED do / AS REQUIRED do / AT CENTER C I TELEPHONE OUTLET d.) PANEL BOARDS & CABINETS 140. m ALL MOUNTING HEIGHTS SHALL BE CONFIRMED WITH THE ARCHITECT

ALL MOUNTING HEIGHTS SHALL BE CONFIRMED WITH THE ARCHITECT PRIOR TO INSTALLATION.

7. FOR EACH SPARE BRANCH CIRCUIT IN PANELBOARDS, PROVIDE ONE 20mm DIAMETER CONDUITS TERMINATED TO A 100 mm OCTAGONAL BOX

ABOVE CELLING

8. PROVIDE PULL WIRES IN ALL EMPTY CONDUITS.

9. SPECIFY THE SERVICE NEEDED NUMBER OF PHASES, VOLTAGE & FREQUENCY

10. SPECIFY IF THERE WILL BE A PHASE CONVERTER AND / OR

TRANSFORMER FOR OTHER EQUIPMENT.

11. USE GREEN CONDUCTOR FOR DROUND & WHITE FOR NUETRAL.

12. GENERATOR SPECS.