



FULL KPI MATRIX

CATEGORY	2022	2023	2024	2025	2026	TOTAL
A. Production						
Measured (MWh)	164,928	173,696	160,983	161,673	68,406	729,686
Deviation Historical	-	7.0%	-3.6%	-1.8%	-10.5%	-1.0%
Deviation P50	-	-	-	-	-20.6%	-20.6%
Deviation P90	-	-	-	-	-9.1%	-9.1%
Capacity Factor	29.2%	30.7%	28.4%	28.6%	24.4%	28.7%
Electrical Losses	1.6%	1.2%	0.6%	0.4%	1.7%	1.0%
B. Consumption						
Measured Consumption (MWh)	565	585	584	653	323	2,710
Ratio to Production	0.4%	0.4%	0.4%	0.4%	0.6%	0.4%
C. Availability						
Contractual availability	97.0%	95.5%	94.9%	97.0%	97.0%	96.2%
Technical availability	96.6%	95.7%	90.2%	92.6%	88.5%	93.2%
Technical availability - Energy based	97.4%	95.9%	95.3%	97.4%	96.7%	96.5%
D. Downtime						
Manufacturer	0.936%	1.482%	1.723%	0.900%	0.954%	1.226%
Owner	0.000%	0.000%	0.000%	0.000%	0.003%	0.000%
Environmental	0.010%	0.007%	0.003%	0.015%	0.024%	0.011%
Utility	0.127%	0.059%	0.232%	0.939%	2.267%	0.554%
Bat Curtailment	0.015%	0.000%	0.197%	0.267%	0.097%	0.117%
E. Wind						
Forecasted WS (m/s)	8.2 m/s	8.2 m/s	8.2 m/s	8.2 m/s	8.1 m/s	8.2 m/s
Measured WS (m/s)	6.3 m/s	6.5 m/s	6.4 m/s	6.3 m/s	6.1 m/s	6.3 m/s
WindSpeed Deviation	-23.5%	-20.7%	-22.2%	-23.3%	-24.6%	-22.7%


PRODUCTION VS TARGET




TURBINE-LEVEL PRODUCTION & AVAILABILITY



AVAILABILITY TREND



WIND RESOURCE



DOWNTIME BY CAUSE

