



FULL KPI MATRIX

CATEGORY	2022	2023	2024	2025	2026	TOTAL
A. Production						
Measured (MWh)	5,484	111,398	134,334	128,319	57,288	436,824
Deviation Historical	-	-13.7%	2.8%	-2.2%	-8.3%	-4.9%
Deviation P50	-	-	-	-	-14.1%	-14.1%
Deviation P90	-	-	-	-	-3.5%	-3.5%
Capacity Factor	1.8%	36.8%	44.4%	42.5%	38.3%	32.1%
Electrical Losses	-95.8%	-15.5%	1.6%	0.9%	0.0%	-24.6%
B. Consumption						
Measured Consumption (MWh)	172	174	186	166	87	785
Ratio to Production	0.1%	0.1%	0.1%	0.1%	0.2%	0.1%
C. Availability						
Contractual availability	-	97.3%	96.5%	97.9%	98.4%	97.4%
Technical availability	100.0%	96.6%	95.5%	97.3%	97.5%	97.4%
Technical availability - Energy based	4.3%	96.0%	96.6%	98.2%	98.4%	76.5%
D. Downtime						
Manufacturer	0.000%	1.940%	1.981%	0.973%	1.142%	1.214%
Owner	0.000%	0.000%	0.000%	0.001%	0.000%	0.000%
Environmental	0.000%	0.013%	0.012%	0.017%	0.006%	0.010%
Utility	0.000%	0.178%	0.485%	1.529%	1.897%	0.698%
Bat Curtailment	0.000%	0.000%	0.000%	0.000%	0.000%	0.000%
E. Wind						
Forecasted WS (m/s)	8.3 m/s	8.3 m/s	8.3 m/s	8.3 m/s	7.9 m/s	8.3 m/s
Measured WS (m/s)	7.8 m/s	7.9 m/s	8 m/s	7.8 m/s	7.5 m/s	7.8 m/s
WindSpeed Deviation	-6.3%	-5.3%	-3.7%	-6.0%	-4.2%	-5.2%


PRODUCTION VS TARGET




TURBINE-LEVEL PRODUCTION & AVAILABILITY



AVAILABILITY TREND



WIND RESOURCE



DOWNTIME BY CAUSE

