


FULL KPI MATRIX


CATEGORY	2022	2023	2024	2025	2026	TOTAL
A. Production						
Measured (MWh)	56,966	60,670	59,862	54,656	25,259	257,414
Deviation Historical	–	7.0%	2.4%	-6.9%	-5.5%	-0.1%
Deviation P50	-67.2%	-65.1%	-11.4%	-19.1%	-19.2%	-49.9%
Deviation P90	-62.5%	-60.1%	-3.5%	-7.5%	-7.6%	-43.1%
Capacity Factor	30.2%	32.1%	31.6%	28.9%	27.0%	30.3%
Electrical Losses	0.6%	0.8%	1.0%	-2.1%	1.2%	0.2%
B. Consumption						
Measured Consumption (MWh)	136	131	134	143	86	630
Ratio to Production	0.3%	0.3%	0.2%	0.3%	0.4%	0.3%
C. Availability						
Contractual availability	96.8%	97.2%	97.0%	97.2%	97.2%	97.1%
Technical availability	96.3%	96.9%	94.2%	94.0%	91.4%	94.9%
Technical availability - Energy based	97.1%	97.6%	97.8%	97.4%	97.3%	97.4%
D. Downtime						
Manufacturer	0.969%	0.832%	0.748%	0.784%	1.018%	0.854%
Owner	0.002%	0.001%	0.000%	0.001%	0.000%	0.001%
Environmental	0.010%	0.006%	0.006%	0.009%	0.004%	0.007%
Utility	0.059%	0.051%	0.158%	0.378%	0.586%	0.209%
Bat Curtailment	0.009%	0.002%	0.060%	0.149%	0.108%	0.061%
E. Wind						
Forecasted WS (m/s)	7.2 m/s	7.2 m/s	7.2 m/s	7.2 m/s	7 m/s	7.2 m/s
Measured WS (m/s)	6.4 m/s	6.6 m/s	6.6 m/s	6.5 m/s	6.3 m/s	6.5 m/s
WindSpeed Deviation	-11.3%	-8.6%	-8.0%	-10.1%	-9.5%	-9.5%

GRAPHICAL DASHBOARD — 2026


PRODUCTION VS TARGET




TURBINE-LEVEL PRODUCTION & AVAILABILITY



AVAILABILITY TREND



DOWNTIME BY CAUSE



WIND RESOURCE

