



FULL KPI MATRIX

CATEGORY	2022	2023	2024	2025	2026	JAN	FEB	MAR	APR	MAY	JUN	TOTAL
A. Production												
Measured (MWh)	162,374	171,642	160,007	160,758	67,276	13,718	11,001	8,118	11,322	11,569	11,549	722,057
Deviation Historical	–	5.7%	-4.2%	-2.4%	-12.0%	11.2%	-4.4%	-31.6%	5.2%	-2.3%	-36.3%	-1.9%
Deviation P50	-7.4%	-10.2%	-16.3%	-15.9%	-21.9%	17.7%	-20.0%	-43.4%	-12.9%	-21.4%	-38.3%	-13.5%
Deviation P90	-2.7%	2.9%	-4.1%	-3.6%	-10.6%	34.8%	-8.4%	-35.1%	-0.2%	-9.9%	-29.4%	-2.8%
Capacity Factor	29.2%	30.7%	28.4%	28.6%	24.4%	29.0%	25.8%	17.3%	24.7%	24.6%	25.3%	28.7%
Electrical Losses	1.6%	1.2%	0.6%	0.4%	1.7%	1.5%	1.6%	2.0%	1.4%	2.0%	1.6%	1.0%
B. Consumption												
Measured (MWh)	565	585	584	653	362	57	65	86	60	54	39	2,749
Ratio to Production	0.4%	0.4%	0.4%	0.4%	0.6%	0.4%	0.6%	1.1%	0.5%	0.5%	0.3%	0.4%
C. Availability												
TBA - Contractual	97.0%	95.5%	94.9%	97.0%	97.0%	98.1%	96.2%	97.3%	96.4%	96.4%	97.3%	96.2%
TBA - Technical	96.6%	95.7%	90.2%	92.6%	88.5%	98.1%	90.7%	87.9%	80.9%	82.8%	90.8%	93.2%
PBA - Technical	97.4%	95.9%	95.3%	97.4%	96.7%	98.0%	95.9%	96.9%	97.1%	95.3%	97.2%	96.5%
D. OLF - Losses												
Manufacturer	3.0%	4.4%	5.1%	2.7%	3.2%	2.0%	3.8%	3.1%	3.0%	4.7%	2.8%	3.7%
Owner	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.1%	0.0%	0.0%	0.0%	0.0%	0.0%
Environmental	0.0%	0.0%	0.0%	0.0%	0.1%	0.3%	0.1%	0.1%	0.0%	0.0%	0.0%	0.0%
Utility	0.4%	0.2%	0.6%	2.7%	10.4%	0.0%	0.0%	13.1%	16.6%	11.6%	21.2%	2.0%
Bat Curtailment	0.0%	0.0%	0.7%	1.0%	0.4%	0.0%	0.4%	0.6%	0.8%	0.8%	0.0%	0.4%
E. Wind												
Forecasted WS (m/s)	6.7	6.7	6.7	6.7	6.6	6.5	6.6	6.2	6	6.8	7.3	6.7
Measured WS (m/s)	6.3	6.5	6.4	6.3	6.1	6.2	5.8	5.3	6.2	6.5	6.5	6.3
WindSpeed Deviation	-6.6%	-3.1%	-5.0%	-6.4%	-7.5%	-5.3%	-12.0%	-15.3%	3.0%	-4.9%	-10.6%	-5.5%


PLANT PRODUCTION




ANNUAL PRODUCTION AND AVAILABILITY PER WT



PLANT AVAILABILITY



OPERATIONAL LOSS FACTORS



WIND SPEED

