



FULL KPI MATRIX

CATEGORY	2022	2023	2024	2025	2026	JAN	FEB	MAR	APR	MAY	JUN	TOTAL
A. Production												
Measured (MWh)	90,260	92,833	92,112	87,117	39,337	6,386	5,427	5,675	7,217	6,864	7,770	401,659
Deviation Historical	–	2.9%	0.6%	-5.0%	-6.8%	2.1%	-5.2%	-17.1%	5.3%	1.8%	-20.8%	-1.4%
Deviation P50	-11.7%	-54.6%	-55.0%	-57.4%	-59.9%	-60.5%	-59.8%	-60.4%	-54.2%	-61.4%	-62.4%	-50.7%
Deviation P90	1.4%	4.3%	3.5%	-2.1%	-8.0%	-9.2%	-7.6%	-8.9%	5.3%	-11.4%	-13.6%	0.7%
Capacity Factor	42.4%	43.4%	43.1%	40.6%	37.2%	35.3%	33.2%	31.4%	41.2%	38.0%	44.4%	41.8%
Electrical Losses	1.2%	1.0%	1.2%	0.6%	1.2%	1.1%	1.1%	1.2%	1.2%	1.2%	1.1%	1.0%
B. Consumption												
Measured (MWh)	100	83	117	118	90	15	12	19	19	17	8	508
Ratio to Production	0.1%	0.1%	0.1%	0.1%	0.2%	0.2%	0.2%	0.3%	0.3%	0.3%	0.1%	0.1%
C. Availability												
TBA - Contractual	93.9%	88.5%	96.3%	96.9%	95.7%	96.9%	90.2%	92.8%	98.0%	99.5%	97.0%	94.1%
TBA - Technical	93.7%	88.7%	92.9%	92.3%	91.4%	93.0%	86.8%	86.6%	92.1%	92.6%	97.1%	91.9%
PBA - Technical	97.2%	95.6%	95.5%	95.4%	95.7%	97.9%	89.5%	92.6%	98.3%	98.7%	97.5%	95.9%
D. OLF - Losses												
Manufacturer	2.8%	4.4%	2.6%	2.6%	4.3%	2.2%	10.5%	7.4%	1.7%	1.3%	2.5%	3.2%
Owner	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.1%	0.0%	0.0%	0.0%	0.0%
Environmental	0.0%	0.0%	1.9%	1.9%	0.8%	1.6%	1.1%	1.7%	0.0%	0.0%	0.0%	0.9%
Utility	0.1%	0.0%	0.4%	1.7%	3.6%	1.5%	0.1%	1.4%	10.0%	8.0%	0.8%	0.9%
Bat Curtailment	0.0%	0.0%	0.1%	0.4%	0.2%	0.1%	0.2%	0.2%	0.3%	0.3%	0.0%	0.1%
E. Wind												
Forecasted WS (m/s)	8.2	8.2	8.2	8.2	8.1	7.9	7.8	7.6	7.4	8.4	9.3	8.2
Measured WS (m/s)	7.6	8	7.8	7.7	7.4	6.9	7	6.7	7.9	7.9	7.8	7.7
WindSpeed Deviation	-7.2%	-3.1%	-4.7%	-6.8%	-8.4%	-12.8%	-10.1%	-11.7%	6.3%	-5.6%	-16.5%	-5.8%


PLANT PRODUCTION




ANNUAL PRODUCTION AND AVAILABILITY PER WT



PLANT AVAILABILITY



OPERATIONAL LOSS FACTORS



WIND SPEED

