



FULL KPI MATRIX

CATEGORY	2022	2023	2024	2025	2026	JAN	FEB	MAR	APR	MAY	JUN	JUL	TOTAL
A. Production													
Measured (MWh)	56,701	60,160	59,270	55,978	26,888	3,776	3,414	3,876	5,080	4,516	4,295	1,930	258,997
Deviation Historical	–	6.1%	1.4%	-4.7%	-20.2%	3.7%	1.5%	-7.1%	22.3%	-8.8%	-33.4%	-72.2%	-2.5%
Deviation P50	-55.1%	-52.3%	-4.8%	-56.9%	-31.0%	-8.4%	-8.1%	-18.0%	-2.3%	-23.1%	-43.7%	-74.9%	-46.4%
Deviation P90	-59.5%	-57.0%	8.9%	-5.2%	-21.1%	4.8%	5.1%	-6.3%	11.7%	-12.1%	-35.6%	-71.3%	-39.4%
Capacity Factor	30.2%	32.1%	31.6%	28.9%	26.5%	23.9%	23.9%	24.5%	33.1%	28.6%	28.0%	23.4%	30.2%
Electrical Losses	0.6%	0.8%	1.0%	-2.1%	1.2%	1.2%	1.2%	1.3%	1.1%	1.2%	1.2%	–	0.2%
B. Consumption													
Measured (MWh)	136	131	134	143	96	17	21	19	14	15	10	–	639
Ratio to Production	0.3%	0.3%	0.2%	0.3%	0.4%	0.5%	0.6%	0.5%	0.3%	0.3%	0.2%	–	0.3%
C. Availability													
Contractual - Time Based	96.8%	97.2%	97.0%	97.2%	97.4%	97.7%	96.8%	97.1%	98.5%	96.8%	96.2%	99.0%	97.1%
TBA - Time Based	96.3%	96.9%	94.2%	94.0%	92.3%	93.1%	90.2%	91.5%	91.7%	88.5%	93.4%	97.7%	94.9%
PBA - Energy Based	97.1%	97.6%	97.8%	97.4%	97.6%	98.1%	97.4%	97.6%	98.9%	95.4%	96.6%	99.1%	97.5%
D. OLF - Losses													
Manufacturer	3.2%	2.5%	2.3%	2.7%	4.0%	1.9%	2.6%	3.2%	4.0%	6.4%	5.3%	4.8%	2.9%
Owner	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
Environmental	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
Utility	0.2%	0.1%	0.6%	1.1%	2.9%	0.8%	0.0%	1.4%	4.3%	4.2%	5.5%	4.3%	0.8%
Bat Curtailment	0.0%	0.0%	0.2%	0.6%	0.4%	0.4%	0.8%	0.5%	0.4%	0.7%	0.0%	0.0%	0.2%
E. Wind													
Forecasted WS (m/s)	7.2	7.2	7.2	7.2	7.1	6.5	6.5	6.6	6.7	7.5	8.1	7.9	7.2
Measured WS (m/s)	6.4	6.6	6.6	6.5	6.2	5.8	5.8	5.9	6.9	6.9	6.5	5.9	6.5
WindSpeed Deviation	-11.3%	-8.6%	-8.0%	-10.1%	-11.9%	-11.3%	-11.0%	-10.4%	3.3%	-7.9%	-19.9%	-25.9%	-9.8%


PLANT PRODUCTION




ANNUAL PRODUCTION AND AVAILABILITY PER WT



PLANT AVAILABILITY



OPERATIONAL LOSS FACTORS



WIND SPEED

