



FULL KPI MATRIX

| CATEGORY                 |  | 2022    | 2023    | 2024    | 2025    | 2026   | JAN    | FEB    | MAR    | APR    | MAY    | JUN    | JUL    | TOTAL   |
|--------------------------|--|---------|---------|---------|---------|--------|--------|--------|--------|--------|--------|--------|--------|---------|
| A. Production            |  |         |         |         |         |        |        |        |        |        |        |        |        |         |
| Measured (MWh)           |  | 162,374 | 171,642 | 160,007 | 160,758 | 71,480 | 13,718 | 11,001 | 8,118  | 11,322 | 11,569 | 11,549 | 4,204  | 726,261 |
| Deviation Historical     |  | –       | 5.7%    | -4.2%   | -2.4%   | -23.8% | 11.2%  | -4.4%  | -31.6% | 5.2%   | -2.3%  | -36.3% | -75.8% | -4.1%   |
| Deviation P50            |  | -7.5%   | -10.2%  | -16.3%  | -15.9%  | -32.3% | 17.7%  | -20.0% | -43.4% | -12.9% | -21.4% | -38.3% | -78.4% | -15.0%  |
| Deviation P90            |  | -2.7%   | 2.9%    | -4.1%   | -3.6%   | -22.5% | 34.8%  | -8.4%  | -35.1% | -0.2%  | -9.9%  | -29.4% | -75.3% | -4.4%   |
| Capacity Factor          |  | 29.2%   | 30.7%   | 28.4%   | 28.6%   | 23.4%  | 29.0%  | 25.8%  | 17.3%  | 24.7%  | 24.6%  | 25.3%  | 17.0%  | 28.5%   |
| Electrical Losses        |  | 1.6%    | 1.2%    | 0.6%    | 0.4%    | 1.7%   | 1.5%   | 1.6%   | 2.0%   | 1.4%   | 2.0%   | 1.6%   | –      | 1.0%    |
| B. Consumption           |  |         |         |         |         |        |        |        |        |        |        |        |        |         |
| Measured (MWh)           |  | 565     | 585     | 584     | 653     | 362    | 57     | 65     | 86     | 60     | 54     | 39     | –      | 2,749   |
| Ratio to Production      |  | 0.4%    | 0.4%    | 0.4%    | 0.4%    | 0.6%   | 0.4%   | 0.6%   | 1.1%   | 0.5%   | 0.5%   | 0.3%   | –      | 0.4%    |
| C. Availability          |  |         |         |         |         |        |        |        |        |        |        |        |        |         |
| Contractual - Time Based |  | 97.0%   | 95.5%   | 94.9%   | 97.0%   | 97.0%  | 98.1%  | 96.2%  | 97.3%  | 96.4%  | 96.4%  | 97.3%  | 97.1%  | 96.2%   |
| TBA - Time Based         |  | 96.6%   | 95.7%   | 90.2%   | 92.6%   | 89.0%  | 98.1%  | 90.7%  | 87.9%  | 80.9%  | 82.8%  | 90.8%  | 91.7%  | 93.2%   |
| PBA - Energy Based       |  | 97.4%   | 95.9%   | 95.3%   | 97.4%   | 96.8%  | 98.0%  | 95.9%  | 96.9%  | 97.1%  | 95.3%  | 97.2%  | 97.1%  | 96.5%   |
| D. OLF - Losses          |  |         |         |         |         |        |        |        |        |        |        |        |        |         |
| Manufacturer             |  | 3.0%    | 4.4%    | 5.1%    | 2.7%    | 3.2%   | 2.0%   | 3.8%   | 3.1%   | 3.0%   | 4.7%   | 2.8%   | 2.8%   | 3.7%    |
| Owner                    |  | 0.0%    | 0.0%    | 0.0%    | 0.0%    | 0.0%   | 0.0%   | 0.1%   | 0.0%   | 0.0%   | 0.0%   | 0.0%   | 0.0%   | 0.0%    |
| Environmental            |  | 0.0%    | 0.0%    | 0.0%    | 0.0%    | 0.1%   | 0.3%   | 0.1%   | 0.1%   | 0.0%   | 0.0%   | 0.0%   | 0.0%   | 0.0%    |
| Utility                  |  | 0.4%    | 0.2%    | 0.6%    | 2.7%    | 11.3%  | 0.0%   | 0.0%   | 13.1%  | 16.6%  | 11.6%  | 21.2%  | 16.6%  | 2.3%    |
| Bat Curtailment          |  | 0.0%    | 0.0%    | 0.7%    | 1.0%    | 0.4%   | 0.0%   | 0.4%   | 0.6%   | 0.8%   | 0.8%   | 0.0%   | 0.0%   | 0.4%    |
| E. Wind                  |  |         |         |         |         |        |        |        |        |        |        |        |        |         |
| Forecasted WS (m/s)      |  | 8.2     | 8.2     | 8.2     | 8.2     | 8.2    | 7.9    | 7.8    | 7.6    | 7.4    | 8.4    | 9.3    | 8.7    | 8.2     |
| Measured WS (m/s)        |  | 6.3     | 6.5     | 6.4     | 6.3     | 5.9    | 6.2    | 5.8    | 5.3    | 6.2    | 6.5    | 6.5    | 5.1    | 6.3     |
| WindSpeed Deviation      |  | -23.5%  | -20.7%  | -22.2%  | -23.3%  | -27.1% | -22.1% | -25.5% | -30.9% | -16.5% | -23.0% | -29.8% | -41.6% | -23.0%  |


PLANT PRODUCTION




ANNUAL PRODUCTION AND AVAILABILITY PER WT



## PLANT AVAILABILITY



## OPERATIONAL LOSS FACTORS



WIND SPEED

