


Grassridge: the plant produced 8.0 GWh, significantly below historical, P50 and P90 targets. Contractual availability averaged 96.2%, while technical availability was lower at 88.5%. Losses were dominated by grid curtailments (recoverable losses).


FULL KPI MATRIX

CATEGORY	2022	2023	2024	2025	2026	JAN	FEB	MAR	APR	MAY	JUN	JUL	TOTAL
A. Production													
Measured (MWh)	162,374	171,642	160,007	160,758	75,270	13,718	11,001	8,118	11,322	11,569	11,549	7,994	730,050
Deviation Historical	–	5.7%	-4.2%	-2.4%	-19.8%	11.2%	-4.4%	-31.6%	5.2%	-2.3%	-36.3%	-54.1%	-3.4%
Deviation P50	-7.4%	-10.2%	-16.3%	-15.9%	-28.8%	17.7%	-20.0%	-43.4%	-12.9%	-21.4%	-38.3%	-59.0%	-14.5%
Deviation P90	-2.7%	2.9%	-4.1%	-3.6%	-18.4%	34.8%	-8.4%	-35.1%	-0.2%	-9.9%	-29.4%	-53.0%	-3.9%
Capacity Factor	29.2%	30.7%	28.4%	28.6%	23.4%	29.0%	25.8%	17.3%	24.7%	24.6%	25.3%	17.0%	28.5%
Electrical Losses	1.6%	1.2%	0.6%	0.4%	1.7%	1.5%	1.6%	2.0%	1.4%	2.0%	1.6%	1.8%	1.1%
B. Consumption													
Measured (MWh)	565	585	584	653	457	57	65	86	60	54	39	95	2,845
Ratio to Production	0.4%	0.4%	0.4%	0.4%	0.7%	0.4%	0.6%	1.1%	0.5%	0.5%	0.3%	1.2%	0.4%
C. Availability													
TBA - Contractual	97.0%	95.5%	94.9%	97.0%	97.0%	98.1%	96.2%	97.3%	96.4%	96.4%	98.7%	96.2%	96.2%
TBA - Technical	96.6%	95.7%	90.2%	92.6%	88.5%	98.1%	90.7%	87.9%	80.9%	82.8%	90.8%	88.5%	93.1%
PBA - Technical	97.4%	95.9%	95.3%	97.4%	96.9%	98.0%	95.9%	96.9%	97.1%	95.3%	98.7%	96.7%	96.6%
D. OLF - Losses													
Manufacturer	3.0%	4.4%	5.1%	2.7%	3.0%	2.0%	3.8%	3.1%	3.0%	4.7%	1.4%	3.0%	3.7%
Owner	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.1%	0.0%	0.0%	0.0%	0.0%	0.1%	0.0%
Environmental	0.0%	0.0%	0.0%	0.0%	0.1%	0.3%	0.1%	0.1%	0.0%	0.0%	0.0%	0.0%	0.0%
Utility	0.4%	0.2%	0.6%	2.7%	11.2%	0.0%	0.0%	13.1%	16.6%	11.6%	22.6%	14.4%	2.3%
Bat Curtailment	0.0%	0.0%	0.7%	1.0%	0.4%	0.0%	0.4%	0.6%	0.8%	0.8%	0.0%	0.0%	0.4%
E. Wind													
Forecasted WS (m/s)	6.7	6.7	6.7	6.7	6.7	6.5	6.6	6.2	6	6.8	7.3	7.2	6.7
Measured WS (m/s)	6.3	6.5	6.4	6.3	5.9	6.2	5.8	5.3	6.2	6.5	6.5	5.2	6.3
WindSpeed Deviation	-6.6%	-3.1%	-5.0%	-6.4%	-10.4%	-5.3%	-12.0%	-15.3%	3.0%	-4.9%	-10.6%	-28.0%	-5.9%


PLANT PRODUCTION




ANNUAL PRODUCTION AND AVAILABILITY PER WT



PLANT AVAILABILITY



OPERATIONAL LOSS FACTORS



WIND SPEED

