

FEASIBILITY STUDY OF LOW VOLTAGE DIRECT CURRENT POWER DISTRIBUTION

by

DAVID PETRIE

Department of Electrical and Power Engineering,
Queensland University of Technology.

Submitted for the degree of
Bachelor of Engineering &
Bachelor of Finance (IX28)

in the division of ...

November & 2016.

142 Flower Street
Brisbane, Q 4013
Tel. 0400 012 299

October 28, 2016


The Dean
School of Engineering
Queensland University of Technology
Brisbane City, Q 4000

Dear Professor Simmons,

In accordance with the requirements of the degree of Bachelor of Engineering / Bachelor of Finance (IX28) in the division of Computer Systems Engineering / Electrical and Electronic Engineering, I present the following thesis entitled Feasibility Study of Low Voltage Direct Current Power Distribution. This work was performed under the supervision of Associate Professor Geoffery Walker.

I declare that the work submitted in this thesis is my own, except as acknowledged in the text and footnotes, and has not been previously submitted for a degree at Queensland University of Technology or any other institution.

Yours sincerely,

A handwritten signature in dark ink, appearing to read 'David Petrie', is written on a light-colored rectangular piece of paper.

DAVID PETRIE.

Acknowledgements

Associate Profesor Geoffery Walker for your guidance, support and patience through the completion of this project.

My fellow students **Ash Abdullrabzak** and **Niroj Gurung** for their valuable discussions throughout our three projects.

Disa, for her constant love and support through not only this project but my entire degree.

Past Queensland University of Technology engineering student **Steven Donohue** for his valuable prior thesis on 48V direct current home power systems.

Geoffery Woods and **Norman Higgins** from Queensland University of Technology's Building Management Services for providing technical drawings and electricity data.

Abhishek Bhasin and **Isaac Linett** from Q Electrical for their technical assistance and frequent questions.

Abstract

This design project aims to solve the issue of incorporating low voltage direct current (DC) power distribution systems to multi-residential and commercial buildings. Low voltage DC power is prevalent in telecommunications systems but has the possibility of being used for a variety of other applications to reduce electricity costs and improve efficiency. Due to the large costs involved in building power systems, the majority of this design project will be completed through software simulations and hand calculations. If these methods cannot be utilised, either physical testing or research will be completed as substitute. If successful, a more efficient and cheaper alternative to running simple electronics from AC mains will be created. This will allow for a portion of building's electricity demands to be self sufficient and not rely on the grid for continual supply.

Contents

1	Introduction	1
2	Research Problems	2
2.1	Current Design Consideration	2
3	Background & Literature Review	4
3.1	Literature Review	4
3.1.1	Direct Current vs Alternating Current	4
3.1.2	Low Voltage Direct Current	4
3.1.3	Low Voltage Direct Current in Telecommunications	5
3.1.4	Existing Power Distribution Systems	5
3.1.5	Commercial and Industrial Power Systems	6
3.1.6	Alternative Electricity Generation Solutions	7
3.1.7	Photo-Voltaic Arrays and DC Arcing	7
3.1.8	Electrical Safety Mechanisms	8
3.1.9	Electrical Safety in Low Voltage DC	8
3.1.10	Converters	8
3.1.11	Buck and Boost Converters	9
3.1.12	Standards	9
3.1.13	Tariffs	9
3.1.14	LED Lighting	10
3.2	Prior Art	11
3.2.1	Previous Thesis: Extra-Low Voltage In-Home Power Distribution and Storage	11
3.2.2	Previous Thesis: DC Supply In Buildings	11
3.2.3	Micro-Inverters	12
3.2.4	Things to look into	12
4	Program and Design	13
4.1	Objectives	13
4.2	Methodology	13
4.3	Research Plan	14
4.4	Resources and Funding	15
4.5	Project Team	15
4.6	Timeline	16

5	Preparation, Considerations and Initial Simulations	18
5.1	Draft Floorplan	18
6	Project Questions	21
6.1	What Is The Optimal Voltage Level When Considering Loads, Costs and Efficiencies?	21
6.2	Can Photo-Voltatic Systems Be Used Effectively for this Application? . .	23
6.3	What Lighting Options Are Optimal?	24
6.4	Structural Design and Safety Mechanisms to Minimise Cable Losses . . .	25
6.5	Can Direct Current Be Used as an Alternative to Alternating Current for Commercial Lighting Systems?	26
7	Future Work & Conclusion	27

List of Figures

Figure 1	Single Battery Communications Room [1]	5
Figure 2	Existing Power Distribution Methods [2]	6
Figure 3	Hotel Single Line Diagram	7
Figure 4	Considerations for a Technical Design Task	14
Figure 5	Initial Design Consideration for DC Home Power System [3]	14
Figure 6	Temporary Office Floor Plan Design	19

List of Tables

Table 1	Comparing Efficiencies of Lighting Types (Bulbs) [4]	10
Table 2	Major Milestones of Project	17
Table 3	Lighting Requirements as per AS/NZS Standards [5]	19
Table 4	Dialux Outputs of Draft Floor Plan	20
Table 5	Cable Sizing As Per Voltage Level	22

1 Introduction

In most Australian homes, power is consumed directly from the local distribution grid. All appliances are connected to one switchboard but can be separated over various circuits each with their own protective devices, usually circuit breakers. Generally, many modern Australian appliances will use Direct Current (DC) electricity but the outlets provide an Alternating Current (AC) source of 240 V at a frequency of 50 Hz. Each device therefore requires a converter that converts the AC source into the required constant DC voltage and current specific to that device.

This project will consider the feasibility of diverting a portion of power distribution from the standard 240 VAC sourced from the grid with an alternative solution. The considered option is utilising a low voltage direct current on a separate grid to power known low consumption devices such as lighting or electronics charging devices. An efficiency and financial analysis will be completed through hand calculations and software simulations.

This project will specifically focus on two aspects of this broader topic. These are whether alternative power generation systems will be utilised as well as whether the new possibilities for generation and distribution methods could be used in applications larger than residential homes. The additional locations for this application that will be analysed are apartment and commercial complexes. There will be a variety of design possibilities considered to find the optimal low voltage DC alternative implementation. To do this there will be a focus on cost, efficiency and usability comparisons of equivalent AC and DC systems.

2 Research Problems

The key problem that this research paper will be targeting is the feasibility of implementing a separate DC power distribution system for the specific purpose of powering LED lighting circuits and simple electronics. Additionally, the goal is to implement these systems into a commercial building and apartment setting within Australia. For a stronger understanding and case study, Brisbane city will be analysed due to the large amounts of sun and numerous high rises. Designs will be tested through physical devices where possible or software simulations otherwise. In order to answer this key question and complete the project, sub questions were separated and discussed.

1. Can direct current power be a suitable alternative to alternating current when efficiencies and costs are compared?
2. What is the optimal voltage level for a low voltage DC system when considering loads, costs and efficiencies?
3. If feasible, how can a photo-voltaic system be implemented to power these circuits?
4. Can lighting load and lux requirements be met through this system?
5. If feasible financially and technically, how can the proposed power distribution methods be implemented in commercial buildings effectively?

2.1 Current Design Consideration

The research completed and discussions with Geoffrey has allowed for a beginning concept for what could be a feasible design. The main design constraints are cable lengths need to be short, the power generation should be with photo-voltaic systems and due to load constraints, many micro-grids should be used. To do this, with tall and thin buildings it would be possible to use PV cells instead of shading or window awnings to generate electricity. Each floor has their own cells and generates electricity to power their lighting and simple electronics or USB wall charging ports.

Utilising Steven Donohue's findings of 48V being the perfect voltage level for these forms of systems, the initial plan is to utilise this level [6]. The cables being run would follow Australian building standards at 2mm² 2 core and earth and would easily provide the necessary current carrying capacity. These cables would feed to separate, dedicated switchboards for a purely DC supply and then through to LEDs where a highly efficiency DC-DC converter needs to be found or designed. Each floor would therefore have it's own switchboard to power an area between 50m² and 100m² although further calculations

are required to check this. An office space is approximately 9m^2 requiring only 4 LEDs to provide necessary lux levels meaning the load for lighting should not exceed 40 watts and at 48 VDC that's only 0.83 A. With multiple rooms such as this, the design should be feasible with further simulations.

3 Background & Literature Review

3.1 Literature Review

3.1.1 Direct Current vs Alternating Current

A very broad and contextual understanding must be made about the differences between direct current and alternating current distribution systems. Compared with traditional AC designs, DC has the potential for effective power supply, smaller feeder loss, increased efficiency, more consistent power and direct access to renewable energy solutions [7]. Alternating current is run to outlets at 240 VAC, 50 Hz and then devices are used to alter that source into whatever the device requires. Many household electronics such as computers, chargers, lighting and televisions operate internally at DC voltages meaning they each require either internal conversion circuitry or use a transformer between the powerpoint and device [8].

AC was originally depicted as the better choice for power distributions due to there being no method at the time for controlling DC electricity at the load causing large losses from the generator to device [9]. To remedy this, AC distribution was used due to efficient transformers being developed to boost the voltage. AC remains the fundamental power type but DC is growing in popularity with improved converters and increased frequency of DC energy sources [9]. Utilising DC generation systems could also fulfill the power industry's obligation to increase the sustainability of their systems and be more environmentally conscious [10]. The required converters to change the AC supply into DC for electronics reduces the efficiency (increasing voltage drop) of the overall system [9].

3.1.2 Low Voltage Direct Current

DC power is currently restricted to special applications such as telecommunications, electric vehicles and high-voltage direct current (HVDC) transmission [11]. Low-voltage DC power systems at 48 VDC has been used fairly widely with telecommunications systems but is recently facing issues due to the high power requirements of computer system upgrades [11]. Studies have shown that the 48 VDC system still remains more efficient than a 270 VDC or 200 VAC but further investigation needs to be done into 230 VDC and 325 VDC through retrofitting existing low voltage AC installations [11]. Photovoltaic generators are used frequently for these forms of power distribution systems as it can be powered directly or use simple DC to DC converters for different devices. Utilising

a DC distribution system makes it easier to incorporate local power generation. This reduces costs and local power is unaffected by issues with power grid [10].

3.1.3 Low Voltage Direct Current in Telecommunications

Using low voltage energy distribution grids for high-speed communications networking which can open up the possibility to utilities for expansion of widespread local area networks [12]. This could be services such as telephony and internet access without the necessity of additional cabling [12]. Firstly, this voltage level is chosen due to it being marginally under the maximum for low voltage power and still considered a "safe low voltage". Additionally, this voltage level could be backed up by battery systems with four 12 V batteries in series. Many data centres or communications rooms for corporate buildings will establish arrays of 48 V battery banks [1]. A solution for areas without large enough storage areas for are limited and power demands are low a single 12 v battery with a 12 V to 48 V boost converter can be used [1]. This setup is shown in Figure 1.




Figure 1: Single Battery Communications Room [1]

3.1.4 Existing Power Distribution Systems

Power systems consist of four major sections; generation, transmission, distribution and loads. AC electricity is generated in power plants and sent through high voltage transmission lines to substations and distributed to switchboards for use in residential, commercial and industrial areas [13]. In order to transport electricity over large distances (excess of 2km) without severe losses, very high voltage and low current is used [13]. This is voltage is lowered and current increased by a transformer at the substation and again at the residence. For electricity to reach the home and be utilised for devices there must be safety mechanisms installed to ensure damage is not done to the user or devices. The protective devices requiring consideration throughout this project will

be fuses, circuit breakers and switchboards [14]. These devices are placed through the circuit to protect the more expensive equipment closer to the transformer and grid.




Figure 2: Existing Power Distribution Methods [2]

3.1.5 Commercial and Industrial Power Systems

There are relatively large differences between home and commercial power systems. A home application is fairly simple with a transformer feeding electricity into one distribution board or switchboard (DB) that provides safety mechanisms along with circuit breakers for the home circuits. In a commercial setting, the loads are far higher and require a stable connection [15]. For an apartment complex, shopping centre or business building, the supplies are usually separated into buses in order to identify separate requirements or areas. The requirements could be essential items (including emergency lifts, safety equipment or machines that cannot be stopped) or non-essentials (tenancies or general equipment). Additionally it can be used to separate the entire building's load over towers or zones to minimise faults. The figure below represents a single line diagram showing the two separate buses for a design.




Figure 3: Hotel Single Line Diagram

3.1.6 Alternative Electricity Generation Solutions

In order to increase efficiency of power systems through utilising a low voltage DC sub-system, alternatives to drawing standard AC electricity from the grid must be considered. In Australia, a strong option for the generation alternative is photo-voltaic systems (known commonly as solar panels). These systems will convert the sun's rays into electricity and power devices via a regulator, a DC to DC converter [16]. This converter is designed to allow the panels to power varying DC loads. If the panels are being used for AC loads, an inverter will also be required. Additionally, if the system is stand-alone a battery will also be required. For the purpose of this project, a vital aspect of DC distribution is the removal of the inverter allowing for the removal of losses caused by these circuits.

3.1.7 Photo-Voltaic Arrays and DC Arcing

With the popularity of PV systems increasing, the risk of DC arc faults are being analysed further [17]. PV arrays and power systems are being designed with converters

boosting voltages to 800 VDC and 1000 VDC. This is being done for efficiency and cost reduction purposes however it leads to large amounts of stress on insulation systems and arc faults developing [17]. This causes more safety concerns than traditional AC systems. There are three major causes of arc fault risk; high DC voltage, high DC current and large distribution of DC wiring [18].

3.1.8 Electrical Safety Mechanisms

For electricity to each the home and be utilised for devices there must be safety mechanisms installed to ensure damage is not done to the user or devices. The protective devices requiring consideration throughout this project will be fuses, circuit breakers and switchboards [14]. These devices are placed through the circuit to protect the more expensive equipment closer to the transformer and grid. A fuse is a simple device that acts as a sacrificial lamb for the protection of the more expensive devices. An internal wire will melt when too much current flows through therefore interrupting the connection [14]. A circuit breaker is a smarter and re-useable version of a fuse that is triggered by overcurrent, overloads or short circuits to fulfil the same purpose [14]. The switchboard is a device that connects a home or building to the electrical grid and allows for individual circuits to be run for different purposes throughout the complex [14].

3.1.9 Electrical Safety in Low Voltage DC

Fuses, mechanical and electronic safety switches / circuit breakers and their combinations operate the same in DC as they do in AC; detecting electric faults and switching off to isolate electrical equipment [19]. Plugs, sockets and safety equipment with nominal currents of 20 A are commercially available for pre-existing DC data centres [19].
probably lacking here

3.1.10 Converters

Converters are electrical devices designed and constructed to convert current between AC and DC [20]. Rectifiers are used to convert the voltage from AC to DC and inverters convert from DC to AC [20]. Although these are the technical terms for the two devices, in general the term "converter" can be used. A specific use for inverters is to convert the DC electrical generated from solar panels to AC for transfer back into mains or to the necessary switchboard. An additional use for these is in Uninterrupted Power Supplies (UPS) where stored DC battery power [20].

3.1.11 Buck and Boost Converters

Buck and boost converters are a subset of the converter section above. These are used in DC to DC power systems where the voltage needs to be stepped up or stepped down [21]. For smaller applications, chips such as the LM2575 buck converter are available to reduce voltages according to a feedback. Boost converters do the opposite and increase the voltage. These devices are frequently used with Photo-Voltaic systems depending on what loads they are feeding [21]. The panels generate electricity that is fed through a boost converter then into an inverter to change to AC in order to be distributed throughout the load for standard use [21].

3.1.12 Standards

Australian standards will be an integral part of this project. If the rules and regulations are not adhered to, the devised system will not be legally approved for installation. There are four standards that will be relevant to this report; AS3000, AS3008, AS1680 and AS3015. The AS/NZS 3000 covers the standards related to electrical installations or wiring rules within Australia and New Zealand [22]. These standards will be the main reference point. The AS/NZS 3008 which are the regulations specifically related to electrical installations and cable specifications will be vital [23]. An additional set of standards that will be used for initial calculations and estimation of building load requires is AS/NZS 1680 which are the lighting regulations and requirements for interiors and workplaces [5]. These standards outline the lux levels required by rooms depending according to their purpose allowing 3D models to be created. The AS/NZS 3015 specifically dictates the rules with regards to electrical installations of extra low voltage direct current power supplies and services earthing within public telecommunications [24].

3.1.13 Tariffs

Tariffs will be an important consideration with the feasibility of this project due to the possibilities of cost reduction. User expenses could theoretically be reduced by implementing a system off the grid. Government policies have been put in place in order to prompt an increase in investment in renewable energy sources [25]. Users are able to sell their unused generated electricity back to the grid to reduce their overall electricity bills or possibly profit if consumption is low enough. In Queensland, according to the SolarChoice website a feed-in tariff of \$0.06/kWh can be earned [26]. By not connecting the photo voltaic panels to the grid, this tariff can not be received however there is the

possibility that it is more efficient and will produce less energy loss by storing in local batteries and running simple circuits rather than feeding the grid [27]. The consideration will be whether the cost reduction in electricity bill will be worth the investment in the equipment and future cost reduction.

3.1.14 LED Lighting

Table 1 below shows a technical comparison of three common lighting types. Improvements in LED lighting allow less power to be used for the same brightness. It is possible to design and create an energy efficient LVDC grid powered LED lighting system with additional automation aspects and energy storage [4]. Typical lighting systems are fluorescent bulbs or tubes that are powered directly from standard 230 V AC due to the devices' high efficacy [4]. When comparing an AC fluorescent system and a LVDC LED system, the LVDC grid system requires significantly less power conversion which increases the overall efficiency [4]. The table below represents these factors. For applications, this means less physical lights are necessary for equivalent light reducing project costs [28].

Lighting Type (Bulbs)	<i>Incandescent</i>	<i>CFL</i>	<i>LED</i>
Average Lifespan (hours)	1,200	8,000	50,000
Wattage (at 800 lumens)	60	13-15	6-8
Lumens/Watt	13.3	53.3	114.3

Table 1: Comparing Efficiencies of Lighting Types (Bulbs) [4]

3.2 Prior Art

For a thorough research project to be completed, devices that have already been designed, tested and created must be researched and analysed. With the popularity of DC power systems increasing in recent years, there have been an many more academics assessing the possibilities. Due to the predominately theoretical design nature of this report and similar aspects of previous papers, a significant focus was made on previous papers.

3.2.1 Previous Thesis: Extra-Low Voltage In-Home Power Distribution and Storage

Steven Donohue completed his undergraduate thesis under Geoffery Walker in 2014 [6]. This paper assessed various aspects of the similar topic question but specifically focussed on using low voltage DC electricity in homes to power lighting systems. He also considered battery storage solutions and discovered that 48V was the best option for voltage levels for this application [6]. He proposed that an installation model for low voltage distribution was uneconomical with current solar feed-in tariffs [6]. The final discussion of lighting application proved to be successful using LED lighting circuits in home. Donohue's project will be an asset to the completion of this thesis as the overall concept is very similar. It will be possible to make some assumptions and avoid investing time on smaller calculations due to Donohue's extensive research.

3.2.2 Previous Thesis: DC Supply In Buildings

From the University of Science and Technology in Norway, Aurora Bøhle Foss completed her master's thesis on incorporating DC supply into buildings with a larger focus on commercial buildings [29]. Her focus wasn't specifically on low voltage DC however it did incorporate some research and testing into the feasibility of these systems. Her research found that the most important aspect of incorporating DC supplies into power systems is a highly efficient Voltage Source Converter (VSC). She determined that if a load is requiring AC, it is more efficient to use an AC source. It has been found that higher power loads and cable lengths longer than 10 metres using 1.5mm² and 2.5mm² are impossible due to severe losses.

3.2.3 Micro-Inverters

A competitor to the system that will be designed throughout this thesis will be recent developments in micro-inverter technologies by Enphase [30]. These products are designed to be efficient, small and affordable to allow for the DC electricity generated by photo-voltaic cells to be converted to 240V 50Hz AC for the mains. A wide range of fittings are possible depending on the PV cells and switchboard distribution. They have a rated efficiency of 95.7% [30].

3.2.4 Things to look into

- DC Distro in buildings
- LVDC for lighting
- LVDC for Power Distro
- LVDC Telecomms
- LVDC Protection
- Lighting Plant
- RAPS systems

4 Program and Design

4.1 Objectives

The objective of this research project is to attempt to answer the overall question of whether a low voltage DC power distribution system could be implemented to power low load devices such as lighting, simple electronics and charging devices. A secondary objective is to relate this project directly to renewable energy generation and in a commercial setting.

4.2 Methodology

In order to complete this task within a timely manner and ensure all aspects are thoroughly considered and discussed, a clear guideline of tasks must be followed. Additionally, these tasks will need to specifically address the objectives that the research proposal addresses. As discussed in Section 3, there are five broad questions that are being addressed throughout the two semesters of this thesis. The methodology of the thesis is based around a combination of physical and theoretical testing. A reliance on previous research and design recommendations will be important [13]. Although research of DC systems has increased, this project will be focusing on an area that has not been sufficiently researched and analysed [3].

The five separate questions are related to the same solution. Initial stages of the project require extensive research on the possibilities and theories behind a purely DC system. Once a strong idea of the possibilities and previous papers were analysed a general analysis of whether or not 48V is the ideal voltage level is secondary. To do this, it will be predominately theoretical with voltage drop calculations over standard cable lengths and areas. Additionally research will be used to back up findings. Software and research will be used to assess the options with solar panels and the best method of implementing them into the solution.

SMART goals will be used to measure the progress. This framework is based off having goals that are specific, measurable, attainable, realistic and timely. These goals are the milestones that are described. By doing so, tasks can be achieved and a regular logbook of activities maintained for process improvements. Spreadsheets and in-built software data storage will be used to record the findings. These findings will be analysed

either through additional hand calculations or Matlab. The figure below shows the methodology behind technical design tasks.




Figure 4: Considerations for a Technical Design Task

4.3 Research Plan

A majority of the project will be through simulations utilising Matlab, PowerCad5, Dialux4.12 and Homer. This is due to power systems electronics being expensive and large scale testing out of the financial scope of this project. Ideally, a full system would be built with Photo-Voltaic cells, battery, controller, DC-DC converters and connections to appliances, however finances will not allow this. Figure 4 below shows a basic PV DC system and the areas requiring consideration.




Figure 5: Initial Design Consideration for DC Home Power System [3]

The software will allow for data collection and spreadsheets used to track and assess. The benefit of using spreadsheets and Matlab is that formulas can be input and optimisation simulations run. If simulations are not being used and physical tests are required, a multimeter or computer interfaces will be utilised. If testing cannot be performed or

simulated, additional research will be completed to find the closest solution possible. If this method needs to be done, it will explicitly stated in the final report that not all aspects could be physically tested.

4.4 Resources and Funding

The design and construction of this project would require a substantial amount of resources. Due to this, computer assisted design (CAD) programs will be used as the main design calculation feasibility analysis mechanism. The University facilitating this research project will allocate \$50 for each student through purchase order applications. This value will be taken into consideration when designing possible testing mechanisms or models for the presentation.

4.5 Project Team

As previously stated, this project is being solely undertaken, however there are three students undertaking topics that are interrelated. In addition to my task focusing on low voltage DC systems in larger applications, the other two students are analysing sub issues in the same broad category. There will be discussions between the three students on relevant articles, journals and standards that each person finds.

4.6 Timeline

This project will be predominately based on two major resources; software availability and personal time. Software will be available at all times due to the University providing paid software packages and myself already having installed free ones. Personal time will be the major difficulty as it will be balanced between other University classes, part-time work, and personal responsibilities.

The tasks were be split into days and University weeks. It was ensured to include the holidays that University allows. This project does not simply end upon the completion of this semester. BEB801 is concluded on November 4th at the end of Week 14, however BEB802 is the subject allocation to complete the second half of this project. The task table will allocate SMART milestones. Additionally, the benefits of completing the subjects during this period is that there is the additional time from summer holidays to account for.

The table on the following page shows the milestones of this project. The University assigned submissions are represented as bold text. The four major deliverables for the first half of this project are the library assessment, project proposal, oral presentation and progress report. These four deliverables are what have outlined how the remaining tasks have been created and the time periods allowed for. Earlier due dates are set to allow for editing or possible difficulties to occur without major repercussions.

The assessed deliverables for Semester 2 are similar to the first. The major difference predicted is that the task should be very well understood by the beginning of semester. By having this advantage as well as the additional time during summer break, it allows for a very strong foundation for the final design. This is why the non-assessed milestones are predominately finalisation throughout the entire semester. The summer break will be utilised to reduce the required work during the University period.

Milestone	Deadline
Project Definition	Week 3
Library Assessment	Week 4
Initial Research Phase	Week 6
Project Proposal	Week 7
Initial Design Phase	Week 9
Initial Prototype Design Finalised	Week 11
3D Modelling for Presentation	Week 12
Written Report	Week 13
Initial Oral Presentation	Week 14
Implement Feedback From Report	Summer Break
Complete Research Shortcomings	Summer Break
Complete Further Technical Calculations	Summer Break
Initial Finance Analysis	Week 2
Design Simulations	Week 6
Progress Report	Week 7
Finalised Design	Week 10
Finalised Simulations & 3D Modelling	Week 11
Finalised Financial Analysis	Week 12
Final Report	Week 13
Final Presentation	Week 14

Table 2: Major Milestones of Project

5 Preparation, Considerations and Initial Simulations

To design a feasible commercial building incorporating low voltage DC electricity an approximate building size and layout was required. Through liaising with Geoff he suggested contacting QUT's Building Management Services department who have access to building schematics and load data. Geoff Woods and Norman Higgins provided electrical drawings, single line diagrams, architectural drawings and electrical specifications for analysis. Additionally, a computer login to the Electricity Management System (EMS) at QUT was created. This interface tracks all the electricity consumed from every meter on campus. The data is access through a interface closely linked with the single line diagrams of buildings including main switchboards (MSBs), distribution boards (DBs) and transformers. This information is critical to understanding optimal power system design.

The EMS system additionally outlines how the PV system at QUT operates and what power it generates. The solar panels act as a load reducing generator rather than direct appliance powering. During the day the panels generate electricity and with a regulator and converter combination the DC generated power is converted to AC and fed into the University's power systems. The major difference between this design and the one which this project seeks to design is the panels will be directly powering loads.

5.1 Draft Floorplan

Before the schematics and floor plans for QUT's buildings were made available, an approximate small office area was modelled in AutoCAD with offices of 5 m². The purpose of this simulation was to analyse approximate lighting loads for the environment.




Figure 6: Temporary Office Floor Plan Design

After the initial room plans for created, the Australian Standards AS/NZS 1680.2.2 Interior and Workplace Lighting were consulted.

Area or Application	Lux Requirement
Rarely Visited	40
Storage Rooms or Change Rooms	80
Machine Work or Waiting Rooms	160
Food Preparation Room	240
Technical Office Room	320
Visually Difficult Work	500

Table 3: Lighting Requirements as per AS/NZS Standards [5]

These two data points were used for the initial draft planning of designs. This is not an accurate representation of a building, it was a starting point to work from once the more accurate schematics and plans were accessed. The next stage was to import the simple floor plan CAD file into Dialux4.13. This is a lighting design software solution

to model options and predict approximate load demands that the LVDC system will be required to power.

Through personal experience in building services design, I had an approximate idea of what amounts of lighting would be required for a 5 m² room. I also knew that I would use LED down lights for simplicity and affordability. The difficult part is finding commercially available products that operate at a voltage level at either 48 VDC when the voltage drop over cabling is removed or at another level where an efficient DC to DC converter could be used. My goal was to have the average lux between 300 lux to 400 lux. This value was chosen as a technical office is an accurate assessment of most corporate buildings. As seen in Table 4 below, 7 20 w LED down lights reaches this specification.

Down Light Wattage	Quantity	Max Lux	Min Lux	Average Lux
11	6	114	3.8	73
11	10	180	7	114
20	8	680	16	383
20	7	677	12	344

Table 4: Dialux Outputs of Draft Floor Plan

6 Project Questions

The following section will go into technical detail of the five questions that this project will analyse. Due to the fact this is a progress report and not the final, there are not solutions to all answers however mechanisms put in place so that the solutions can be found. If a question has not been solved, it will be outlined how the solution will be found over the remaining semester.

6.1 What Is The Optimal Voltage Level When Considering Loads, Costs and Efficiencies?

To determine what voltage level would be optimal for the suggested distribution systems, research was enlisted over technical tests. The previous QUT student, Steven Donohue did extensive research on this aspect of the solution in 2014 for his project Extra Low Voltage In-Home Power Distribution and Storage 48 VDC. For the purpose of investing time more efficiently, this project relies on the quality of his research for the basis of this question.

With battery storage implementations, there are some restrictions on that voltage level for the solution. Batteries may or may not be implemented into this project's solution, however it is important to understand the fundamentals behind the voltage level decisions. There is a large amount of literature suggesting that 48 VDC is the best option due to the efficiency levels with standard loads. When a 240 VAC home power system was compared with DC it was found that the 48 VDC system used 22% less and a 120 VDC used 18% less [6].

An additional factor that is arguably more important is current differences affecting cable sizing requirements. As the voltage level is increased, the current required to power loads will be decreased following the relationship $\text{Power} = \text{Voltage} * \text{Current}$ ($P=VI$). The table below represents brief calculations using 24, 48 and 96 VDC with two different loads to calculate approximate cable sizing. Although reducing cable sizes is important, an alternative comparison method is the distance that cables can be run. By using less current, cables of the same size can be run further distances without suffering from too high voltage drops. The voltage drop is the factor that affects a system's efficiency level. Therefore, when the voltage drop can be reduced from a 24 VDC system to 48 VDC system, the efficiency is being increased.

Load (Watts)	Voltage (Volts)	Current (A)	Approximate Cable Size (mm ²)
100	24	4.16	1
100	48	2.08	1
100	96	1.041	1
500	24	20.83	5
500	48	10.42	2
500	96	5.21	1

Table 5: Cable Sizing As Per Voltage Level

With these factors considered and the extensive literature review supporting the choice of 48 VDC, at this stage of the project this voltage level will be chosen. Simulations of this level will be run in further questions and analysis applications to determine if it is suitable when applied to commercial buildings.

6.2 Can Photo-Voltatic Systems Be Used Effectively for this Application?

6.3 What Lighting Options Are Optimal?

6.4 Structural Design and Safety Mechanisms to Minimise Cable Losses

6.5 Can Direct Current Be Used as an Alternative to Alternating Current for Commercial Lighting Systems?

7 Future Work & Conclusion

The project being undertaken plans to design and confirm the feasibility of a DC power distribution for commercial buildings to power low load electronics such as lighting and simple devices with a group of photo-voltaic cells. The completion of this task will require extensive research, time, calculations and computer simulations. Milestones that have been set meet the SMART criteria which will allow for tracking and maintaining progress throughout the project. The initial research phase has been completed and designs will begin to be theorised and soon tested following the timeline.

Computer simulations are the main design solution due to the large costs involved in commercial power system implementation. By simulating designs and providing visual aids through 3D rendered images, the presentation will be show not only calculation data but designs implemented on a visual model. In the event that an experimental test can be financially and physically completed and it would benefit the task, it will be done.

Overall it is expected that this research project will be completed with a feasible design. If it is found that no solution will be suitable, a strong justification and possible future areas of discussion will be brought forward. November 2016 will have a preliminary design along with justification for the feasibility so that a presentation can be made and successful progress shown. By ensuring that this stage is reached, valuable feedback will be provided via the project supervisor and academic team behind the course.

References

- [1] E. Herz, “48v dc for telecommunications: Powering an industry,” 2016, <http://resources.secamerica.com/48v-dc-for-telecommunications-powering-an-industry>.
- [2] A. S. Active and P. Filter, “Transmission and Distribution Components,” *Quadrennial Technology Review 2015*, no. January, pp. 1–22, 2015.
- [3] J. Pellis, “The DC Low-Voltage House,” Ph.D. dissertation, Eindhoven University of Technology, 1997.
- [4] L. H. Koh, Y. K. Tan, Z. Z. Wang, and K. J. Tseng, “An energy-efficient low voltage DC grid powered smart LED lighting system,” *IECON Proceedings (Industrial Electronics Conference)*, vol. 2, no. 11, pp. 2883–2888, 2011.
- [5] Standards Australia, “Interior and workplace lighting Part 1 : General principles and recommendations,” 2006.
- [6] S. Donohue, “Extra Low Voltage In-home Power Distribution and Storage (48vdc),” Undergraduate Thesis, Queensland University of Technology, 2014.
- [7] Z. Liu and M. Li, “Research on Energy Efficiency of DC Distribution System,” *AASRI Procedia*, vol. 7, pp. 68–74, 2014. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S2212671614000328>
- [8] P. Paaianen, T. Kaipia, and J. Partanen, “DC supply of low-voltage electricity appliances in residential buildings,” in *20th International Conference and Exhibition on Electricity Distribution (CIRED 2009)*, no. 0692, 2009, pp. 1–4. [Online]. Available: <http://digital-library.theiet.org/content/conferences/10.1049/cp.2009.0925>
- [9] M. Starke, L. M. Tolbert, and B. Ozpineci, “AC vs. DC distribution: A loss comparison,” *Transmission and Distribution Exposition Conference: 2008 IEEE PES Powering Toward the Future, PIMS 2008*, vol. 1, no. 1, pp. 1–7, 2008.
- [10] M. Starke, F. Li, L. M. Tolbert, and B. Ozpineci, “AC vs. DC distribution: Maximum transfer capability,” *IEEE Power and Energy Society 2008 General Meeting: Conversion and Delivery of Electrical Energy in the 21st Century, PES*, pp. 1–6, 2008.

- [11] D. Salomonsson and A. Sannino, “Low-voltage DC distribution system for commercial power systems with sensitive electronic loads,” *IEEE Transactions on Power Delivery*, vol. 22, no. 3, pp. 1620–1627, 2007.
- [12] T. Waldeck, M. Busser, and K. Dostert, “Telecommunication Application Over The Low Voltage Power Distribution Grid,” pp. 1–5, 1998.
- [13] M. Amin, Y. Arafat, S. Lundberg, and S. Mangold, “Low voltage DC distribution system compared with 230 V AC,” *2011 IEEE Electrical Power and Energy Conference, EPEC 2011*, pp. 340–345, 2011.
- [14] United States Department of the Interior, “Methods for Coordinating System Protective Equipment,” *Facilities Instructions, Standards, and Techniques*, vol. 3-9, no. December 1991, 2000.
- [15] M. Baran and N. Mahajan, “DC distribution for industrial systems: opportunities and challenges,” *IEEE Transactions on Industry Applications*, vol. 39, no. 6, pp. 1596–1601, 2003.
- [16] L. Pillay and K. S. Karimov, “Photo-Voltaic System,” in *3rd International Conference on Electrical & Computer Engineering*, no. December. Dhaka, Bangladesh: ICECE, 2004, pp. 28–30.
- [17] E. D. Spooner and N. Wilmot, “Safety issues, arcing and fusing in PV arrays,” in *3rd International Solar Energy Society*, no. November, 2008, pp. 1–9. [Online]. Available: <http://auses.org.au/wp-content/uploads/425.pdf>
- [18] M. Dargatz, “Dc arc faults and pv system safety,” 2009, <http://www.renewableenergyworld.com/articles/2009/12/dc-arc-faults-and-pv-system-safety.html>.
- [19] P. Meckler, F. Gerdinand, R. Weiss, U. Boeke, and A. Mauder, “Hybrid switches in protective devices for low-voltage DC grids at commercial used buildings,” *27th International Conference on Electrical Contacts, June 22 – 26, 2014, Dresden, Germany*, pp. 120–125, 2014.
- [20] Diffen.com, “Converter vs inverter,” 2016, <http://www.diffen.com/difference/Converter-vs-Inverter>.

- [21] H. Abu-Rub, M. Malinowski, and K. Al-Haddad, *Power Electronics For Renewable Energy Systes, Transportation and Industrial Appliactions*. West Sussex, UK: John Wiley & Sons Ltd, 2014.
- [22] Standards Australia, “AS/NZS 3000: Wiring Rules,” pp. 1–21, 2007.
- [23] —, “AS/NZS 3008: Electrical Installations,” pp. 1–136, 2010.
- [24] —, “AS/NZS 3015: Electrical Installations of Extra Low Voltage DC Power Supplies and Service Earthing Within Public Telecommunications Networks,” pp. 1–61, 2004.
- [25] T. Nelson, P. Simshauser, and S. Kelley, “Australian Residential Solar Feed-in-Tariffs: Industry Stimulus or Regressive Form of Taxation,” *Economic Analysis and Policy*, vol. 41, no. 2, pp. 113–129, 2011. [Online]. Available: http://www.eap-journal.com/archive/v41{i2}_{_}01-nelson.pdf
- [26] SolarChoice.net, “Which electricity retailer is giving the best solar feed in tariff?” 2016, <http://www.solarchoice.net.au/blog/which-electricity-retailer-is-giving-the-best-solar-feed-in-tariff/?Qld>.
- [27] S. Antoniou, A. Tzimas, A. Rowland, “Transition from AC to DC Low-Voltage Distro Networks,” *IET Generation, Transmission & Distribution*, vol. 9, no. 12, pp. 1391–1401, 2015.
- [28] E. Revolution, “Lumens and light output,” 2016, <http://www.eco-revolution.com/lumens-and-light-output/>.
- [29] A. B. Foss, “DC Supply in Buildings,” Masters Paper, Norwegian University of Science and Technology, 2014.
- [30] Enphase, “Enphase microinverters: What’s underdeanth the panels makes all the difference,” 2016, <https://enphase.com/en-au/products-and-services/microinverters>.