

PythonPowerFlow: OPF Comparison Framework

Short Technical Report

David Jose Florez Rodriguez

1 Introduction

PythonPowerFlow is a framework for comparing convex relaxations of AC Optimal Power Flow (OPF) against local and heuristic solvers on standard test networks. The AC OPF minimises generation cost subject to the nonlinear AC power flow equations and operating limits:

$$\begin{aligned} \min \quad & \sum_g c_g P_g \\ \text{s.t.} \quad & P_i = \sum_{g \in i} P_g - P_{\text{load},i}, \quad Q_i = \sum_{g \in i} Q_g - Q_{\text{load},i} \\ & V_{\min} \leq |V_i| \leq V_{\max}, \quad P_g^{\min} \leq P_g \leq P_g^{\max} \end{aligned}$$

The power balance is nonlinear ($|V_i||V_k| \cos \theta_{ik}$, $|V_i||V_k| \sin \theta_{ik}$), making AC OPF non-convex and NP-hard. The **project SOCP** relaxation replaces the rank-1 voltage constraint with a convex second-order cone, providing a tractable global lower bound. The framework runs four solvers, records nine comparison metrics, and reports exactness diagnostics (τ , δ) per test case.

2 Solvers

2.1 Circuits NR

Full Newton–Raphson AC power flow. Solves the nonlinear power-balance equations from a given starting point; finds one locally valid AC solution. Highly sensitive to initialisation on meshed networks. Returns no objective value (power-flow only, no dispatch optimisation).

2.2 project DC OPF

Linear DC OPF formulated as an LP. Approximates $|V_i| \approx 1$ pu and neglects reactive power and losses. Susceptance: $b_{ij} = x/(r^2 + x^2)$. Returns zero reactive flows. Provides a fast, loose lower bound on the AC OPF cost.

2.3 project SOCP

SOCP relaxation of AC OPF (Jabr 2006/2007). Introduces *lifted variables*:

$$W_{ii} = |V_i|^2, \quad W_{ij}^R = \text{Re}(V_i V_j^*), \quad W_{ij}^I = \text{Im}(V_i V_j^*)$$

Power balance becomes *linear* in these variables:

$$P_i = G_{ii} W_{ii} + \sum_{k \neq i} (G_{ik} W_{ik}^R + B_{ik} W_{ik}^I)$$

Physical voltages require $\mathbf{W} = \mathbf{V}\mathbf{V}^H$ (rank-1). The SOCP relaxes each 2×2 principal submatrix to:

$$\|(2W_{ij}^R, 2W_{ij}^I, W_{ii} - W_{jj})\|_2 \leq W_{ii} + W_{jj}$$

equivalent to $|W_{ij}|^2 \leq W_{ii} W_{jj}$ (Cauchy–Schwarz relaxation of the physical equality). Since the SOCP feasible

set *contains* the AC OPF feasible set:

$$\text{project SOCP objective} \leq \text{AC OPF objective}$$

Solved via a CLARABEL→GUROBI→SCS cascade. Runs in *PF mode* (fix dispatch, compare voltages) or *OPF mode* (minimise cost); PV bus voltages are free in OPF mode.

2.4 pandapower AC OPF

Interior-point NLP (`pp.runopf`). Finds a locally optimal AC solution; used as a ground-truth reference on WB5 and Case22loop variants.

Solver summary:

Solver	Type	Bound
Circuits NR	NR AC PF	None (local)
project DC OPF	LP	Lower bound
project SOCP	SOCP (convex)	Lower bound
pandapower AC OPF	NLP (local)	None (local)

3 Metrics

The interactive CLI (`my_opfs.py`) exposes nine metrics:

1. **Bus voltage magnitudes** $|V_i|$ (pu)
2. **Voltage angles** θ_i (deg)
3. **Branch active flows** P_{ij} (pu)
4. **Branch reactive flows** Q_{ij} (pu; zero for DC)
5. **Objective value** $\sum_g c_g P_g$ (\$/h)
6. **Convergence status**
7. **Solve time** (s)
8. **SOCP branch tightness** τ_k
9. **Loop residuals** δ_k (deg)

3.1 Branch tightness τ_k

$$\tau_k = \frac{(W_{ij}^R)^2 + (W_{ij}^I)^2}{W_{ii} \cdot W_{jj}} \in [0, 1]$$

$\tau_k = 1$: the SOC constraint is active; the submatrix is locally rank-1. $\tau_k < 1$: the relaxation is slack — a *certificate of inexactness*.

3.2 Loop residuals δ_k

A BFS spanning tree assigns angles θ_i from the slack bus. For each non-tree branch $k = (i, j)$, let $\phi_{ij}^{\text{dir}} = \arctan(W_{ij}^I/W_{ij}^R)$ be the phase implied by the SOCP solution, and $\phi_{ij}^{\text{tree}} = \theta_i - \theta_j$ the phase predicted by the tree path. Then:

$$\delta_k = \phi_{ij}^{\text{dir}} - \phi_{ij}^{\text{tree}} \quad (\text{wrapped to } (-\pi, \pi])$$

$\delta_k \neq 0$ signals that phase assignments around that fundamental cycle are *inconsistent*: no global phasor set can produce this W matrix, even when all $\tau_k = 1$.

Interpretation:

$\tau_k=1$ all k	$\delta_k=0$ all loops	Conclusion
No	—	Provably inexact
Yes	Yes	SOC exact; AC-feasible
Yes	No	Inexact (phase inconsistency)

4 Test Cases

Case	Buses	Lines	Key property
IEEE 14-bus	14	20	Meshed; $\tau \approx 1$, $ \delta \leq 4.3^\circ$
WB5	5	6	41% SOCP gap
C22 (uniform)	22	22	Ring; SOCP exact
C22 (asymm.)	22	22	Two AC optima; SOCP exact

4.1 IEEE 14-bus

Standard MATPOWER case; 5 generators, 3 transformers. project SOCP runs in *PF mode* (compared to Circuits NR as ground truth). Voltage bounds $[0.5, 1.5]$ pu (Q-limits widened: the model omits the Bus 9 shunt capacitor). SOCP is tight ($\tau \approx 1$) yet loop residuals reach 4.3° — illustrating that $\tau = 1$ everywhere does *not* certify AC-feasibility on a meshed network.

4.2 WB5

5-bus meshed network (Bukhsh et al. 2013). Bus 1: \$4/MWh; Bus 5: \$1/MWh. The cheap generator is reachable only via two high-impedance lines ($r = 0.55$, $x = 0.90$ pu), creating a non-convex bottleneck. Voltage bounds $[0.5, 1.5]$ pu. The canonical example of a non-zero SOCP duality gap.

4.3 Case22loop — uniform costs

22-bus ring; all 11 generators at \$2/MWh. One branch beyond the spanning tree creates one loop degree of freedom. Voltage bounds $[0.95, 1.05]$ pu. SOCP is exact: $\tau_k \approx 1$, $\delta = 0^\circ$.

4.4 Case22loop — asymmetric costs

Same ring; buses 1, 3, ..., 11 (cheap arc) at \$1/MWh; buses 13, ..., 21 (expensive arc) at \$4/MWh. The global optimum loads only the cheap arc; flat-start Circuits NR converges to a balanced but expensive solution. SOCP remains exact ($\delta = 0.74^\circ \approx 0$).

5 Results

5.1 WB5 duality gap

Solver	Obj. (\$/h)	Note
project DC OPF	325	Linear LB; no reactive/losses
project SOCP	740	Convex LB; Bus 5 at $V_{\max} = 1.5$ pu
pandapower AC OPF	1,256	True local AC optimum
Duality gap	515 (41%)	$\delta_{L04-05} = 1.58^\circ$

All SOC constraints are tight ($\max(1-\tau_k) \approx 3 \times 10^{-9}$) yet loop residuals are nonzero. The SOCP exploits freedom to assign inconsistent phases around the two fundamental cycles, reaching a cost that no physical voltage assignment can realise.

5.2 Case22loop: exactness and multiple optima

Solver	Uniform (\$/h)	Asymm. (\$/h)
project DC OPF	4,494	2,244
project SOCP	4,541	2,464
pandapower AC OPF	4,541	2,464
Circuits NR (flat)	4,544	5,336

On the asymmetric ring, Circuits NR (flat start) finds the balanced operating point at 5,336 \$/h; project SOCP and pandapower AC OPF find the globally optimal dispatch at 2,464 \$/h — a **116% cost difference** from routing power exclusively through the cheaper arc.

5.3 SOCP diagnostics summary

Case	$\max(1 - \tau_k)$	$\max \delta_k $	Gap
IEEE 14-bus	5×10^{-6}	4.3°	≈ 0
WB5	3×10^{-9}	1.58°	41%
C22 uniform	~ 0	0.0°	≈ 0
C22 asymm.	3×10^{-12}	0.74°	≈ 0

Key takeaway. $\tau_k \approx 1$ alone is insufficient to certify exactness. WB5 has tight SOC constraints everywhere yet a 41% duality gap — revealed only by its nonzero loop residuals. The ring cases satisfy both $\tau \approx 1$ *and* $\delta \approx 0^\circ$, confirming their SOCP solutions are globally AC-feasible and optimal.

On *radial* networks, the SOC relaxation is provably exact (Jabr 2006, Low 2014): no fundamental cycles exist, so loop residuals vanish, and $\tau_k = 1$ everywhere guarantees $\mathbf{W} = \mathbf{V}\mathbf{V}^H$ (rank-1). The SOCP yields the global AC OPF optimum at the cost of a single convex solve.

Solvers: project SOCP via CLARABEL/GUROBI/SCS (cvxpy); project DC OPF via cvxpy LP; Circuits NR and pandapower AC OPF via pandapower/PYPOWER. All powers in per-unit on a 100 MVA base.