

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# 291

Customer Sample Collection

Facility Name: Springhill Suites Date: 12/2/24
Time: 11:30 AM

Address: 16 Trinity Point Drive Method: Grab

Washington, PA 15301

Matrix: Recreational Water Sample Final Analysis

Date: 12/5/24

Source Type: Spa Time: 9:00 AM Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/3/24	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/3/24	9:30 AM	AS	SM 9222B
Standard plate count:	190/ml	200/ml	12/2/24	5:15 PM	AS	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	12/3/24	9:30 AM	AS	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.2 SU	7.2 - 7.8 SU	12/2/24	11:30 AM	JM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	12/2/24	11:30 AM	JM	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/2/24	11:30 AM	JM	Visual

Sample comments

andra Cmith I and Cinanicar

Chobie Smith

(When exceeding reporting limit pool or spa is unfit)



1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# 291

Customer Sample Collection

Facility Name: Springhill Suites Date: 12/2/24
Time: 11:30 AM

Address: 16 Trinity Point Drive Method: Grab

Washington, PA 15301

Matrix: Recreational Water Sample Final Analysis

Date: 12/5/24

Source Type: Spa Time: 9:00 AM Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/3/24	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/3/24	9:30 AM	AS	SM 9222B
Standard plate count:	190/ml	200/ml	12/2/24	5:15 PM	AS	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	12/3/24	9:30 AM	AS	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.2 SU	7.2 - 7.8 SU	12/2/24	11:30 AM	JM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	12/2/24	11:30 AM	JM	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/2/24	11:30 AM	JM	Visual

Sample comments

andra Cmith I and Cinanicar

Chobie Smith

(When exceeding reporting limit pool or spa is unfit)