1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab#   306

Customer

Facility Name:	*University of Pittsburgh*
Address:	*3501 Allequippa St.*
	Pittsburgh, PA 15260
Matrix:	*Recreational Water*
Source Type:	*Sm Pool Deep*

Sample Collection

Date:	*12/3/24*
Time:	3:00 PM
Method:	*Grab*

Sample Final Analysis

Date:	*12/6/24*
Time:	*9:00 AM*
Analyst:	*AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/4/24	11:00 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/4/24	11:00 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	12/3/24	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	12/3/24	3:00 PM	SCL	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	12/3/24	3:00 PM	SCL	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/3/24	3:00 PM	SCL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab# 306

Customer

Facility Name:	*University of Pittsburgh*
Address:	*3501 Allequippa St.* *Pittsburgh, PA 15260*
Matrix:	*Recreational Water*
Source Type:	*Sm Pool Deep*

Sample Collection

Date:	*12/3/24*
Time:	3:00 PM
Method:	*Grab*

Sample Final Analysis

Date:	*12/6/24*
Time:	*9:00 AM*
Analyst:	*AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/4/24	11:00 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/4/24	11:00 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	12/3/24	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	12/3/24	3:00 PM	SCL	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	12/3/24	3:00 PM	SCL	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/3/24	3:00 PM	SCL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)