



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041

W-1

Lab# 093

**Customer**

Facility Name: Doubletree Hotel  
Address: 8402 University Blvd.  
Moon, PA 15108

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 12/2/24  
Time: 9:18 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/5/24  
Time: 9:00 AM  
Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/3/24	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/3/24	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/2/24	5:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/2/24	9:18 AM	AH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/2/24	9:18 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/2/24	9:18 AM	AH	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041

W-1

Lab# 093

**Customer**

Facility Name: Doubletree Hotel  
Address: 8402 University Blvd.  
Moon, PA 15108

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 12/2/24  
Time: 9:18 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/5/24  
Time: 9:00 AM  
Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/3/24	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/3/24	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/2/24	5:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/2/24	9:18 AM	AH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/2/24	9:18 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/2/24	9:18 AM	AH	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)