

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

N-3

Lab# 450

Customer Facility Name:

Gold Fish

Address:

1115 Freeport Rd.

Fox Chapel, PA 15238

Matrix:

Recreational Water

Source Type: Pool Sample Collection

Date:

12/5/23

Time: Method: 9:08 AM Grab

Sample Final Analysis

Date:

12/8/23 9:00 AM

Time:

AS

Analyst:

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	9:55 AM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	9:55 AM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/5/23	4:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/5/23	9:08 AM	АН	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/5/23	9:08 AM	АН	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/5/23	9:08 AM	AH	Visual

Sample comments

Andre Smith, Lead Supervisor

andre Smith

(When exceeding reporting limit pool or spa is unfit)



1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

N-3

Lab# 450

Customer Facility Name:

Gold Fish

Address:

1115 Freeport Rd.

Fox Chapel, PA 15238

Matrix:

Recreational Water

Source Type: Pool Sample Collection

Date:

12/5/23

Time: Method: 9:08 AM Grab

Sample Final Analysis

Date:

12/8/23 9:00 AM

Time:

AS

Analyst:

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	9:55 AM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	9:55 AM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/5/23	4:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/5/23	9:08 AM	АН	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/5/23	9:08 AM	АН	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/5/23	9:08 AM	AH	Visual

Sample comments

Andre Smith, Lead Supervisor

andre Smith

(When exceeding reporting limit pool or spa is unfit)