

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

Service

Lab# 313

Customer Facility Name: UPMC Sports Rehab - Cranberry

Address: 8000 Cranberry Springs Drive

Cranberry Township, PA 16066

Matrix: Recreational Water

Source Type: Spa Sample Collection

Date: 12/3/24

Time: 9:15 AM Method: Grab

Sample Final Analysis

Date: 12/6/24

Time: 9:00 AM AS Analyst:

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/4/24	9:30 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/4/24	9:30 AM	PS	SM 9222B
Standard plate count:	190/ml	200/ml	12/3/24	3:40 PM	AS	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	12/4/24	9:00 AM	PS	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.5 SU	7.2 - 7.8 SU	12/3/24	9:15 AM	JP	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/3/24	9:15 AM	JP	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/3/24	9:15 AM	JP	Visual

Sample comments

andre Smith



1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

Service

Lab# 313

Customer Facility Name: UPMC Sports Rehab - Cranberry

Address: 8000 Cranberry Springs Drive

Cranberry Township, PA 16066

Matrix: Recreational Water

Source Type: Spa Sample Collection

Date: 12/3/24

Time: 9:15 AM Method: Grab

Sample Final Analysis

Date: 12/6/24

Time: 9:00 AM AS Analyst:

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/4/24	9:30 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/4/24	9:30 AM	PS	SM 9222B
Standard plate count:	190/ml	200/ml	12/3/24	3:40 PM	AS	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	12/4/24	9:00 AM	PS	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.5 SU	7.2 - 7.8 SU	12/3/24	9:15 AM	JP	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/3/24	9:15 AM	JP	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/3/24	9:15 AM	JP	Visual

Sample comments

andre Smith