



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 409

Customer

Facility Name: Best Western Cranberry
Address: 5001 Cranberry Springs Dr.
Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 12/5/23
Time: 11:05 AM
Method: Grab

Sample Final Analysis

Date: 12/8/23
Time: 9:00 AM
Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	10:45 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	10:45 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/5/23	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	12/5/23	11:05 AM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/5/23	11:05 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/5/23	11:05 AM	BH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 409

Customer

Facility Name: Best Western Cranberry
Address: 5001 Cranberry Springs Dr.
Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 12/5/23
Time: 11:05 AM
Method: Grab

Sample Final Analysis

Date: 12/8/23
Time: 9:00 AM
Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	10:45 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	10:45 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/5/23	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	12/5/23	11:05 AM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/5/23	11:05 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/5/23	11:05 AM	BH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)