



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# 029

Customer

Facility Name: Fairfield Inn
Address: 451 Racetrack Rd.
Washington, PA 15301

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 12/2/24
Time: 1:00 PM
Method: Grab

Sample Final Analysis

Date: 12/5/24
Time: 9:00 AM
Analyst: AS

| Laboratory Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 12/3/24 | 9:30 AM | AS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 12/3/24 | 9:30 AM | AS | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 12/2/24 | 5:15 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method | |
|----------------|----------|-----------------|-----------|---------|--------|--------|
| pH: | 7.2 SU | 7.2 - 7.8 SU | 12/2/24 | 1:00 PM | JM | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 12/2/24 | 1:00 PM | JM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 12/2/24 | 1:00 PM | JM | Visual |

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# 029

Customer

Facility Name: Fairfield Inn
Address: 451 Racetrack Rd.
Washington, PA 15301

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 12/2/24
Time: 1:00 PM
Method: Grab

Sample Final Analysis

Date: 12/5/24
Time: 9:00 AM
Analyst: AS

| Laboratory Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 12/3/24 | 9:30 AM | AS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 12/3/24 | 9:30 AM | AS | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 12/2/24 | 5:15 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method | |
|----------------|----------|-----------------|-----------|---------|--------|--------|
| pH: | 7.2 SU | 7.2 - 7.8 SU | 12/2/24 | 1:00 PM | JM | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 12/2/24 | 1:00 PM | JM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 12/2/24 | 1:00 PM | JM | Visual |

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith