



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 062

Customer

Facility Name: Comfort Inn - Butler

Address: 1 Comfort Ln.
Butler, PA 16001

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 12/5/23

Time: 2:40 PM

Method: Grab

Sample Final Analysis

Date: 12/8/23

Time: 9:00 AM

Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	10:45 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	10:45 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/5/23	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/5/23	2:40 PM	BH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	12/5/23	2:40 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/5/23	2:40 PM	BH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 062

Customer

Facility Name: Comfort Inn - Butler

Address: 1 Comfort Ln.
Butler, PA 16001

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 12/5/23

Time: 2:40 PM

Method: Grab

Sample Final Analysis

Date: 12/8/23

Time: 9:00 AM

Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	10:45 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	10:45 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/5/23	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/5/23	2:40 PM	BH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	12/5/23	2:40 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/5/23	2:40 PM	BH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)