

## 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

E-1

Lab# 454

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Hampton Inn Date: 12/4/24

Address: 3000 Mosside Blvd. Time: 11:40 AM Method: Grab

Monroeville, PA 15146

Matrix: Recreational Water Sample Final Analysis

Date: 12/7/24

Source Type: Pool Time: 9:00 AM
Analyst: AS

**Laboratory Analysis** Results Reporting limit **Analyst** Method **Incubation Date/Time** Escherichia Coli: Absent Absent 12/5/24 9:50 AM AS SM 9222G Total coliforms: 0/100mls 2/100mls AS SM 9222B 12/5/24 9:50 AM Standard plate count: 0/ml 200/ml 12/4/24 6:00 PM AS SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/4/24	11:40 AM	SH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/4/24	11:40 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/4/24	11:40 AM	SH	Visual

## Sample comments

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

anobie Smith



## 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

E-1

Lab# 454

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Hampton Inn Date: 12/4/24

Address: 3000 Mosside Blvd. Time: 11:40 AM Method: Grab

Monroeville, PA 15146

Matrix: Recreational Water Sample Final Analysis

Date: 12/7/24

Source Type: Pool Time: 9:00 AM
Analyst: AS

**Laboratory Analysis** Results Reporting limit **Analyst** Method **Incubation Date/Time** Escherichia Coli: Absent Absent 12/5/24 9:50 AM AS SM 9222G Total coliforms: 0/100mls 2/100mls AS SM 9222B 12/5/24 9:50 AM Standard plate count: 0/ml 200/ml 12/4/24 6:00 PM AS SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/4/24	11:40 AM	SH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/4/24	11:40 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/4/24	11:40 AM	SH	Visual

## Sample comments

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

anobie Smith