



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 154

Customer

Facility Name: Hilton Garden Inn
Address: 2000 Garden View
Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 12/2/24
Time: 9:09 AM
Method: Grab

Sample Final Analysis

Date: 12/5/24
Time: 9:00 AM
Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	12/3/24 9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/3/24 9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/2/24 5:15 PM	AS	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	12/3/24 9:30 AM	AS	SM 9230C
---------------------	----------	----------	-----------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.6 SU	7.2 - 7.8 SU	12/2/24 9:09 AM	SCL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/2/24 9:09 AM	SCL	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/2/24 9:09 AM	SCL	Visual

Sample comments

Andrea Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 154

Customer

Facility Name: Hilton Garden Inn
Address: 2000 Garden View
Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 12/2/24
Time: 9:09 AM
Method: Grab

Sample Final Analysis

Date: 12/5/24
Time: 9:00 AM
Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	12/3/24 9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/3/24 9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/2/24 5:15 PM	AS	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	12/3/24 9:30 AM	AS	SM 9230C
---------------------	----------	----------	-----------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.6 SU	7.2 - 7.8 SU	12/2/24 9:09 AM	SCL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/2/24 9:09 AM	SCL	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/2/24 9:09 AM	SCL	Visual

Sample comments

Andrea Smith, Lead Supervisor

Andrea Smith

(When exceeding reporting limit pool or spa is unfit)