

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Method:

Lab ID No. 02-04041

Service

Lab# 379

Grab

2/8/24

Sample Final Analysis

Sample Collection Customer

Facility Name: PPG Paints Arena Date: 2/5/24 9:35 AM Time:

Address: Pittsburgh, PA 15219

1001 Fifth Ave

Matrix: Recreational Water Date:

Time: 9:00 AM Source Type: Spa Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	2/6/24	9:50 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/6/24	9:50 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	2/5/24	4:49 PM	DG	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	1/0/00	12:00 AM	0	SM 9230C

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
рН:	7.4 SU	7.2 - 7.8 SU	2/5/24	9:35 AM	ВН	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	2/5/24	9:35 AM	ВН	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/5/24	9:35 AM	ВН	Visual

Sample comments

Andre Smith, Lead Supervisor

andre Smith

(When exceeding reporting limit pool or spa is unfit)



1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Method:

Lab ID No. 02-04041

Service

Lab# 379

Grab

2/8/24

Sample Final Analysis

Sample Collection Customer

Facility Name: PPG Paints Arena Date: 2/5/24 9:35 AM Time:

Address: Pittsburgh, PA 15219

1001 Fifth Ave

Matrix: Recreational Water Date:

Time: 9:00 AM Source Type: Spa Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	2/6/24	9:50 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/6/24	9:50 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	2/5/24	4:49 PM	DG	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	1/0/00	12:00 AM	0	SM 9230C

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
рН:	7.4 SU	7.2 - 7.8 SU	2/5/24	9:35 AM	ВН	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	2/5/24	9:35 AM	ВН	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/5/24	9:35 AM	ВН	Visual

Sample comments

Andre Smith, Lead Supervisor

andre Smith

(When exceeding reporting limit pool or spa is unfit)