



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041

P.P.S.

Lab# 010

**Customer**

Facility Name: Arsenal Middle  
Address: 220 40th St.  
Pittsburgh, PA 15201

Matrix: Recreational Water

Source Type: Pool Shallow

**Sample Collection**

Date: 12/3/24  
Time: 8:30 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/6/24  
Time: 9:00 AM  
Analyst: AS

| Laboratory Analysis   | Results  | Reporting limit | Rating | Incubation | Date/Time | Analyst | Method   |
|-----------------------|----------|-----------------|--------|------------|-----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | A      | 12/4/24    | 10:15 AM  | PS      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | A      | 12/4/24    | 10:15 AM  | PS      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | A      | 12/3/24    | 5:40 PM   | AS      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Rating |         | Date/Time | Analyst | Method |
|----------------|----------|-----------------|--------|---------|-----------|---------|--------|
| pH:            | 7.4 SU   | 7.2 - 7.8 SU    | A      | 12/3/24 | 8:30 AM   | JM      | DPD    |
| Chlorine:      | 3.0 mg/l | 1.0 - 5.0 mg/l  | A      | 12/3/24 | 8:30 AM   | JM      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | A      | 12/3/24 | 8:30 AM   | JM      | Visual |

**Sample comments**

Andre Smith, Lead Supervisor

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041

P.P.S.

Lab# 010

**Customer**

Facility Name: Arsenal Middle  
Address: 220 40th St.  
Pittsburgh, PA 15201

Matrix: Recreational Water

Source Type: Pool Shallow

**Sample Collection**

Date: 12/3/24  
Time: 8:30 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/6/24  
Time: 9:00 AM  
Analyst: AS

| Laboratory Analysis   | Results  | Reporting limit | Rating | Incubation | Date/Time | Analyst | Method   |
|-----------------------|----------|-----------------|--------|------------|-----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | A      | 12/4/24    | 10:15 AM  | PS      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | A      | 12/4/24    | 10:15 AM  | PS      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | A      | 12/3/24    | 5:40 PM   | AS      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Rating |         | Date/Time | Analyst | Method |
|----------------|----------|-----------------|--------|---------|-----------|---------|--------|
| pH:            | 7.4 SU   | 7.2 - 7.8 SU    | A      | 12/3/24 | 8:30 AM   | JM      | DPD    |
| Chlorine:      | 3.0 mg/l | 1.0 - 5.0 mg/l  | A      | 12/3/24 | 8:30 AM   | JM      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | A      | 12/3/24 | 8:30 AM   | JM      | Visual |

**Sample comments**

Andre Smith, Lead Supervisor

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)